

**FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE**

[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2017/W2/586

Dated: 27/4 /2017

**FIRE SAFETY CERTIFICATE**

Certified that M/s Capital Vehicles Sales Ltd. (Formerly FSC issued to Ginni Polymers) located at Basement + Ground Floor, Plot No. C-1, Udyog Nagar, Rohtak, Road, New Delhi-110041 in a building comprised of Basement + Ground + 1 upper Floor (Sealed) was earlier issued Fire Safety Certificate vide letter No. F6/MS/DFS/2003/238 dated 31/01/2003. The premises was re-inspected by the officer concerned of Fire Service on 13.04.2017 in presence of Mr. Harish Arora and observed that all the fire prevention & fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy class **Industrial Group (G)** with effect from 27 / 4 /2017 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued on..... 27/4/17 .....at New Delhi by.

(ATUL GARG)

CHIEF FIRE OFFICER.

Copy to:

1. Authorized Signatory, Capital Vehicle Sales Pvt. Ltd., C-1, Udyog Nagar, Rohtak, Road, New Delhi-110041.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)
8. Basement shall be used strictly as per Building By-Laws 1983.
9. The First Floor is sealed and shall not be used for any purpose.

1. Name & address of the building: Capital Vehicle Sales Pvt. Ltd., C-1, Udyog Nagar,  
Rohtak, Road, New Delhi-110041.
2. Type of Occupancy : Industrial Basement, Ground Floor only
3. Type of Case : Renewal
4. Details of previous NOC : F6/MS/DFS/2003/238 dated 31/01/2003
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/99/1797 dated 20/12/1999
6. Date of inspection : 13/04/2017
7. Name of the Inspecting Officer : A.K. Jaiswal.(A.D.O.)
8. Name and designation of Officer  
from the building side : Mr. Harish Arora
9. Year of Construction : 1999
10. Applicant's letter No. : - 22/03/2017

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL / NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	6 mtr	MR
	• Gate width	5 mtr	5 mtr	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	N/A	N/A	N/A
	• Basements	2	3	MR
	b. Width of staircases			
	• Upper floors	N/A	N/A	N/A
	• Basements	1.25 mtr	1.25mtr x 3	N/A
	c. Protection of exits			
	• Fire check door	Required (Basement)	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	N/A	N/A	N/A
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	1.20 mtr	1.20 mtr	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	N/A	Provided	N/A
5.	Fire Extinguishers			
	• Total numbers	18	25	MR
	• Types	ISI marked ABC/CO <sub>2</sub>	Provided	MR



	• Total numbers on each floor	1	1	MR
	• Length of hose reel hose	30 Mtr.	30Mtr.	MR
	• Nozzle diameter	5 mm.	5 mm.	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	150 mm	150 mm	MR
	• Number of hydrants per floor	1	1	MR
	• Hose Box	1	1	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	Provided	N/A
	• Hose Box	N/A	Provided	N/A
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	Not mentioned in the guidelines dated 20/12/1999	1620 LPM (As per previous NOC dated 31/01/2003)	MR
	➤ Head of main pump	Not mentioned in the guidelines dated 20/12/1999	40 MH	MR
	➤ Number of main pumps	Not mentioned in the guidelines dated 20/12/1999	2 (As per previous NOC dated 31/01/2003)	MR
	➤ Jockey pump out put	Not mentioned in the guidelines dated 20/12/1999	180 LPM (As per previous NOC dated 31/01/2003)	MR
	➤ Jockey pump head	Not mentioned in the guidelines dated 20/12/1999	40 MH	MR
	➤ Standby Pump out put	Not mentioned in the guidelines dated 20/12/1999	1620 LPM (As per previous NOC dated 31/01/2003)	MR
	➤ Standby Pump Head	Not mentioned in the guidelines dated 20/12/1999	40 MH	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	NR	450 LPM	NR
	➤ Head of the pump	NR	40 MH	NR
	➤ Power supply	NR	Provided	NR
	➤ Auto starting of pump	NR	Provided	NR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	1,00,000 ltr	1,00,000 lts	MR
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A



		Required	Provided	M/R
15	Exit Signage			
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note:- Owner of the building Mr. Harish Arora has submitted an undertaking in the form of affidavit bearing certificate No. IN-DL 142314739483760 dated 26/10/2016 that:-

1. First Floor of the building is permanently Closed / Sealed.
2. Will not use 1<sup>st</sup> floor in future as this is permanently Closed / Sealed.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. MCB and Conduit Metal Wiring has also been provided.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/MS/DFS/2003/238 dated 31/01/2003 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

D.O.// (w)

*[Signature]*  
18/4/17

Dy. CFO (WZ) MIR

*[Signature]*  
20/4/17

FT PLS

*[Signature]*  
13.4.17

Signature of the Inspecting Officer

Name : A.K. Jaiswal

Designation : A.D.O. (Jwala Puri)