

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/2017/WZ/ 597

Dated: 27/04/2017

**FIRE SAFETY CERTIFICATE**

Certified that the **Cherish Banquet Hall** Located at **C-94, Wazipur Industrial Area, New Delhi-110052** in a building comprised of Basement + Ground Floor + 02 Upper Floor own/occupied by **Cherish Banquet Hall** was issued FSC vide Letter No. F6/DFS/MS/2014/WZ/93 Dated – 23/01/2014. The premises was re inspected by the officers concerned of this department on 17-04-2017 in the presence of **Sh. Sarwasv Bhatia (Manager)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class “ Assembly” Group D with effect from 27/4/17 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 27/4/17..... at New Delhi by.

(Atul Garg)  
Chief Fire Officer  
Delhi Fire Service

Copy to:

Sh. Sarwasv Bhatia (Manager), Cherish Banquet Hall, C-94, Wazipur Industrial Area, New Delhi-110052.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

**INSPECTION REPORT**

1. Name & address of the building: **Cherish Banquet Hall** Located at **C-94, Wazipur Industrial Area, New Delhi-110052.**
2. Type of Occupancy : Banquet, (Assembly) Basement+ Ground Floor + Two UFs
3. Type of Case : Renewal
4. Details of previous NOC ; F6/DFS/MS/2014/WZ/93 Dated – 23/01/2014
5. Fire Safety directives Letter No. : F-6/DFS/MS/BP/2007/1678 Dated 27/06/2007
6. Date of inspection . 17-04-2017
7. Name of the Inspecting Officer : Udai vir Singh ADO (WP)
8. Name and designation of Officer from the building side : Sh. Sarwasv Bhatia (Manager)
9. Year of Construction : 2008
10. Applicant's letter No. : Nil Dated – nil

S N o	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	Provided	MR
	• Gate width	Required	Provided	MR
	• Width of internal road	Old case	Old case	Old case
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	3	3	MR
	• Upper floors	3	3	MR
	• Basements	2 stair one ramp	2 stair one ramp	MR
	b. Width of staircases			
	• Upper floors	Old case	1x120cm, 1x195cm, 1x200cm	MR
	• Basements	Old case	1x125cm & 1x225cm, Ramp 1x286 cm	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	2	Provided	MR
	e. Width Of Corridor	Old case	Old case	Old case
	f. Door Size	2m	GF=2x240cm, 2x200cm, FF= 2x169, & 2x200cm, SF= 2x204cm, 1x195 cm & 1x152cm	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	Required	Provided	MR
	• Fire Dampers	Required	Provided	MR
4.	Smoke managements System			
	• Basements	Required	Exhaust fans Provided	MR
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			

	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 m	Provided	MR
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	Smoke & Heat	Provided & functional	MR
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Hooters' Location</li> </ul>	On each Floor	Provided	MR
8.	MOEFA	Required	Provided & functional	MR
9.	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basements</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	Required	Provided	MR
11	Internal Hydrants			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	150 mm	Provided	MR
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	2	Provided	MR
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	2	Provided	MR
12	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	Required	Provided	MR
13	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>			
	<ul style="list-style-type: none"> <li>Discharge of main pump</li> </ul>	2280 lpm	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Head of main pump</li> </ul>	60 m	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Number of main pumps</li> </ul>	1	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Jockey pump out put</li> </ul>	180 lpm	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Jockey pump head</li> </ul>	60 m	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Standby Pump out put</li> </ul>	2280 lpm	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Standby Pump Head</li> </ul>	60 m	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Auto Starting/Manual, stopping</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Terrace level</li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of pump</li> </ul>	900 lpm	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Head of the pump</li> </ul>	60 m	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Power supply</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Auto starting of pump</li> </ul>	Required	Required	MR
14	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> <li>Under ground tank capacity</li> </ul>	50,000 ltrs	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Draw of connection</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Access to tank</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Overhead Tank capacity</li> </ul>	10, 000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR

	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided 125 KVA	MR
18	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20	Special Fire Protection Systems for Protection of special Risks, if any;	LPG Bank in rear side on ground	Gas sensor D.C.P. fire extinguishers are Provided	NR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter no.F6/DFS/MS/2014/WZ/93 Dated – 23/01/2014 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer  
 Name Uda Vir Singh  
 Designation ADO/WP

Signature of the Inspecting Officer  
 Name  
 Designation

DO/W 20/9/17  
 Dy. CPO (W2) - MR  
 CPO (West) 20/9/17  
DO/W VTP/L  
 ADO/WP 20/9/17