


No. F6/DFS/MS/School/2017/SZ/ 107/

Dated: 26/4/17

FIRE SAFETY CERTIFICATE

Certified that **Good Samaritan Senior Secondary School** located at **Sector-8, Jasola, New Delhi-110025**, comprised of **Ground + Three upper floors** was granted FSC by this department vide letter no. F.6/DFS/MS/School/2014/SZ/8 dated 01/01/2014. The building/premises was re-inspected by officer concerned of this department on 01.04.2017 in the presence of Mr. Chakravarti (Admn Manager) of the school and found that said school building have deemed complied with the fire prevention and fire safety arrangements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "**Educational Building, Group-B**" as above with effect from 26/4/2017 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the condition under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 26/4/17 at New Delhi by


(Vipin Kental)
Chief Fire Officer

Copy to: -

1. The Founder Manager, Good Samaritan Sr. Sec. School, Sector-8, Jasola, New Delhi-25
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT				
1	Name & Address of the Building	Good Samaritan Senior Secondary School, Sector-8, Jasola, New Delhi-110025		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Ground + Three upper floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS//School2014/SZ/8 Dated 01-01-2014		
6	Fire Safety Directives Letter No	F.6/DFS/MS/2002/517 Dated 26-03-2002		
7	Date of Inspection	01-04-2017		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mr. Chakravarti (Admn Manager)		
10	Year of construction	2002		
11	Applicant letter No.	Nil dated 07/02/2017		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Dt. 17-11-2005 requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Accessible	9 mtr	MR
	• Gate width	5 mtr	5 mtr	MR
	• Width of internal road	N/A	6 mtr provided	N/A
2	Number, width, type & arrangement of exits			
	a. Number of Staircase			
	➤ Upper floors	4 No's	4 No's	MR
	➤ Basement floor	N/A	N/A	N/A
	b. Width of Staircase			
	➤ Upper floors	1.5 mtr each	1.5 mtr each	MR
	➤ Basement floor	N/A	N/A	N/A
	c. Protection of exits			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Required	4 No's	MR
	e. Width of corridor	1.5 mtr	Provided	MR
	f. Door size	N/A	1.15 mtr	N/A
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4.	Smoke Management system.			
	• Basement	30a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	N/A	N/A
5.	Fire Extinguishers.			
	• Total numbers	30 No's	38 No's	MR
	• Types	ISI Marked	ABC-30, Co2-08	MR
	• ISI Marking		Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.		4 No's	MR
	• Length of hose-reel hose.	Hose-reels	30 mtr	MR
	• Nozzle Diameter		5 mm	MR

Renewal

Good Samaritan Sr. Sec. School, Sec-8, Jasola, ND-25

7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8.	MOEFA /Electric Alarm	N/A	Provided	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement. Upper floors Sprinkler above false ceiling 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	Required	150 mm	MR
		Required	4 No's	MR
		Required	4 No's	MR
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	N/A	Provided	N/A
		N/A	Provided	N/A
13.	Pumping arrangements.			
	a) Ground Level			
	➤ Discharge of main pump.	1620 LPM	1620 LPM	MR
	➤ Head of main pump.	54 mtr	54 mtr	MR
	➤ Number of main pumps.	One	One	MR
	➤ Jockey Pump output.	225 LPM	225 LPM	MR
	➤ Jockey Pump head.	54 mtr	54 mtr	MR
	➤ Standby Pump output.	1620 LPM	1620 LPM	MR
	➤ Standby Pump head.	54 mtr	54 mtr	MR
	➤ Auto Starting / Manual Stopping.	Required	Provided	MR
	b) Terrace Level			
	➤ Discharge of pump.	450 LPM	450 LPM	MR
	➤ Head of pump.	40 mtr	40 mtr	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	50,000 Ltr	50,000 Ltr	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		10,000 Ltr	10,000 Ltr	MR
15.	Exit Signage.	N/A	Provided	N/A
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby Power Supply	N/A	Provided	N/A
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	N/A	N/A	N/A
		N/A	N/A	N/A

N/15

19.	Fire Control Room.			
	• Detector System Panel.	N/A	N/A	N/A
	• Flow Switch Panel.	N/A	N/A	N/A
	• PA system Panel.	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for the Protection of special Risk, if any.	N/A	01 ABC & 01 Co2 type fire extinguisher found provided near electrical panel	N/A

The Fire protection systems provided in the building were checked randomly and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rule, FSC issued vide letter No. F6/DFS/MS/School/2014/SZ/8 dated 01-01-2014, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended

Accordingly DFA is put up for approval and signature please.

R.N. Singh
12/4

Signature of the Inspecting Officer
Name : R.N. Singh
Designation: ADO

Renewal

Good Samaritan Sr. Sec. School, Sec-8, Jasola, ND-25

D. O. (SD)

Prakash
12/4/14

By CPO/CS2

798/CS2
08/4/12/2014

ADMP
13/4

FT 107.

CFO (Sp) m's cell

W
17/4

F.T letter is put up for sign. plz

CPO/SP

W
19/4

m's cell

W
24/4

