

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No.F6/DFS/MS/School/2017/NDZ/ 589

Dated: 25/4/17

FIRE SAFETY CERTIFICATE

Certified that the Govt. Girls Sr.Sec.School Khichripur, Delhi-91, owned/occupied by Govt. Girls Sr.Sec.School Comprised of ground floor only was granted FSC vide letter no. F6/DFS/MS/School/2014/NDZ/52 dated 13/01/14..The school building was inspected by the officer concerned of this department on 08/03/17 in the presence of Mrs. Shashi Kapoor (Vice-Principal) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular of Director of Education and ground floor of building is fit for occupancy class B "Educational Building" with effect from ...25/4/17..... for a period of **three** years, subject to conditions printed overleaf.

Issued on ...25/4/17..... at New Delhi by

u
12/4.
(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

gcs

To,

The Vice-Principal (Ist & IInd Shift)
Govt. Girls Sr.Sec.School Khichripur, Delhi-91.

Copy to:-

The Joint Director of Education, (Land & Estate)
Director of Education, Lucknow Road, Delhi-54.

Conditions -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. "The owner /occupier shall apply for renewal of this Fire Safety certificate to the Director inform 'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"
7. The owner / occupier shall submit a declaration every year in form 'K' provided schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

N/10

1. Name & address of the building : Govt. Girls Sr. Sec. School Khichripur, Delhi-91.
 2. Building is comprised of : Ground floor only ✓
 3. Type of Occupancy : Educational ✓
 4. Type of Case : Renewal
 5. Details of Previous NOC letter : F6/DFS/MS/School/2014/NDZ/52 dated 13/01/14
 6. Fire Safety direction letter No : Director of Education
 7. Date of Inspection : 08/03/17
 8. Name of the Inspecting officers : ADO R.K. Yadav ✓
 9. Name and designation of Officer from the building side : Mrs. Shashi Kapoor
 10. Year of Construction : 1980
 11. Applicant's letter No : G.G.S.S.S./KHP/66 Date 08/02/17

Sr. No	Minimum Standards on Fire Prevention and Fire Safety U/R33	Circular Requirement	Provided at Site	Remarks
01	Access to Building			MR/NMR
	• Road width	06 m.	12 m.	MR ✓
	• Gate width	4.5 m	4.5 m	MR
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	b. Width of Staircases			
	• Upper floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	01 m	01 m	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers			
	• Total numbers	09 nos.	15 nos.	MR ✓
	• types	ABC /CO ₂	ABC /CO ₂	MR ✓
	• IS marking	ISI marked	ISI marked	MR ✓

N/11

06	First-Aid-Hose Reels.			
	Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA			
09	Public Address System.			
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main Pump	N/A	N/A	N/A
	• Head of Main Pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump Head	N/A	N/A	N/A
	• Auto Starting /Manual stopping	N/A	N/A	N/A
	• Pump House Access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	N/A	N/A	N/A
	• Head of the Pump	N/A	N/A	N/A
	• Power supply	N/A	N/A	N/A
	• Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage.			
		N/A	N/A	N/A

Gaut. Gint' Sr. Sec. School, Khichrupur

N/12

Gaut. Govt. Sec. School Khuchapau

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply			
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:			
		N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection. This department had issued already FSC vide letter no. F6/DFS/MS/School/2014/NDZ/52 dated 13/01/14.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the Circular of Director of Education(GNCTD) is recommended to renew Fire Safety Certificate.

R. K. Yadav

Signature of the Inspecting Officer 29/3/2017
 Name: R. K. Yadav
 Designation: ADO(LN)

DO(ED)

R.K.P.
29/3

DCFO(NDZ)

[Signature]

148/Chk 22
22/4/17

CFP - M. Seenu

FT/M.

3/4/17

Say FT letter & put up for sign. pl

R.K.P.
12/4/2017

M. Seenu *[Signature]*