

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/EH/2017/WZ/ 586

Dated: 25/4/2017

FIRE SAFETY CERTIFICATE

Certified that the **Mc Donalds Family Restaurant by Connaught Plaza Restaurants Pvt. Ltd, Anchor No-01, Ground Floor, D Mall, Netaji Subhash Place Pitampura, Delhi- 110034**, in a mall comprised of three Basement + Ground + 12 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/EH/2014/WZ/327 dated 10-03-14 and the mall has issued FSC vide letter no. F6/DFS/MS//2015/WZ/1331 dated 23-07-15. The premises was re inspected by the officers concerned of this department on 21-03-2017 in the presence of Mr. Ravi Arora (Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly Building" Group D with effect from 25/4/17 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ... 25/4/17 at New Delhi by.


(Atul Garg)
Chief Fire Officer
Delhi Fire Service

Copy to: Sh. Ravi Arora (Authorized Signatory) Anchor No-03,19,20,Ground Floor, D Mall, Netaji Subhash Place, Pitampura, Delhi – 110034.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1 Name & address of the building: **Mc Donalds Family Restaurant by Connaught Plaza Restaurants Pvt.Ltd, Anchor No-01,Ground Floor, D Mall, Netaji Subhash Place Pitampura, Delhi- 110034.**

2. Occupancy : Assembly(Restaurant)
3. Type of Case : Renewal (The Mall has already issued FSC Vide Letter no. F6/DFS/MS/WZ/2015/1331 dated -23/07/2015
4. Details of previous NOC : Letter No. F6/DFS/MS/EH/2014/WZ/327 dated 10-03-14.
5. Fire Safety directives Letter No. : Issued to the mall
6. Date of inspection : 21-03-2017
7. Name of the Inspecting Officer : Udai vir Singh ADO (WP)
8. Name and designation of Officer
from the building side : Sh. Ravi Arora (Manager)
9. Year of Construction : 2010
10. Applicant's letter No. :CPRPL/FM/NOC/2016-17/225 Dated 27-02-2017

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 m	30m Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits (Common with Mall)			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	Old case	1x165cm,1x118cm	MR(Old case)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c per hour	Provided By Mall	MR
	• Upper floors	12 a/c per hour	Provided By Mall	MR
5.	Fire Extinguishers			
	Total numbers	2 nos	Provided	MR

6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke & Heat	Provided By Mall	MR
	• Location of Main Panel	Required	Provided By Mall	MR
	• Location of Repeater Panel	NA	Provided By Mall	MR
	• Alternate source of power	Required	Provided By Mall	MR
	• Hooters' Location	Required	Provided By Mall	MR
8.	MOEFA	Required	Provided By Mall	MR
9.	Public Address System	NA	Provided By Mall	MR
10.	Automatic Sprinkler System	Common With Mall		
	• Basements	Not Required	Provided By Mall	MR
	• Upper Floor	Not Required	Provided By Mall	MR
	• Sprinkler above false ceiling	Not Required	Provided By Mall	MR
11.	Internal Hydrants	Common With Mall		
	• Size of riser/down- comer	150 mm	Provided By Mall	MR
	• Number of hydrants per floor	1	Provided By Mall	MR
	• Hose Box	Required	Provided By Mall	MR
12.	Yard Hydrants	Common With Mall		
	• Total number of hydrants	NA	Provided By Mall	MR
	• Hose Box	NA	Provided By Mall	MR
13.	Pumping Arrangements	Common With Mall		
	• Ground Level			
	• Discharge of main pump	NA	4500 lpm Provided By Mall	MR
	➤ Head of main pump	NA	65m Provided By Mall	MR
	➤ Number of main pumps	NA	2 Provided By Mall	MR
	➤ Jockey pump out put	NA	180 lpm Provided By Mall	MR
	➤ Jockey pump head	NA	65m Provided By Mall	MR
	➤ Standby Pump out put	NA	4500lpm Provided By Mall	MR
	➤ Standby Pump Head	NA	65m Provided By Mall	MR
	➤ Auto Staring/Manual stopping	NA	Provided	MR
	➤ Pump House Access	NA	Provided	MR
	• Terrace level	900 LPM	Provided By Mall	MR
	➤ Discharge of pump	40 m	Provided By Mall	MR
	➤ Head of the pump	Required	Provided By Mall	MR
	➤ Power supply	Required	Provided By Mall	MR
	➤ Auto starting of pump	Required	Provided By Mall	MR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	NA	Common with the mall	MR
	➤ Draw of connection	NA	Common with the mall	MR
	➤ Fire service inlet	Required	Common with the mall	MR
	➤ Access to tank	NA	Common with the mall	MR
	• Overhead Tank capacity	10, 000 litres	50,000 ltr Common with the mall	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA

D.M.

17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection. In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide Letter No. F6/DFS/MS/EH/2014/WZ/327 dated 10-03-14 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Uday Var Singh
23/3/17

Name

Designation

ASO/wp

Designation

Upto 3/4/17
Dr. P. O. (N2)
CFO west
10/4/17
FT Pls

ASO/wp

Sir R4 letter is put for sign

Pls

24/3/17