

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001


No. F6/DFS/MS/SCHOOL/2017/ W2/583

Dated: 25/4/17

FIRE SAFETY CERTIFICATE

Certified that Perna Model School (ID-1556354) located at 55-56, Rishal Garden, Nangloi, Delhi-110041, comprised of Ground Floor and 1st Floor with school running on Ground Floor only owned / occupied by Perna Model School, has already been issued NOC / FSC by this department vide letter No. F6/DFS/MS/School/2013/WZ/1104 dated 21/10/2013. The premises was re-inspected by the officer concerned of this department on 12.04.2017 in the presence of Sh. Tripurary Roy (Teacher) and observed that Fire prevention and fire safety arrangements provided in the premises, found in good working condition. The premises have therefore, deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by Director of Education, GNCT of Delhi vide letter dated 01.03.2011 and that the building / premises is fit for occupancy class Educational (Group B) with effect from 25.4.17.....for a period of 3 (three) years subject to conditions printed below.

Issued on 25/4/17 at New Delhi by.


(Atul Garg)
Chief Fire Officer.

Copy to :-

1. The Manager, Perna Model School (ID-1556354), 55-56, Rishal Garden, Nangloi, Delhi-41.
- Conditions for the validity of Fire Safety Certificate:**
1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
 2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
 3. The trained fire fighting staff should be available round the clock.
 4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
 5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
 6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

School at GF

1. Name & address of the building: **Prerna Model School (ID-1556354), 55-56, Rishal Garden, Nangloi, Delhi-110041.**
2. Type of Occupancy : **Educational (Ground Floor only)**
3. Type of Case : **Renewal(Total Area-200Yard² & Cov.A.-200Y²)**
4. Details of previous NOC : **F6/DFS/MS/School/2013/WZ/1104 dated 21/10/2013**
5. Fire Safety directives Letter No. : **DOE Circular dated 01.03.2011**
6. Date of inspection : **12/04/2017** *Students = 175*
7. Name of the Inspecting Officer : **A. K. Jaiswal** *Class Rooms = 6*
8. Name and designation of Officer
from the building side : **Sh. Tripurary Roy (Teacher)**
9. Year of Construction : **2000**
10. Applicant's letter No. : **2218 dated 15/03/2017**

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE Circ. Dated 01/3/2011 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	6 mtr	MR
	• Gate width	4.5 mtr	4.5 mtr	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	No basement	N/A	N/A
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	N/A	N/A	N/A
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1.00 Mtr.	1.00 Mtr	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	2	3	MR
	• Types	ISI marked ABC/CO ₂	Provided	M/R
	• IS marking			

	each floor			N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level	N/A		
	• Discharge of main pump	N/A	N/A	
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A

15.	Exit Signage	N/A	N/A	N/A
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Batter backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note:-A) General requirements for schools as per Director of Education circular dated 01/03/2011.

1. Escape route Clear.....
2. LPG cylinders in laboratories Nil.....
3. Electric wiring ...Conduit Wiring..... MCB and ELCB
Electric circuit
4. Electric meter boardNot under the staircase.....
5. Basement use as per BBL 1983NA.....
6. Emergency telephone no. boardDisplayed.....
7. Generator setNil.....

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/School/2013/WZ/1104 dated 21/10/2013 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Note: Bldg. comprised of G+1st floor, but school is running only at G.F. There is room on 1st floor where caretaker is residing.

D.O./CO

[Signature] 17/4/17

Dy. CFO (WZ) MR

[Signature]
13/4/17

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : A.D.O. (Jwala Puri)