

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F.6/DFS/MS/EH/WZ/2017/ 609

Dated: 28/04/2017

FIRE SAFETY CERTIFICATE

Certified that M/s Mc Donald's Family Restaurant located at Ground floor of Unitech Rohini Metro Walk, Shop No 01-03 Sector 10, Rohini, Delhi-110085 in the building comprised Ground plus one upper floor was granted NOC by this department vide letter no F-6/DFS/MS/EH/2014/WZ/482 Dated 16/04/2014. The premises was re-inspected by the officers concerned of this department on 06/04/2017 in the presence of Mrs. Shilpa (Manager) and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and premises is fit for Assembly occupancy with effect from 28/04/17 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of fire safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 28/04/17 at New Delhi by


(Atul Garg)

Chief Fire Officer

Ph: 011-23414250

Copy to:

1. The Additional Commissioner of Police (Lic), 1st floor, Police Station, Defense Colony, New Delhi for information
2. Mrs. Shilpa (Manager), M/s M C Donald's Family Restaurant at Unitech Rohini Metro Walk Shop No 01-03, Sector 10, Rohini, Delhi-110085

INSPECTION REPORT

1. Name & address of the building : M/s Mc Donald's Family Restaurant at Unitech Rohini
Metro Walk Shop No 01-03, Sector 10, Rohini, Delhi-85
2. Type of Occupancy : Assembly **(Ground Floor Only)**
3. Type of Case : Renewal
4. Details of previous NOC : F-6/DFS/MS/EH/2014/WZ/482 Dated 16/04/2014
5. Fire Safety directives letter No : As per Amusement Park
6. Date of inspection : 06 / 04 / 2017
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers
from the building side : Mrs. Shilpa (Manager)
9. Year of Construction : 2003
10. Applicant's letter No. : L.No- nil Dated 23/01/2017.

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 mtr	6 mtr	M/R
	• Gate width	6m	6m	M/R
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	M/R
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floors	1.5 mtr	168 cm & 130 cm	M/R
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	Required	Provided with mall	M/R
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	2 mtr	5 ft & 4.5 ft	M/R

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Water Curtain 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire Dampers 	N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	N/A	N/A
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	N/A	N/A
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	O4	05	M/R
	<ul style="list-style-type: none"> • Types 		CO2 & ABC	M/R
	<ul style="list-style-type: none"> • IS marking 	ISI marked	Yes	M/R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor 	one	Provided with mall	M/R
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 m	Provided	M/R
	<ul style="list-style-type: none"> • Nozzle diameter 	5 mm	Provided	M/R
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Location of Main Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Alternate source of power 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Hooters' Location 	N/A	N/A	N/A
8	MOEFA	Required	Provided	M/R
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Upper Floor 	Required	Provided with mall	M/R
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	4"	Provided with Mall	M/R
	<ul style="list-style-type: none"> • Number of hydrants per floor 	1	1	M/R
	<ul style="list-style-type: none"> • Hose Box 	1	1	M/R

12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	4500 LPM	Provided with Mall	M/R
	➤ Head of Main pump	60 m	Provided with Mall	M/R
	➤ Number of main pumps			
	➤ Jockey Pump out put	180 LPM	Provided with Mall	M/R
	➤ Jockey pump head	60m	Provided with Mall	M/R
	➤ Standby Pump out put	4500 LPM	Provided with Mall	M/R
	➤ Standby Pump Head	60m	Provided with Mall	M/R
	➤ Auto Starting/ Manual stopping	R	Provided with Mall	M/R
	➤ Pump House Access	R	Provided with Mall	M/R
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power Supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	2,50,000 ltrs	Provided with Mall	M/R
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	30,000 ltr	Provided with Mall	M/R
15	Exit Signage.	Required	Provided	M/R
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
17	Standby power supply	Required	Provided	M/R

18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F-6/DFS/MS/EH/2014/WZ/482 Dated 16/04/2014 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

[Handwritten Signature]

Signature of the Inspecting Officer

Name *Rajesh Kumar*

Designation *AO/IN & S.W.*

Do In/DO
Slugh
10.4.17

M/D