

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No.

F6/DFS/MS/2017/SZ/626.

Dated:

03/05/17

**FIRE SAFETY CERTIFICATE**

Certified that **M/s Auditorium building at Chinmaya Mission, 89, Lodhi Road, New Delhi-110003**, comprised of basement, ground plus two upper floors but Auditorium is at first floor only, owned/occupied by Sri Chinmaya Mission was granted Fire Safety Certificate by this department vide letter no. **F6/DFS/MS/2014/SZ/575, dated 08.05.2014**. The premises was re-inspected by the officer concerned of this department on 19.04.2017 in the presence of Sh. Anil Choudhary, Chief Operating Officer and found that the auditorium building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for **Occupancy Class-D Assembly Building(Auditorium)** at first floor only with effect from...03.05.....2017 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...03.05.....2017 at New Delhi by

  
(Vipin Kental)

Chief Fire Officer

T.No.011-23412225

Copy To:- 1. Joint C.P.Licensing, PS Defence Colony, New Delhi.  
2. Sh. Anil Choudhary, COO, M/s Chinmaya Mission, 89, Lodhi Road, New Delhi.

**Conditions for the validity of fire safety certificate**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate in form J, six month prior to its expiry.



1	Name & address of the building	M/s Auditorium building at Chinmaya Mission, 89, Lodhi Road, New Delhi-110003.		
2	Type of Occupancy	Group "D" Assembly Building.		
3	Building Comprised of	Basement (storage & services), ground plus two upper floors. (Auditorium at first floor only having 430 seats). Ground Floor open hall and at 2nd floor offices & residence of Swammiji.		
4	Type of case	Renewal		
5	Details of previous NOC	F6/DFS/MS/2014/SZ/575, dated 08.05.2014.		
6	Fire safety directives letter No	F6/DFS/MS/BP/94/902, dated 16.06.1994.		
7	Date of inspection	19.04.2017.		
8	Name of the inspecting Officers :	ADO Vedpal		
9	Name and designation of officers from the building side	Sh. Anil Chaudhary, Chief Operating Officer		
10	Year of construction	1996		
11	Applicant's letter No.	Nil, Dated 18.04.2017.		
S. NO.	<b>Minimum Standards on fire prevention and fire safety U/R 33</b>	<b>Requirements/ Existing Fire Protection System</b>	<b>Provided at site</b>	<b>Remarks MR / NMR</b>
1	<b>Access to building</b>			
	1) Road width	9m	15m	MR
	2) Gate width	5m	5m	MR
	3) Width of internal road	N/A	N/A	N/A
2	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	GF to 1st Floor=03nos. 1st Floor to 2nd Floor=02nos	GF to 1st Floor=03nos. 1st Floor to 2nd Floor=02nos	MR
	2. Basements	02nos.	02nos.	MR
	<b>b. Width of staircase</b>			
	1. Upper floors	Required	02nos=2.40m(each) upto 2nd floor & 01no=1.5m upto 1st floor	MR(old case)
	2. basements	Required	1.70m & 2.40m	MR(old case)
	<b>c. Protection of exits</b>			
	1. Fire check door	Required	Provided at basement floor only	MR(old case)
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	01no.	01no.	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1.2m(each)	03 Exit gates at 1st floor (1.6m, 1.6m & 1.50m)	MR(old case)
3	<b>Compartmentation.</b>			
	1. Fire check door	Required	Provided at basement floor only	MR(old case)
	2. Sealing of electrical shafts	Required	Provided	MR
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management system.</b>			
	Basement	30 a/c per hour	Provided	MR
	Upper floors	12 a/c per hour	Exhaust Fans Provided	MR
5	<b>Fire Extinguishers</b>			
	Total numbers		14 Nos. Provided	MR
	Types	12Nos ABC, CO2 & WCO2 ISI	ABC, W CO2 & CO2 ,	MR
	ISI marking	CO2 & WCO2 ISI	Provided	MR



INSPECTION REPORT

6	<b>First-Aid Hose Reels.</b>			
	Total numbers on each floor	01no. & 2nos additional in auditorium	01no. & 02nos additional in auditorium	MR
	Length of Hose reel hose	30m	30m	MR
	Nozzle Diameter	5mm	5mm	MR
7	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	Smoke & Heat	Smoke & Heat	MR
	Location of Main Panel	Ground Floor	Ground Floor	MR
	Location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	Required	Battery Backup Provided	MR
	Hooter's location	All Areas	All Areas	MR
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	Required	Provided	MR
10	<b>Automatic Sprinkler System.</b>			
	Basement	Required	Provided	MR
	Upper floors	N/A	Provided at stage only	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	Size of riser/down-corner	150mm	150mm	MR
	Number of Hydrants per floor	01no.	01no.	MR
	hose Box	01no.	01no.	MR
12	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	N/A
	house box	N/A	N/A	N/A
13	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2. Terrace level</b>			
	a. Discharge of pump	900+180LPM	900+180LPM	MR
	b. head of the pump	40m	40m	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	100,000 ltr	100,000 Ltr Provided	MR
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	Required	Provided	MR
	Over head tank Capacity	20000 ltr	20,000 ltr Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	Required	Provided	MR
	d. Fireman's grounding switch	Required	Provided	MR
	e. Lift signage	Required	Provided	MR
17	<b>Standby power supply</b>	Required	Provided	MR
18	<b>Refuge Area.</b>			
	total area	N/A	N/A	N/A
	location	N/A	N/A	N/A

