

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

No F 6/DFS/MS/2017/WZ/329

Dated

03/05/17

FIRE SAFETY CERTIFICATE

Certified that the Chanderprabhu Jain College of Higher Studies and School of Law, Plot No. OCF, Sector – A8, Narela, Delhi – 110040 comprised of Basement + Ground +Five Upper floors, owned / occupied by Chanderprabhu Jain College was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/2014/WZ/329 Dated 10.03.2014 have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of Fire Service on 29.04.2017 in the presence of Sh. S.K Mohla, (Chief Admn. Officer) and that the building/premises is fit for occupancy class Educational with effect from 03/05/17 for a period of 03 (three) years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The use of basement shall be in accordance with building bye laws.
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.Delhigovt.nic.in.

Issued on03/05/17..... at New Delhi by.


(Atul Garg)

Chief Fire Officer
Ph:- 011-23414250

Copy to:-

Chanderprabhu Jain College of Higher Studies and School of Law, Plot No. OCF, Sector – A8,
Narela, Delhi – 110040

N/36


INSPECTION REPORT

B+Gr.+Five upper floors

1. Name & address of the building: CPJ College of higher Studies and School of Law,
Plot no-OCF, Sector-A-8, Narela, Delhi-110040
2. Type of Occupancy : **Education building**
3. Type of Case : Renewal
4. Details of previous NOC : **F.6/DFS/MS/2014/WZ/329 Dated 10/03/2014**
5. Fire Safety directives letter No : **F6/DFS/MS/BP/2008/2459 dated 28/08/2008**
6. Date of inspection : 29/04/2017
7. Name of the Inspecting Officers : DO (NW) & ADO (BW)
8. Name and designation of officers
from the building side : Sh. S.K Mohla, Chief Admn. Officer.
9. Year of Construction : 2008-09
10. Applicant's letter No.: : Nil **dated 28/02/2017**

Plot Area-4154 Sqm Covered Area-9401 Sqm

| | Minimum Standards on fire prevention and fire safety U/R 33 | NBC Requirement | Provided at site | Remarks MR/NMR |
|---|--|-----------------|-------------------------------|----------------|
| 1 | Access to building | | | |
| | <ul style="list-style-type: none">• Road width | 12 mtr | 12 mtr | MR |
| | <ul style="list-style-type: none">• Gate width | 6 mtr | Provided | M/R |
| | <ul style="list-style-type: none">• Width of internal road | — | — | — |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | N/A | N/A | N/A |
| | <ul style="list-style-type: none">• Upper Floors | 02 | 03 | MR |
| | <ul style="list-style-type: none">• Basements | 02 | 02 | MR |
| | b. Width of staircases | N/A | N/A | N/A |
| | <ul style="list-style-type: none">• Upper Floors | 1.5 mtr each | (i) 175 (ii) 171 (iii) 118 | MR |
| | <ul style="list-style-type: none">• Basements | 1.50 mtr each | (i) 175 (ii) 171 CM | MR |
| | c. Protection of exits | N/A | N/A | N/A |
| | <ul style="list-style-type: none">• Fire check door | Required | Provided | MR |
| | <ul style="list-style-type: none">• Pressurization | N/A | N/A | N/A |
| | e. No. of continuous staircases to terrace | N/A | N/A | N/A |
| | g. Width of Corridor | 1.5 mtr | 1.5 mtr | MR |
| | h. Door Size | 1.0 mtr | 1.0 mtr | MR |
| 3 | Compartmentation. | | | |



| | | | | |
|----|---|--------------------------|------------------|-----|
| | <ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers | Required | Provided | MR |
| | | N.A | N.A | N.A |
| | | N.A | N.A | N.A |
| | | N.A | N.A | N.A |
| | | N.A | N.A | N.A |
| 4 | Smoke Management System. | | | |
| | <ul style="list-style-type: none"> • Basements • Upper floors | 30 a/c per hour | Exhaust Provided | M.R |
| | | 12 a/c per hour | Exhaust Provided | M.R |
| 5 | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> • Total numbers • Types • IS marking | One @ 300 M ² | 35 ABC | M.R |
| | | ISI marked | ABC | M.R |
| | | | YES | M.R |
| 6 | First-Aid Hose Reels. | | | |
| | <ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter | 02 | Provided | M.R |
| | | 30 m | Provided | M.R |
| | | 5 mm | Nozzles provided | M.R |
| 7 | Automatic fire detection and alarming system. | | | |
| | <ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location | N.A | N.A | N.A |
| | | N.A | N.A | N.A |
| | | N.A | N.A | N.A |
| | | N.A | N.A | N.A |
| | | N.A | N.A | N.A |
| 8 | MOEFA | Required | Provided | M.R |
| 9 | Public Address System. | Required | Provided | M.R |
| 10 | Automatic Sprinkler System. | | | |
| | <ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling | Required | Provided | M.R |
| | | N.A | N.A | N.A |
| | | N.A | N.A | N.A |
| 11 | Internal Hydrants | | | |
| | <ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box | 100 MM | Provided | M/R |
| | | 02 | Provided | M/R |
| | | 02 | Provided | M/R |
| 12 | Yard Hydrants. | | | |

Mr. Jyoti

| | | | | |
|----|---|-------------------|------------------------|---|
| | <ul style="list-style-type: none"> Total number of hydrants Hose Box | N.A | N.A | N.A |
| | | N.A | N.A | N.A |
| 13 | Pumping Arrangements. | | | |
| | <ul style="list-style-type: none"> Ground Level ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump | N.A | N.A | N.A |
| | | N.A | N.A | N.A |
| | | N.A | N.A | N.A |
| | | N.A | N.A | N.A |
| | | N.A | N.A | N.A |
| | | N.A | N.A | N.A |
| | | N.A | N.A | N.A |
| | | N.A | N.A | N.A |
| | | N.A | N.A | N.A |
| | | 900 LPM & 180 LPM | Provided | M.R |
| | | 40 M | Provided | MR |
| | | N.A | N.A | N.A |
| | | Required | Provided | M.R |
| 14 | Captive Water Storage for fire fighting. | | | |
| | <ul style="list-style-type: none"> Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity | N.A | N.A | N.A |
| | | N.A | N.A | N.A |
| | | N.A | N.A | N.A |
| | | N.A | N.A | N.A |
| | | 25000 LTR | Provided | M.R |
| 15 | Exit Signage. | Required | Provided | M.R |
| 16 | Provision of Lifts. | | | |
| | <ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage | Required | Lift lobby open to sky | Waived off vide FP meeting dated 21/01/2014 |
| | | — | — | — |
| | | — | — | — |
| | | Required | Provided | MR |
| | | N/A | N/A | N/A |
| 17 | Standby power supply | Required | 125 KVA | MR |
| 18 | Refuge Area. | | | |
| | ➤ Total Area | N.A | N.A | N.A |

M. H. Khan

| | | | | |
|----|--|----------|----------|-----|
| | ➤ Location | N.A | N.A | N.A |
| 19 | Fire Control Room | | | |
| | • Detector System Panel | N.A | N.A | N.A |
| | • Flow Switch Panel | N.A | N.A | N.A |
| | • PA System Panel | Required | Provided | M.R |
| | • Batter backup | Required | Provided | M.R |
| | • Building Floor Plans | Required | Provided | M.R |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | N.A | N.A | N.A |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/2014/WZ/329 Dated 10/03/2014. Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

[Handwritten signature]
 Singh
 1.5.17
 Dy. CPO (WZ)
 CPO West
 2/5/17
 F.T.P.G

Signature of the Inspecting Officer

Name

Designation

[Handwritten signature]
 1/5/17
 ADD (B)

~~ADP/MS~~
 F.T letter is put up for signatures,
 phase
[Handwritten signature]
 2/5/17
 1
[Handwritten signature]
 2/5/17