

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/school/2017/W2/627

Dated: 3/04/2017

FIRE SAFETY CERTIFICATE

Certified that the **Jaspal Kaur Public School**, located at **Shalimar Bagh, B-Pashchim, Delhi – 110088**, comprised of Basement+ Ground + 03 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/2009/2477 Dated 01-09-2008. The premises was re inspected by the officer concerned of this department on 24-04-2017 in the presence of Sh. G. Mathew (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance NBC part-IV/DOE Circular 262–362 Dated 17-01-2005 and that the premises is fit for occupancy class “Educational” Group B with effect from 03/05/17 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ... 03/05/17 ... at New Delhi by.


(Atul Garg)
Chief Fire Officer
Delhi Fire Service

Copy to:

The Principal, Jaspal Kaur Public School, Shalimar Bagh, B-Pashchim, Delhi – 110088.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

1. Name & address of the building: Jaspal Kaur Public School, located at Shalimar Bagh, B-Pashchim, Delhi – 110088.

2. Type of Occupancy : Educational (Basement +Ground + 3 Upper Floor)

3. Type of Case : Renewal

4. Details of previous NOC : F6/DFS/MS/2008/2477 Dated 01/09/2008

5. Fire Safety directives Letter No. : Cir. no262-362 dated 17/01/2005

6. Date of inspection : 24/04/2017

7. Name of the Inspecting Officer : ADO (WP)

8. Name and designation of Officer

from the building side : Sh.G. Mathew (Principal)

9. Year of Construction : 1987(As declared by school authority)

10. Applicant's letter No. : JKPS/LB23/DFS/2016 Dated-21/01/2016

No. of Students=2435
No. of class rooms=102
Plot area=4.45 Acre
Covered area=8800 sqm

S No	Minimum standards on fire prevention and fire safety U/R 33	Cir 262-362 dated 17/01/2005	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> Road width 	Accessible	6m Provided	MR
	<ul style="list-style-type: none"> Gate width 	Accessible	Provided (On Road)	MR
	<ul style="list-style-type: none"> Width of internal road 	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper floors 	5+ Ramp	Provided	MR
	<ul style="list-style-type: none"> Basements 	02	02 Provided	MR
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper floors 	3x150cm	1x140cm, 1x155cm, & 1x145cm 1x220cm(Ramp) up to 1 st Floor) 2x140cm (Up to 1 st Floor)	MR(old case)
	c. Basements	1x150cm & 1x100cm	Basement=1x115cm & 1X107CM	MR (Being old case)
	d. Protection of exits			
	<ul style="list-style-type: none"> Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> Pressurization 	NA	NA	NA
	e. No of continuous staircase to terrace	01	Provided	MR
	f. Width Of Corridor	2mtrs	235 cm	MR
	g. Door Size	100cm	110cm Provided	MR
		Multi activity hall= 2m(At 1 st Floor)	Multi activity hall= 8x2m	
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> Fire Dampers 	NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> Basements 	Required	Exhaust Fan	MR

	<ul style="list-style-type: none"> Total numbers Types IS marking 	29 nos. ABC & CO ₂ ISI marked	Provided	MR
			Provided	MR
			Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	03 30m 5mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	Required NA NA	Provided NA NA	MR NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down comer Number of hydrants per floor Hose Box 	100mm 03 03	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA NA NA NA NA NA NA NA NA NA NA 450 lpm 180 lpm 40Mtr Required Required	NA NA NA NA NA NA NA NA NA NA NA Only 2x450 lpm provided at 3 rd floor Provided Provided Provided	NA NA NA NA NA NA NA NA NA NA NA MR MR MR MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Under ground tank capacity Draw off connection Fire service inlet Access to tank Overhead Tank capacity 	NA NA NA NA 10,000Ltrs	NA NA NA NA Provided 18,000 ltrs	NA NA NA NA MR

16

16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/2008/2477 Dated 01/09/2008 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Uday Vir Singh

Name

Designation

ADO/WP

Designation

D.O/W 27/04/17

Dy. CPO (West) - 42
CPO (West) 9th
28/04/17

FT PLS