

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/2017/NDZ/ 628

Dated: 3/5/17

FIRE SAFETY CERTIFICATE

Certified that the **M/S Shubh Lagan Eating House**, E-363, Nirman Vihar, Delhi at the ground floor of the building which comprised of Basement, ground plus three upper floors was granted fire safety certificate vide letter no. F6/MS/DFS/2014/NDZ/27 dated-09/01/14. The Assembly (Eating House) building was inspected by the officer concerned of this department on 13/04/17 in the presence of **Smt. Kanchan Kapoor (Manager)** and found that the Assembly building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 35 of the Delhi Fire Service Rule 2010, and that the premises is fit for occupancy "Assembly (Eating House)" with effect from 3/5/17..... for a period of **three** years, subject to conditions printed overleaf.

Issued on 3/5/17..... at New Delhi by


(Vipin Kental)
Chief Fire Officer



To,

1. Shubh Lagan Eating House,
E-363, Nirman Vihar, Vikas Marg, Delhi.
2. The Dy. Health Officer,
East MCD Health Department,
Shahdara South Zone, Karkardooma, Shahdara Delhi.

CONDITIONS:

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. All comments/ directions of the Licensing Department shall always be permitted and followed.
7. The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

W/10

1. Name & address of the building : M/S Shubh Lagan Eating House at E-363, Nirman Vihar, Delhi-92.
2. Building is comprised of : B+G+3 (Eating House running at ground floor only)
3. Type of Occupancy : Assembly
4. Type of Case : Renewal
5. Details of Previous FSC letter : F6/MS/DFS/2014/NDZ/27 dated-09/01/14
6. Fire safety direction letter No. : Nil
7. Date of Inspection : 13/04/17
8. Name of the Inspecting officers : ADO R.K. Yadav
9. Name and designation of Officer from the building side : ^{Sub} Kanchan Kapoor (Manager)
10. Year of Construction : 1999
11. Applicant's letter No : Dated 06/03/17

S	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks
1	Access to building			
	• Road width	12 M	13.5 M.	MR
	• Gate width	4.5 M	On road	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	02 Nos.	02 Nos.	MR
	• Basement	02 Nos.	02 Nos.	MR
	B. Width of Staircases			
	• Upper Floor	N/A	1.05 M & .90 M	MR
	• Basement	N/A	1.05 M & .90M	MR
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	02 Nos	02 Nos	MR
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	2 M	2 m & 1.4 m	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	04 Nos.	12 Nos.	MR
	• types	ABC & Co2	ABC & Co2	MR
	• IS marking	ISI marked	ISI marked	MR

N/4

6	First-aid-Hose Reels.			
	Total numbers of each floor	01Nos	01 no at Gr.floor	MR
	• Length of hose reel hose	30 M	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	Provided	MR
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	Provided	MR
	• Hooter's location	Near gate	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	01 No ¹⁵ Provided at G. Fl. ¹⁶	MR
	• Number of hydrants per floor	01 Nos.	Provided	MR
	• Hose Box	01 Nos.	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the Pump	40 M	40 M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	15,000Ltrs	15,000Ltrs	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The FSC issued vide letter no. F6/MS/DFS/2014/NDZ/27 dated-09/01/14 renewal under the rule 35 of the Delhi Fire Service Rule 2010, is recommended to renew Fire Safety Certificate.

R. K. Yadav
21/4/2017

Signature of the Inspecting Officer
Name: R. K. Yadav
Designation: ADO (LN)

~~DOLED~~ *22/4*

~~DeFO(NDZ)~~ *22/4*

C.F.P.

M. Scell

FT 101

25/4

Sy FT letter is put up for signature please

R. K. Yadav
21/5/2017