

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. *F6/DFS/MS/School/2017/52/637*

Dated: *4/5/17*

FIRE SAFETY CERTIFICATE

Certified that M/s Mount St. Mary's School, located at 75, Parade Road, Delhi Cantt, New Delhi-110010, having two blocks i.e main block comprised of ground plus two upper floors and Auditorium block comprised of ground plus two upper floors having audi at 1st and 2nd floor, owned/occupied by Mount St. Mary's School, was granted Fire Safety Certificate by this department vide letter No.F6/DFS/MS/School/2014/SZ/289, dated 03.03.2014. The premises was re-inspected by the officer concerned of this department on 18-04-2017 in the presence of Sh. Ganga Dhar, Supervisor of the school and found that the said school premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules 2010 and that the building is fit for occupancy class-B "Educational" with effect from *4/5/*.....2017 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules,2010.

Issued on *4/5/*.....2017 at New Delhi by

4/3/5
(Vipin Kental)

Chief Fire Officer

T. No.011- 23412225

Copy to:-1. Director of Education, Old Secretariat, Civil Lines, Delhi-54.

2. Principal, M/s Mount St. Mary's School, located at 75, Parade Road, Delhi Cantt, New Delhi-110010.

Conditions for the validity of fire safety certificate are as under:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. The employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All fire fighting equipments shall be maintained in perfect working condition all time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate, six month prior to its expiry.

117
INSPECTION REPORT

1	Name & address of the building	M/s Mount St. Mary's School, located at 75, Parade Road, Delhi Cantt, New Delhi-110010.
2	Type of Occupancy	Educational Building "B"
3	Type of case	Renewal
4	Details of previous NOC	No.F6/DFS/MS/School/2014/SZ/289, Dated 03.03.2014.
5	Fire safety directives letter No	Circular of Director of Education dated 17.01.2005
6	Date of inspection	18.04.2017.
7	Name of the inspecting Officers	A.D.O. Vedpal.
8	Name and designation of officers from the building side	Sh. Ganga Dhar, Superwiser of the school.
9	Building Comprised of	Two Blocks each comprised of ground plus two upper floors.
10	Year of construction	Not Known.
11	Applicant's letter No.	No. A.837/01/2016-17, Dated 15.03.2017.

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per initial FSC dt 11.01.11	Provided at site	Remarks MR / NMR
--------	---	---	------------------	------------------

1	Access to building			
	1) Road width	Accessible	15m	MR
	2) Gate width	N.A	5m	N.A
	3) Width of internal road	N/A		N/A

2 Number, width Type & arrangement of exits

a. Number of staircases				
1. Upper floors	Main block=03nos & Audi block=04nos (04nos upto 01st floor, 03nos upto 2nd floor)	Main block=03nos & Audi block=04nos (04nos upto 01st floor, 03nos upto 2nd floor)		MR(old case)
2. basements	N.A.	N.A.		N.A
b. Width of staircase				
1. Upper floors	1.5m & 75cm	Main block=1.73m (each) & Audi block=1.6, 1.34, 1.00 & 1.5m		MR(old case)
2. basements	N/A	N/A		N/A
c. Protection of exits				
1. Fire check door	N/A	N/A		N/A
2. Pressurization	N/A	N/A		N/A
d. No. of continuous staircase to terrace	01no.	01no. In each block		MR
e. Width of corridor	N/A	1.5m		N/A
f. Door size	1 Mtr	1Mtr Provided		MR

3 Compartmentation.

1. Fire check door	N/A	N/A		N/A
2. Sealing of electrical shafts	Required	Provided		MR
3. Fire Rating of shaft door	N/A	N/A		N/A
4. water curtain	N/A	N/A		N/A
5. Fire dampers	N/A	N/A		N/A

4 Smoke Management system.

basement	30 a/c per hour	12 a/c	N/A	N/A
Upper Floors	per hour		Natural Ventilation & Exhaust fans in Auditorium/Multipurpose hall	MR

5 Fire Extinguishers

total numbers	40nos.	ABC	44nos.	MR
Types	& WCO2	ISI Mark	ABC=22 & Water CO2=22	MR
ISI marking			ISI Mark	MR

[Handwritten Signature]

118

6	First-Aid Hose Reels.			
	total numbers on each floor	Required	05nos.	MR
	Length of Hose reel hose	30m	30m	MR
	Nozzle Diameter	5mm	5mm	MR
7	Automatic Fire Detection & Alarming System			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	Provided	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	Required	100mm	MR
	Number of Hydrants per floor	Required	04nos	MR
	hose Box	Required	04nos	MR
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level	N/A	N/A	N/A
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450LPM+180LPM	450LPM+180LPM	MR
	b. head of the pump	40m(each)	40m(each)	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	5000Liters	5000Liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.		Not Required	
	total area	N/A	N/A	N/A
	location	N/A	N/A	N/A

219

19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A

20 Special Fire Protection systems for protection of special risks, if any: N/A

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, the FSC issued vide letter No: F6/DFS/MS/School/2014/SZ/289, dated 03.03.2014, renewal under rule 37 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly DFA is put up for your approval and signature please.

[Handwritten Signature] 24/4/17

Signature of the inspecting officer

Name: Vedpal

Designation : ADO

~~D.O. (SD)~~
[Handwritten Signature]
24/4/17

~~Dy. Insp. (S2)~~

[Handwritten Signature]
24/4



Chf Insp

What's the level of balcony in auditorium.

[Handwritten Signature]
28/4

~~Dy. Insp. (S2)~~

[Handwritten Signature]
1/5

~~D.O. (SD)~~
[Handwritten Signature]
11/5/17