

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

NO. FG(DFS)MS/BH/05/2017/642


DATED:

04/05/17

FIRE SAFETY CERTIFICATE

Certified that Ambika Palace (Banquet Hall) located at B-3/B, Main Wazirabad Road, Bhajanpura, Delhi-110053 running on 1st, mezzanine and 2nd floor of the building comprised of basement, ground, 1st, mezzanine and 2nd floor, owned/occupied by Ambika Palace (Banquet Hall) have complied with the fire prevention and fire safety requirements in accordance with rules 33 of the Delhi Fire Service Rules, 2010 and verified by a team of officers of this department on 06/04/2017 in the presence of Mr. Shashi Kant Aggarwal, owner of the Banquet Hall and found that the 1st, mezzanine and 2nd floor of the building is fit for occupancy class "D" 'Assembly Building' with effect from 04/05/17 for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 04/05/17 at New Delhi by


(Vipin Kertal)
Chief Fire Officer

To,
The Owner,
Ambika Palace (Banquet Hall),
B-3/B, Main Wazirabad Road,
Bhajanpura, Delhi-110053

Copy to:-

1. The Deputy Health Officer (EDMC),
SHD (N)-Zone, Health Department,
Delhi-110032

- Conditions -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, six months prior to its expiry.

1. Name & address of the building : Ambika Palace (Banquet Hall),
B-3/B, Main Wazirabad Road,
Bhajanpura, Delhi-110053
2. Building is comprised of : Basement, Ground plus two floors (Banquet hall is running on 1st, Mez & 11th floor only)
3. Type of Occupancy : Assembly (Banquet Hall)
4. Type of Case : New
5. Details of Previous NOC letter no. : Nil
6. Fire Safety directive letter no. : NBC Part-IV
7. Date of Inspection : 06/04/2017
8. Name of the Inspecting officers : ADO V. B. Yadav and ADO Om Prakash
9. Name and designation of Officer from the building side : Mr. Shashi Kant Aggrawal (Owner)
10. Year of Construction : 2003
11. Applicant's letter No : Letter No. Nil, Dated- 23/02/17

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Part-IV Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building.			
	• Road width	06 mtr.	24 mtr.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper floor	02 nos.	02 nos.	MR
	• Basement	02 nos.	02 nos.	MR
	b. Width of Staircases			
	• Upper floor	1.50 mtr (old building)	3.65 & 1.10 mtr	MR
	• Basement	1.25 mtr	1.35 & 0.93 mtr	MR
	c. Protection of Exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	01 no.	01 no.	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	02 mtr.	02 mtr.	MR
03	Compartmentation.			
	• Fire check door	Not Required	Exit of basement separated	MR
	• Sealing of electrical shafts	N/A	Concealed type	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	Required	Exhaust fans. Provided	MR
	• Upper floor	Required	Ventilated	MR
05	Fire Extinguishers			
	• Total numbers	12 nos.	12 nos.	MR
	• types	ABC /CO ₂	Provided	MR
	• ISI marking	ISI marked	Provided	MR

06	First-Aid-Hose Reels.			
	Total numbers on each floor	01 No.	01 No.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	Required	Provided	MR
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	Staircase	Provided	MR
08	MOEFA	Required	Provided	MR
09	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 No.	01 No.	MR
	• Hose box per floor	01 No.	01 No.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	Ground Level			
	• Discharge of main pump	2280 Lpm.	2280 Lpm.	MR
	• Head of Main pump	40 M	40 M	MR
	• Number of main pumps	01 No.	01 No.	MR
	• Jockey pump out put	180 Lpm.	180 Lpm.	MR
	• Jockey pump head	40 M	40 M	MR
	• Standby pump out put	2280 Lpm.	2280 Lpm.	MR
	• Standby pump head	40 M	40 M	MR
	• Auto starting /manual stopping	Required	Provided	MR
	• Pump house access	Required	Provided	MR
	➤ Terrace Level			
	• Discharge of pump	450 Lpm.	450 Lpm.	MR
	• Head of the Pump	40 M	40 M	MR
	• Power supply	Required	Provided	MR
	• Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	50,000 Ltr.	50,000 Ltr.	MR
	• Draw-off connection	Required	Provided	MR
	• Fire service inlet	Required	Provided	MR
	• Access to tank	Required	Provided	MR
	• Overhead Tank capacity	5,000 Ltr.	10,000 Ltr.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	Required	Provided	MR
	• Firemen's grounding switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR

		Required	Provided	MR
17	Standby Power Supply			
18	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if any:	N/A	N/A	N/A

The shortcomings communicated vide letter no. F6 /DFS/MS/2016/2058 dated 30/08/16 have been rectified. The basement is being used as parking and ground floor is on rent for motor cycle showroom. The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the NBC Part-IV, it is recommended to issue Fire Safety Certificate.

Om Prakash
20/4/17

Signature of the Inspecting Officer

Name :- Om Prakash

Designation :- A.D.O

V. B. Yadav
18/4/17

Signature of the Inspecting Officer

Name :- V. B. Yadav

Designation :- A.D.O (Tanirpur)

~~D.O (ED)~~ submitted pl.
1
21/4

~~DeFO (NDZ)~~
21/4

1 CF/NDZ
4/12/4/5/17

C.F.O. If all the shortcomings mentioned in letter dt 30.8.16 are complied now.

DeFO NDZ

U
28/4

Sir the shortcomings communicated earlier vide our letter are rectified now.

V. B. Yadav
3/5/17

CFD (NDZ)