

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

Fax No. 011-23412593, Ph. 011-23412225

No. F6/DFS/MS/EH/2017/SZ/ 672

Dated: 11/05/17

**FIRE SAFETY CERTIFICATE**

Certified that the M/S Big Banana restaurant located at 15 & 16, First Floor, J-Block Market, Saket, New Delhi-110017, comprised of Ground floor plus Two upper floors (Restt. running at first floor of the building) was granted FSC by this department vide letter No.F6/MS/DFS/EH/2013/167 dated 10/04/2013. The premises was re-inspected by the officer concerned of this department on 03/05/2017 in the presence of Mr. Rohit Gupta(owner) of the restaurant and observed that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class-D "Assembly Building" (Restaurant) as above with effect from 11/05/17 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 11/05/17 at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer

Copy to: -

1. M/S Big Banana restaurant located at 15 & 16, First Floor, J-Block Market, Saket, New Delhi-110017
2. The Joint C.P. (Lic.), First Floor, PS Defence Colony, New Delhi-110049
3. The DHO (Central Zone), South MCD, Health Deptt, Lajpat Nagar, New Delhi-24

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye Laws.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

11/12

**INSPECTION REPORT**

1	Name & Address of the Building	Big Banana Restaurant, 15 & 16, First Floor, J-Block Market, Saket, New Delhi-110017		
2	Type of Occupancy	Group-D Assembly Building. (Restaurant)		
3	Building comprised of	Ground, + 2 upper floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	No.F6/MS/DFS/EH/2013/167 Dated 10-04-2013		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	03/05/2017		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mr. Rohit Gupta (Owner)		
10	Year of construction	Not Known	Restt running at first floor only	
11	Applicant letter No.	Nil Dated 07/04/2017		
<b>S. No</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>As Per Old NOC – 2013</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
<b>1</b>	<b>Access to Building.</b>			
	• Road width	Required	6 mtr	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
<b>2</b>	<b>Number, width, type &amp; arrangement of exits</b>			
	<b>a. Number of Staircase</b>			
	• Upper floors	Required	1no	MR
	• Basement floor	N/A	N/A	N/A
	<b>b. Width of Staircase</b>			
	• Upper floors	Required old Case	1.25 mts	MR
	• Basement floor	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	N/A	N/A	N/A
	<b>e. Width of corridor</b>	N/A	N/A	N/A
	<b>f. Door size</b>	Required two nos exit	2 mtr Provided	MR
<b>3</b>	<b>Compartmentation.</b>			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management system.</b>			
	• Basement	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	Exhaust Fan	MR
<b>5.</b>	<b>Fire Extinguishers.</b>			
	• Total numbers	ISI marked	8No's	MR
	• Types		ABC-08	MR
	• ISI Marking		Provided	MR
<b>6.</b>	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	01 no	Provided	MR
	• Length of hose-reel hose.	30 m	Provided	MR
	• Nozzle Diameter	5 mm	Provided	MR

7	<b>Automatic fire detection &amp; alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooter's location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8.	<b>MOEFA</b>	Required	Provided	M/R
9.	<b>Public Address System</b>	N/A	N/A	N/A
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper floors</li> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
		Required	Provided	M/R
		N/A	N/A	N/A
11.	<b>Internal Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Size of Riser/Down-comer</li> <li>Number of Hydrant per floor</li> <li>Hose box.</li> </ul>	100mm	Provided	M/R
		1no	Provided	M/R
		1no	Provided	M/R
12.	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants.</li> <li>Hose box.</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
13.	<b>Pumping arrangements.</b>			
	<ul style="list-style-type: none"> <li><b>Ground Level</b> <ul style="list-style-type: none"> <li>Discharge of main pump.</li> <li>Head of main pump.</li> <li>Number of main pumps.</li> <li>Jockey Pump output.</li> <li>Jockey Pump head.</li> <li>Standby Pump output.</li> <li>Standby Pump head.</li> <li>Auto Starting / Manual Stopping.</li> </ul> </li> <li><b>Terrace Level</b> <ul style="list-style-type: none"> <li>Discharge of pump.</li> <li>Head of pump.</li> <li>Power supply.</li> <li>Auto starting of pump.</li> </ul> </li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		450 LPM	450LPM	MR
		38mtr	38 mtr	MR
		Required	Provided	MR
		Required	Provided	MR
14.	<b>Captive water storage for Fire Fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity. <ul style="list-style-type: none"> <li>Draw-off connection.</li> <li>Fire Service Inlet.</li> <li>Access to tank.</li> </ul> </li> <li>Overhead tank capacity.</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	M/R
		N/A	N/A	N/A
		5,000 Ltr	5,000 Ltr.	MR
15.	<b>Exit Signage.</b>	Required	Provided	M/R
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of lift shaft.</li> <li>Pressurization of lift lobby.</li> <li>Communication in lift car.</li> <li>Fireman's switch.</li> <li>Lift signage.</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	<b>Standby Power Supply</b>	Required	Provided	MR
18.	<b>Refuge Area</b>			
	<ul style="list-style-type: none"> <li>Total area</li> <li>Location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A

N/14

19.	<b>Fire Control Room.</b>			
	• Detector System Panel.	N/A	N/A	N/A
	• Flow Switch Panel.	N/A	N/A	N/A
	• PA system Panel.	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for the Protection of special Risk, if any :</b>			N/A
<p>The Fire protection systems provided in the building were checked randomly and found functional at the time of inspection.</p> <p>Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/MS/DFS/EH/2013/167 dated 10-04-2013, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.</p> <p>Accordingly, DFA is put up for approval and signature please.</p>				
				<p><i>R.N. Singh</i> 9/5/17</p> <p>Signature of the Inspecting Officer Name : R.N. Singh Designation: ADO</p>

Div. Officer (SD)

*R.N. Singh*  
9/5/17

*By. C.P. S. S.*



*Kapoor*  
5/5

*8246082*  
9/5/17/15 C.P.S.S.

*m. scell FT br.*

*u/s*

*F.T letter is put up for sign. p.t.c.*

*cro/sf*

*m. scell u/s*

*R.N. Singh*  
9/5/17