

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001  
Fax No. 011-23412593, Ph. 011-23412225

No. F6/DFS/MS/School/2017/SZ/ 665

Dated: 05/05/17

**FIRE SAFETY CERTIFICATE**

Certified that the Dakshin Nigam Prathibha Co-Ed, Primary School located at Pushp Vihar Sec-7, New Delhi-110017 comprised of ground floor only Owned/Occupied by SDMC was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2014/SZ/702 dated 09/06/2014. The premises was re-inspected by officer concerned of this department on 22.04.2017 in the presence of Mrs. Veervati (HOS) of the school and found that school have deemed complied with the fire prevention and fire safety arrangements in accordance with Directorate of Education circular No. F.16/Fire Safety/2011/13298 to 3398 dated 01.03.2011 issued by Director of Education and the building/premises is fit for occupancy class "**Educational Building Group-B**" with effect from 05/05/2017 of the issue of this certificate for a period of **Three years** subject to conditions as mentioned below.

Issued on .....05/05/17... at New Delhi by

  
Vipin Kental  
Chief Fire Officer

**Copy to: -**

1. The Principal, Dakshin Nigam Prathibha Co-Ed, Primary School, Pushp Vihar Sec-7, New Delhi-110017
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye Laws.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

1	Name & Address of the Building	Dakshin Nigam Prathibha Co-Ed, Primary School, Pushp Vihar Sec-7, New Delhi-110017		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Ground Floor Only.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2014/SZ/702 dated 09/06/2014		
6	Fire Safety Directives Letter No	F.16/Estate/CC/Fire Safety/2011/3298 to 3398 Dated 01/03/2011		
7	Date of Inspection	22-04-2017		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mrs. Veervati (HOS)		
10	Year of construction	1997		
11	Applicant letter No.	Nil Dt. 28/03/2017		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	As Per Old Noc 2014	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>			
	• Road width	Accessible	6 mtr	MR
	• Gate width	4.5m	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, width, type &amp; arrangement of exits</b>			
	<b>a. Number of Staircase</b>			
	➤ Upper floors	N/A	N/A	N/A
	➤ Basement floor	N/A	N/A	N/A
	<b>b. Width of Staircase</b>			
	➤ Upper floors	N/A	N/A	N/A
	➤ Basement floor	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	N/A	N/A	N/A
	<b>e. Width of corridor</b>	N/A	N/A	N/A
	<b>f. Door size</b>	Required	1m	MR
3	<b>Compartmentation.</b>			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4.	<b>Smoke Management system.</b>			
	• Basement	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	<b>Fire Extinguishers.</b>			
	• Total numbers	10 No's	10 No's	MR
	• Types	ISI Marked	ABC-10	MR
	• ISI Marking		Yes	MR
6.	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	N/A	N/A	N/A
	• Length of hose-reel hose.	N/A	N/A	N/A
	• Nozzle Diameter	N/A	N/A	N/A

Renewal

Dakshin Nigam Prathibha Co-Ed, Primary School, Pushp Vihar Sec-7, New Delhi-110017



7	<b>Automatic fire detection &amp; alarming system.</b>			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8.	<b>MOEFA / Siren</b>	N/A	N/A	N/A
9.	<b>Public Address System</b>	N/A	N/A	N/A
10.	<b>Automatic Sprinkler System</b>			
	• Basement.	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	<b>Internal Hydrants.</b>			
	• Size of Riser/Down-comer	N/A	N/A	N/A
	• Number of Hydrant per floor	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
12.	<b>Yard Hydrants.</b>			
	• Total number of hydrants.	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
13.	<b>Pumping arrangements.</b>			
	<b>a) Ground Level</b>			
	➤ Discharge of main pump.	N/A	N/A	N/A
	➤ Head of main pump.	N/A	N/A	N/A
	➤ Number of main pumps.	N/A	N/A	N/A
	➤ Jockey Pump output.	N/A	N/A	N/A
	➤ Jockey Pump head.	N/A	N/A	N/A
	➤ Standby Pump output.	N/A	N/A	N/A
	➤ Standby Pump head.	N/A	N/A	N/A
	➤ Auto Starting / Manual Stopping.	N/A	N/A	N/A
	➤ Pump house access.	N/A	N/A	N/A
	<b>b) Terrace Level</b>			
	➤ Discharge of pump.	N/A	N/A	N/A
	➤ Head of pump.	N/A	N/A	N/A
	➤ Power supply.	N/A	N/A	N/A
	➤ Auto starting of pump.	N/A	N/A	N/A
14.	<b>Captive water storage for Fire Fighting.</b>			
	• Underground tank capacity.	N/A	N/A	N/A
	➤ Draw-off connection.	N/A	N/A	N/A
	➤ Fire Service Inlet.	N/A	N/A	N/A
	➤ Access to tank.	N/A	N/A	N/A
	• Overhead tank capacity.	N/A	N/A	N/A
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	• Pressurization of lift shaft.	N/A	N/A	N/A
	• Pressurization of lift lobby.	N/A	N/A	N/A
	• Communication in lift car.	N/A	N/A	N/A
	• Fireman's switch.	N/A	N/A	N/A
	• Lift signage.	N/A	N/A	N/A
17	<b>Standby Power Supply</b>	N/A	N/A	N/A
18.	<b>Refuge Area</b>			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A

N/7

19.	<b>Fire Control Room.</b>				
		• Detector System Panel.	N/A	N/A	N/A
		• Flow Switch Panel.	N/A	N/A	N/A
		• PA system Panel.	N/A	N/A	N/A
		• Battery backup	N/A	N/A	N/A
		• Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	N/A	N/A	N/A	

The Fire Protection system provided in the building were checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the circular of Directorate of Education dated 01/03/2011, Fire Safety Certificate issued vide letter No. F6/DFS/MS/School/2014/SZ/702 dated 09/06/2014, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended

Accordingly DFA is put up for approval and signature please.

*R.N. Singh*  
24/4/17

Signature of the Inspecting Officer  
Name : R.N. Singh  
Designation: ADO

Renewal Dakshin Nigam Prathibha Co-Ed, Primary School, Pushp Vihar Sec-7, New Delhi-110017

D. O. (SD)

*Amilash*  
25/5/15

*dy. cfo (CS2)*

*824/cf/s2*  
27/4/15

*28/4*

*CFD(S7)*

*m.s cell*

*26/4*

*F.T letter is put up for sign pka*

*R.N. Singh*  
2/5

*CFD/S2*

*m.s cell*

*4/5*

