

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No.F6/DFS/MS/GH/SZ/2017/ 650

Dated: 05/05/17

FIRE SAFETY CERTIFICATE

Certified that **Hotel Ashu Palace Guest house** located at **12A/34, WEA, Karol Bagh, New Delhi- 110005** comprised of basement (storage), ground floor (reception & office & 04 guest rooms), first floor (08 guest room), second floor (08 guest rooms), third floor (08 guest rooms) and forth floor (01 store, 04 rooms for staff with pantry) (total 28 guest rooms), was granted FSC by this department vide letter No. F6/DFS/MS/GH/2013/SZ/479 dated 25.06.2013. The premises was re-inspected by the officer concerned of this department on 20/04/2017 in presence of Mr. Raj Kumar, manager of the guest house and found that 04 guest rooms at ground floor removed and segregated by the management of the guest house and deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class residential (guest house) for 24 guest rooms with effect from 05/05/17 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 05/05/17 at New Delhi by.

(VIPEN KENTAL)
CHIEF FIRE OFFICER

Copy to:-

1. The Manager, Hotel Ashu Palace Guest house, 12A/34, WEA, Karol Bagh, New Delhi- 05.
2. The Joint C.P.(Lic.), Police Station, Defence Colony, 1st floor, New Delhi

Following Fire Safety Directives must be adhered to: -

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : M/s Hotel Ashu Palace Guest house, 12A/34, WEA, Karol Bagh, New Delhi- 05.
2. Type of Occupancy : Lodging House
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/GH/2013/SZ/479 dated 25.06.2013 (for 28 guest rooms)
5. Fire Safety directives letter No : Nil
6. Date of inspection : 20-04-2017
7. Name of the Inspecting Officers : M.K. Chattopadhyay, DO(South West)
8. Name and designation of officers from the building side : Mr. Raj Kumar, manager
9. Year of Construction : Before 2006
10. Applicant's letter No. : nil dated nil

The said guest house is comprised of basement (storage), ground floor (reception, office), first floor (08 guest room), second floor (08 guest rooms), third floor (08 guest rooms) and fourth floor (01 store, 04 rooms for staff with pantry) (total 24 guest rooms)

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Existing fire safety requirements as per letter dated 25.06.2013	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided (09 mts)	MR
	• Gate width	-----	Directly accessible	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	01	01	MR being old case
	• Basements	01	01	MR being old case
	b. Width of staircases	-	-	-
	• Upper Floors	1.25 mts	1.33 mts	MR being old case
	• Basements	1.25 mts	1.20 mts	MR being old case
	c. Protection of exits	-	-	-
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	1.25 mts	1.33 mts	MR
	h. Door Size	Old case	0.80 mts	MR being old case
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A

	<ul style="list-style-type: none"> Basements Upper floors 	12 a/c per hour 12 a/c per hour	Exhaust fan provided Natural Ventilation	MR MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	20 CO ₂ , ABC, WCO ₂ ISI marked	Provided Provided Provided	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 30 m 5 mm	Provided Provided Provided	MR MR MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	Required N/A N/A	Provided N/A N/A	MR N/A N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	N/A N/A	N/A N/A
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put 	--- N/A N/A N/A N/A N/A N/A	--- N/A N/A N/A N/A N/A N/A	--- N/A N/A N/A N/A N/A N/A

	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	-----	-----	-----
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the pump	30 mts	30 mts	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	Old case	6,000 lts	MR being old case
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided (125 KVA)	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	Two ABC type fire extinguisher found provided near elect. panel	MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/GH/2013/SZ/479 dated 25.06.2013, renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

DFA is put up for approval & signature please.



Signature of the Inspecting Officer
Name M.K.CHATTOPADHYAY
Div. Officer (South West)

DCFO (SX)

Handwritten signature
25/4

Chd sup

m.scell F7101 W 26/4.

F.T. letter is put up for sign. please.

CFO (South)

m.scell W 4/5.

Handwritten signature
3/5/13

239/DOCSW
25.06.2013

835/CF-22
25/4/13

