

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

Fax No. 011-23412593, Ph. 011-23412225

NO.F6/ DFS/ MS/School/SZ/2017/ 663

Dated: 05/05/17

FIRE SAFETY CERTIFICATE

Certified that Sri Dashmesh Khalsa Primary School, Located at Malviya Nagar, New Delhi-110017 is running at ground and first floor of a building comprised of basement, ground and one upper floor (basement is others property) owned/occupied by school management was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2014/SZ/959 dated 30/07/2014. The premises was re-inspected by the officer concerned of this department on 24/04/2014 in the presence of Ms. Sarbjeet Kaur (Principal) of the school and found that school have deemed complied with the fire prevention and fire safety arrangements in accordance with Directorate of Education circular No. F.16/Fire Safety/2011/13298 to 3398 dated 01.03.2011 issued by Director of Education and the building/premises is fit for occupancy class "Educational Building Group-B" with effect from 05/05/2017 of the issue of this certificate for a period of **Three years** subject to conditions as mentioned below.

Issued on 05/05/17 at New Delhi by.


Vipin Kental
Chief Fire Officer

Copy to: -

1. The Principal, Sri Dashmesh Khalsa Primary School, Located at Malviya Nagar, New Delhi-110017
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye Laws.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building : Sri Dashmesh Khalsa Primary School, Malviya Nagar,
New Delhi-110017
2. Type of Occupancy : Educational (School)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2014/SZ/959 dated : 30/07/2014
5. Fire Safety directives letter No : F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01-03-2011.
6. Date of inspection : 24/04/2017
7. Name of the Inspecting Officers : R.N. Singh ADO
8. Name and designation of officers
from the building side : Ms. Sarbjeet Kaur,(Principal)
9. Year of Construction : 1996
10. Applicant's letter No. : SDKS/16-17/28 dated: 07/03/2017
11. Composition Of Building : The school is running in ground and 1st floor of a building comprised of basement, ground and one upper floor.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	As Per Old NOC 2014	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Required	6 mtr	MR
	• Gate width	Required	4.5 mtr	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
a. Number of staircases				
• Upper Floors	01 no		02 No s	MR
• Basements	N/A		N/A	N/A
b. Width of staircases				
• Upper Floors	1.5 mtr		1.45m & 1.45m	MR
• Basements	N/A		N/A	N/A
c. Protection of exits				
• Fire check door	N/A		N/A	N/A
• Pressurization	N/A		N/A	N/A
e. No. of continuous staircases to terrace	01		02	MR
g. Width of Corridor	N/A		N/A	N/A
h. Door Size	1 mtr		Provided	MR

N/A

	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	N/A	N/A
		12 a/c per hour	N/A	N/A
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	12 Nos	12 Nos	MR
		ISI Marked	ABC- 6nos Co ₂ - 6 nos	MR
			Provided	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A

11	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power Supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	-----	01 no. of Co2 extinguisher is provided near electric mains.	MR

The fire protection systems provided in the school were test checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the circular of Directorate of Education dated 01/03/2011, Fire Safety Certificate issued vide letter No. F6/DFS/MS/School/2014/SZ/959 dated 30/07/2014, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

D. O. (SD)

[Handwritten Signature]
25/4/17

[Handwritten Signature]

CFO: P.S.

[Handwritten Signature]

25/4
PTM.

m-seen 26/4

[Handwritten Signature]
25/4/17

Signature of the Inspecting Officer
Name : R.N. Singh
Designation: ADO

823/Ch 52
25/4/15

