

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

NO F 6/DFS/MS/EH/2017/ 699

Dated:- 16/05/2017

FIRE SAFETY CERTIFICATE

Certified that the M/S United Coffee House located at 15-E, Connaught Place, New Delhi comprises of ground +2 Upper floors Restaurant is running at ground & Mezzanine floor only was granted FSC by this Department vide letter No F.6/DFS/MS/EH/2014/NDZ/504 dated 24/04/2014. The restaurant was re- inspected by the officer concerned of this department on. 11/05/17 in the presence of Sh. Akash Kalra (partner) and found that the said premises have deemed complied with the fire prevention and fire safety requirement in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy of class Assembly Group- D with effect from 16/05/17 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 mentioned below.

Issued on----- 16/05/17 -----at New Delhi

  
(Sunil Chawdhary )  
Dy.Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. Mr. Akash Kalra (partner)  
M/S United Coffee House,  
15-E, Connaught place New Delhi-11001.
2. The DEO (Restt.)  
Deptt. Of Excise, Entertainment and Luxury,  
Govt. of N.C.T of Delhi,  
L & N Block. Vikas Bhawan. I.P. Estate, New Delhi.

Following fire safety directives may be adhered to :-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. The means of escape shall be kept unobstructed/unlocked & remain available for speedy evacuation of occupants in case of an emergency. of smooth and speedy safe evacuation of occupants in case of emergency
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management. rendering non functional of fire safety measures, management shall be responsible.
4. Any deviation with regard to construction, electric shall be verified by the concerned building sanctioning authority.
5. The trained fire fighting staff should be available around the clock.
6. This fire safety certificate may not be treated in any case for regularizations of unauthorized construction if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi fire service 2010. The form is available on www.dfs.delhigovt.nic.in.
8. The owner / occupier shall apply for renewal of this fire safety certificated to the director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to it expiry.



**INSPECTION REPORT**

1. Name & address of the building : M/S United Coffee House, 15-E, Connaught Place, New Delhi.
2. Building is comprised of : Ground +2 Upper floors Restaurant is at Ground & Mezzanine floor
3. Type of Occupancy : Eating House.
4. Type of Case : Renewal.
5. Details of Previous FSC letter : F6/DFS/MS/EH/2014/NDZ/504 dated 24/04/2014.
6. Fire Safety Circular No. : Nil.
7. Date of Inspection : 11/05/2017.
11. Name of the Inspecting officers : (Dy. C.F.O. Sunil Chawdhary.& A.D.O manoj Sharma)
12. Name and designation of Officer from the building side : Mr. Akas Kalra.(partner)
13. Year of Construction :
14. Applicant's letter No : Nil Dated 21/04/17.

N O.	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks
1	Access to building			
	• Road width	09 mtrs	09 mtrs	MR
	• Gate width	N/A	Directly accessible from the road	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	02 Nos.	02 Nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.2 mtr & .70 Mtr	1.2 mtr & .70 Mtr	MR (old case)
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	1.0 Mtr	1.0 Mtr.	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	Required	provided	MR
5.	Fire Extinguishers			
	• Total numbers	04 Nos.	8 Nos.	MR
	• types	Co2 & WCo2	Co2 & WCo2	MR
	• ISI marking	ISI marked	Provided	MR

MR



6	First-aid-Hose Reels.			
	Total numbers of each floor	Required	provided	MR
	7. Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	05 mm	05 mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.	Required	Provided	MR
	• Basement	N/A	N/A	N/A
	• upper floor	Required	Provided	MR
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	180 Lpm & 450 LPM	180 Lpm & 450 LPM	MR
	➤ Head of the Pump	30 Mtrs.	30 Mtrs.	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	5,000 ltrs	5,000 ltrs	MR
15	Exit Signage.	Required	Provided	MR


*M*




16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the guest house were tested /checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The FSC issued vide letter no. F6/DFS/MS/EH/2014/NDZ/504 dated 24/04/2014 renewal under Rule 35 of the Delhi fire Service rules 2010, is recommended. It is recommended to renew Fire Safety Certificate.



Signature of the Inspecting Officer  
Name: Sunil Chawdhary  
Designation: Dy. Chief Fire Officer




Signature of the Inspecting Officer  
Name: Manoj Sharma  
Designation: (A.D.O/ C.C)

F.T. please.

M.S. all

F.T. is put up for signature

CFO. on leave. Manoj  
16/5/17



16/5  
M.S. all