

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F6/DFS/MS/2017/W2/696

Dated: 16/5/2017

FIRE SAFETY CERTIFICATE

Certified that Munni Garg, Plot No J-116, Sector -4, Bawana Industrial Area, Delhi-110039 comprised of Basement + Ground + one upper floor, owned / occupied by that M/s Munni Garg was issued fire safety certificate by this department vide letter no. F6/DFS/MS/2013/953 Dated: 24/09/2013 have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 01/05/2017 in the presence of Smt. Munni Garg (Owner) and the building / premises is fit for occupancy Class G-2 (ii) industrial occupancy the date of issue of this certificate for a period of Three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule -38 of the Delhi Fire Service Rule, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The use of basement shall be in accordance with building bye laws
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on

WWW.dfs.Delhigovt.nic.in

Issued on 16/5/17 at New Delhi by

Atul Garg
(Atul Garg)

Chief Fire Officer

Ph: 011-23414250

Copy to :

1. Munni Garg, Plot No J-116, Sector -4, Bawana Industrial Area, Delhi-110039


INSPECTION REPORT

B+Gr.+1

1. Name & address of the building : Muni Garg, Plot No J-116, Sector-4, Bawana Industrial Area, Delhi-39.
2. Type of Occupancy : Industrial G-2(ii)
3. Type of Case : Renewal
4. Details of previous NOC : Letter No.F6/DFS/MS/2013/953 Dated: 24/09/2013
5. Fire Safety directives letter No : F.6/DFS/MS/BP/2016/304 dated 28/11/2016
6. Date of inspection : 01/05/2017
7. Name of the Inspecting Officers : ADO (BW)
8. Name and designation of officers
from the building side : Sh. Munni Garg (Owner)
9. Year of Construction : 2014
10. Applicant's letter No. : Nil dated 16/03/2017

Plot Area: 250 sq m Covered Area: 410 sq mtr

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	12.0 mtr	12.0 mtr	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	N/A	N/A	N/A
	• Upper Floors	02	02	MR
	• Basements	02	02	MR
	b. Width of staircases	N/A	N/A	N/A
	• Upper Floors	1.50 mtr	2 staircase of 1.50 mtr one pucca and one iron staircase provided	MR
	• Basements	1.50 mtr	-DO-	MR
	c. Protection of exits	N/A	N/A	N/A
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	One	One	MR
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	1.00 mtr	1.00 mtr	MR



3	Compartmentation.	—	—	—
	<ul style="list-style-type: none"> • Fire check door 	Required	Provided	MR
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Water Curtain 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire Dampers 	N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	Provided exhaust fan	MR
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	N/A	N/A
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	10 ABC	10	M/R
	<ul style="list-style-type: none"> • Types 		ABC	M/R
	<ul style="list-style-type: none"> • IS marking 	ISI marked	Yes	M/R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor 	One	provided	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 m	provided	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	5 mm	provided	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Location of Main Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Alternate source of power 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Hooters' Location 	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	Required	Provided	MR
	<ul style="list-style-type: none"> • Upper Floor 	Required	Provided	MR
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	100 MM	Provided	MR
	<ul style="list-style-type: none"> • Number of hydrants per floor 	One at each floor	Provided	MR
	<ul style="list-style-type: none"> • Hose Box 	One at each floor	Provided	MR

Alkhan

12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	N/A	N/A	N/A
	➤ Discharge of pump	900 LMP	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	15 K P	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	1,0000 ltr	1,0000 ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR

A. Lakshmi

18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no Letter No. Letter No.F6/DFS/MS/2013/953 Dated: 24/09/2013. Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

Do (11/17)

Singh
3.5.17

Dy CPO (WZ)

CFO West
11/05/17
FT DL

ADU BW FT is put up for sign. Please

CFO (WZ)
16/05/17

MS

Signature of the Inspecting Officer

Name

Designation

Alkhan
11/5/17
ADU (BW)

Alkhan
16/5/17
ADU (BW)