

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/2017/

685

Dated :-----

15/5/17

**FIRE SAFETY CERTIFICATE**

Certified that the **Ghalib Institute Auditorium** located at **Aiwan-E-Ghalib Marg, Mata Sundari Lane, New Delhi** comprised of **Basement floor + Ground floor (Hall)** was granted FSC by this department vide letter **F6/DFS/MS/A/2014/NDZ/618** dated **20/05/2014**. The premises was re-inspected by the officer concerned of this department on **27/04/17** in the presence of **Sh. Idrish (Admn. Officer)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Assembly Building Group D** with effect from ~~---15/5/17---~~ for period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued ~~---15/5/17---~~ at New Delhi by.

  
(Vipin Kental)  
Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi ref. letter no. 707-09/Joint C.P./Lic.(Amst.) dated 15/03/17.
2. Sh. Syed Raza Haider (Director),  
Ghalib Institute Auditorium,  
Aiwan-E-Ghalib Marg, Mata Sundari Lane, New Delhi ref. letter No. A.G.D.-974 dated 02/03/2017.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. **The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.**
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Ghalib Institute Auditorium located at  
Aiwan-E-Ghalib Marg, Mata Sundari Lane,  
New Delhi
2. Type of occupancy : Assembly Building B + Ground floor (Hall)
3. Type of case:- : Renewal
4. Details of previous FSC : F6/DFS/MS/2014/NDZ/618 dated 20/05/2014
5. Fire safety directives No. : N/A
6. Date of inspection:- : 27/04/17
7. Name of the inspecting officer : Sh. G.S. Chauhan DO/CD & Sh.  
M.K Sharma ADO/CC
8. Name & designation of officer  
From the building side : Sh. Idrish (Admn. Officer)
9. Year of construction : 1982 Old building
10. Applicant's letter No : 707-09/Addl. C.P/Lic.(Amst.) dated 15/03/17.  
Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	09 mtr.	12 mtr.	MR
	2) Gate width	4.5 mtr.	4.5 mtr.	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	04	04	MR
	2. Basements	01	01	MR
	B. Width of staircase			
	1. Upper floors	1.5 mtr.	02 Nos. 1.50 mtr. 02 Nos. 1.30 mtr.	MR
	2. Basements	1.0 mtr. Old	0.90 mtr. existing	MR
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	02 No	02 No	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1.5 Mtr.	02 Nos. 1.30 mtr., 02 Nos. 1.5 mtr., 02 Nos. 1.75 mtr. & 2.0 Mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	Machincal	MR
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	20 Nos.	22 Nos.	MR
	2) Types	ABC & CO2	ABC, CO2 & W.CO2	MR
	3) ISI marking	Required	Provided	MR

*me*

- 7/54 -

6.	First-Aid Hose Reel			
	1) Total number of each floor	04 No.	04 No.	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	05 mm	05 mm.	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Required	Provided	MR
	2) Location of main panel	At G. floor	Provided	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	100 mm	MR
	2) Number of hydrants per floor	04	04	MR
	3) Hose box per floor	04	04	MR
12.	Yard Hydrants			
	1) Total number of hydrants	02	02	MR
	2) Hose box	02	02	MR
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	1620 LPM	1620 LPM	MR
	b) Head of main pump	25 mtr.	25 mtr.	MR
	c) Number of main pump	01	01	MR
	d) Jockey pump out put	280 LPM	280 LPM	MR
	e) Jockey pump head	25 mtr.	25 mtr.	MR
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	50,000 ltr.	50,000 ltr.	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	20,000 Ltr.	20,000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			

Mw

	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any: CO <sub>2</sub> & DCP			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F6/DFS/MS/2014/NDZ/618 dated 20/05/2014 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer

Name :- G.S Chauhan  
Designation :- DO (CD)

Signature of the Inspecting Officer

Name :- M.K. Sharma  
Designation :- ADO (CC)

Dy CPO (NDZ)  
*[Signature]*  
1/5

*30/05/2014  
& 18/12/2015*

*C.F.O.*

*M.S.C.E.U*

*F.T.M.*

*u  
2/5*

*F.T. letter is put up for sign. pl*

*a fo (NDZ)*

*M.S.C.E.U u  
1/5*

*[Signature]*  
12/5/14