

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001


NO F 6/DFS/MS/NDZ/2017/ 698

Dated:- 16/05/2017

FIRE SAFETY CERTIFICATE

Certified that the **Galleria Mall** located at **Plot no. 01B, District center Mayur Vihar Ph-1, Delhi.** owned/occupied by M/S Paliwal Developers Ltd. Comprised of basement, ground + two Upper floors was issued Fire Safety Certificate by This Department vide letter F.6/DFS/MS/2014/NDZ/631 dated 22/05/2017. The Mercantile building was inspected by the officer concerned of this department on 06.05.2017 in the presence of **Colonel Ravinder Ahuja (center manager)** and found that the Mercantile building have complied with the fire prevention and fire safety requirement in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building premises is fit for occupancy of Group "**Mercantile Building**" with effect from 16/05/17 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 mentioned below.

Issued on-----16/05/17-----at New Delhi


(Sunil Chawdhary)
DY.Chief Fire Officer
Delhi Fire Service

- Copy to:- 1.The Joint. Commissioner of Police (Lic.),
1st Floor Police Station,
Defence Colony, New Delhi
2. M/S Paliwal Developers Ltd
Galleria Mall, plot no. 01B,
District Center Mayur Vihar Ph-1, Delhi-92

Following fire safety directives may be adhered to :-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. The means of escape shall be kept unobstructed/unlocked & remain available for speedy evacuation of occupants in case of an emergency.
of smooth and speedy safe evacuation of occupants in case of emergency
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
rendering non functional of fire safety measures, management shall be responsible.
4. Any deviation with regard to construction, electric shall be verified by the concerned building sanctioning authority.
5. The trained fire fighting staff should be available around the clock.
6. This fire safety certificate may not be treated in any case for regularizations of unauthorized construction if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi fire service 2010. The form is available on www.dfs.delhigovt.nic.in.
8. The owner / occupier shall apply for renewal of this fire safety certificated to the director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to it expiry.

INSPECTION REPORT

1. Name & address of the building : DLF Galleria Mall at Plot No. 1B, District Centre, Mayur Vihar -1, Delhi.
2. Building is comprised of : Basement, ground plus Two upper floors
3. Type of Occupancy : Mercantile
4. Type of Case : Renewal
5. Details of Previous FSC : F.6/DFS/MS/2014/NDZ/631 dated-22/05/14
6. Fire Safety direction letter No : F.6/DFS/MS/2011/642/dated-11/04/2011
7. Date of Inspection : 05/05/17
8. Name of the Inspecting Officers: : R.K.Yadav (ADO) Om Prakash (ADO)
9. Name of the designation of Officer from the building side : Colonel Ravinder Ahuja (Centre Manager)
10. Year of Construction : 2008
11. Applicant's letter No : 07/04/17


S.No	Minimum Standards on fire prevention and fire safety U/R 33	Requirement BBL/NBC	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	12 m	24 m	MR
	Gate width	N/A	N/A	N/A
	Width of internal road	06 M	06 M	MR
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	Upper Floor	6 Nos.	6 Nos.	MR
	Basement	9 Nos.	9 Nos.+1 Ramp	MR
	B. Width of Staircases			
	Upper Floor	1.25 M	1.5 M	MR
	Basement	1.25 M	1.5 M & 1 no. Of 1.75 M	MR
	c. Protection of exits			
	Fire check door			
	Pressurization	Required	Provided	MR
	e. No. of continuous staircases to terrace	Required	Provided	MR
g. Width of Corridor	2 nos.	2 nos.	MR	
h. Door Size	1.5 M	3.0 M	MR	
	1.0 Mtrs.	1.0 M	MR	
3	Compartmentation.			
	Fire check door	Required	Provided	MR
	Sealing of electrical shafts	Required	Sealed	MR
	Fire rating of shaft door	2 hrs.	2 hrs.	MR
	Water curtain	N/A	N/A	N/A
	Fire Dampers	Required	Provided	MR
4	Smoke Management System.			
	Basement	30 a/c per hour	30 a/c per hour	MR
	Upper floor	12 a/c per hour	12 a/c per hour	MR
5.	Fire Extinguisher			
	Total numbers	70 Nos.	70 Nos.	MR
	types	Water type & Co2	Water type & Co2	MR
	ISI marking	ISI marked	ISI marked	MR


6	First-aid-Hose Reels.			
	Total numbers of 2 nd floors	05 nos.	05 nos.	MR
	Length of hose reel hose	30 m	30 m	MR
	Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	Heat or Smoke	smoke	MR
	Location of main panel	Control Room	Provided	MR
	Location of repeater panel	Reception	Provided	MR
	Alternate source of power	Battery & DG Set	Provided	MR
	Hooters	Different location	Different location	MR
8	MOEFA	Required	Provided	MR
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	Basement	Required	Provided	MR
	Upper floor	Required	Provided	MR
	sprinkler above false ceiling	Required	Provided	MR
11	Internal Hydrants			
	size of riser/down-comer	150 mm	150 mm	MR
	Number of hydrants each floor	5 nos.	5 nos.	MR
	Hose box each floor	5 nos.	5 nos.	MR
12	Yard Hydrants.			
	Total number of hydrants	06 nos.	08 nos.	MR
	Hose Box	06 nos.	08 nos.	MR
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> ● Ground Level ➤ Discharge of main Pump ➤ Head of Main Pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby pump out put ➤ Standby pump Head ➤ Auto Starting /Manual stopping ➤ Pump House Access ● Terrace Level ➤ Discharge of pump ➤ Head of the Pump ➤ Power supply ➤ Auto Starting of pump 	Required	Provided	MR
		4500 LPM	4500 LPM	MR
		60 Mtrs	60 Mtrs	MR
		2 nos.	2 nos.	MR
		450 LPM	450 LPM	MR
		60 mtrs	60 mtrs	MR
		4500 LPM	4500 LPM	MR
		60 Mtrs.	70 Mtrs.	MR
		Required	Auto	MR
		Required	Provided	MR
		Required	Provided	MR
		900 LPM	900 LPM	MR
		60 mtrs	60 mtrs	MR
		Required	Auto	MR
		Required	Provided	MR


14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	4,50,000 Ltrs.	4,50,000 Ltrs.	MR
	Draw-off connection	Required	Provided	MR
	Fire service inlet	Required	Provided	MR
	Access to tank	Required	Provided	MR
	Overhead Tank capacity	20,000 Ltrs.	20,000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	Required	Provided	MR
	Pressurization of Lift lobby	Required	Provided for Basement	MR
	Communication in lift car	Required	Provided	MR
	Firemen's grounding switch	Required	Provided	MR
	Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	Total area	N/A	N/A	N/A
	Location	N/A	N/A	N/A
19	Fire Control Room			
	Detector system panel	Required	Provided	MR
	Flow switch panel	Required	Provided	MR
	PA system panel	Required	Provided	MR
	Batter backup	Required	Provided	MR
	Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	Manually operated Co2 fire extinguishers provided	MR


The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

In view of deemed compliance of the minimum standards of fire prevention and fire Safety measured as required under the rules. The fire safety certificate issued vide letter no. F.6/DFS/MS/2014/631 dated 22/05/2014 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.


Signature of the Inspecting Officer
Name : R.K.Yadav
Designation : ADO (LN)


Signature of the Inspecting Officer
Name : Om Prakash
Designation : ADO

D.O. (East) *Submitted please.*

11/5

Dy. CFO (NDZ)

11/5

M. S. cell P.T.M.
on leave 12/5
