

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2017/SZ/727

Dated: 22/05/2017

FIRE SAFETY CERTIFICATE


Certified that the **Guru Harkrishan Public School**, Tilak Nagar, New Delhi-110018, comprised of basement, ground floor plus two upper floors, owned/occupied by Guru Harkrishan Public School was issued NOC by this department vide letter F6/DFS/MS/2010/1386 dated 12.05.2010. The School building was re-inspected by the officer concerned of this department on 24.04.2017 in the presence of Sh. Karamjeet Singh (Care Taker) and found basement of the building is closed. Now Guru Harkrishan Public School (Ground plus two upper floors) have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises (Ground plus two upper floors) is fit for occupancy class "Educational" for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....22/05/2017..... at New Delhi.


(VIPIN KENTAL)
CHIEF FIRE OFFICER

Copy to:-

1. The Principal,
Guru Harkrishan Public School,
Tilak Nagar, New Delhi-110018
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi - 110054

9c

15/5/17

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Guru Harkrishan Public School, Tilak Nagar, New Delhi-110018
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of Previous NOC : F6/DFS/MS/2010/1386 dated 12.05.2010
5. Fire Safety directives letter No : N/A
6. Date of inspection : 24.04.2017
7. Name of Inspecting Officer : A.D.O. Sandeep Duggal
8. Name and designation of officers
From the building side : Sh. Karamjeet Singh (Care Taker)
9. Year of Construction : Before 2010
10. Applicant's letter No. : GHPS/TN/2017/GEN./2860 dated 10.03.2017

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per NOC dt. 12.05.2010	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible (06 mtrs) 4.5 mtrs N/A	12 mtrs 05 mtrs N/A	MR MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	04 No's N/A	04 No's N/A	MR NA, basement is closed & not in use
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	Old case N/A	125 cms (04 no.'s) N/A	MR, being old case NA, basement is closed & not in use
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace			
	e. Width of Corridor			
	f. Door Size			
		Required	Two	MR
		150 cms	210 cms	MR
		100 cms	112 cms	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A N/A N/A N/A N/A	Provided N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	Required	Exhaust fans are provided	MR
	<ul style="list-style-type: none"> • Upper floors 	Required	Natural ventilation	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	08 no.'s ABC/CO ₂ type ISI marked	13 no.'s provided Provided ISI marked	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	04 no.'s/floor 30 mtrs 5 cms	Provided Provided Provided	MR MR MR

7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Main Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Alternate source of power 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hooters' Location 	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	Provided	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	Required	Provided	MR
	<ul style="list-style-type: none"> Ground Floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	N/A	Provided	N/A
	<ul style="list-style-type: none"> Number of hydrants per floor 	N/A	One	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	One	N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	N/A	One	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	One	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> Pump House Access 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	Old case	450 LPM & 180 LPM Provided	MR
		40 mtrs	Provided	MR
		Required	Provided	MR
		N/A	N/A	N/A
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	Provided	N/A
		N/A	N/A	N/A
		Old Case	5000 ltrs Provided	MR (being old case)
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			No Lift
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pressurization of Lift lobby 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Communication In lift Car 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fireman's Grounding Switch 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Lift Signage 	N/A	N/A	N/A
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> Total Area 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location 	N/A	N/A	N/A

2/8

19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection and shortcomings issued vide letter no. F.6.DFS.MS/School/2016/SZ/2610 dated 04.11.2016 has been complied. ✓

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter number F6/DFS/MS/2010/1386 dated 12.05.2010 renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Note:- As per letter submitted by the Principal (placed at C-28) the school management is certified that they are not using the area of the basement and there are three rooms in the basement which are locked. The management assure that they will not using the basement area in the future.

Sandeep
04/05/17
 Signature of Inspecting Officer
 Name:- Sandeep Duggal
 Designation:- Asstt. Divisional Officer

[Signature]
 D.O. (South West) 04/05/17

866/CF-02
9/5/17-18/5
 D CFO (SZ)
[Signature]
 CFO (SZ)
 m/s cell FT/107.
[Signature]



F.T. letter is put up for Sign please.
[Signature]
 CFO (South) 15/5/17