

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

Fax No. 011-23412593, Ph. 011-23412225

NO.F6/ DFS/ MS/Assembly/SZ/2017/ 717

Dated: 18/05/17

**FIRE SAFETY CERTIFICATE**

Certified that, Science of the Soul Research Centre , located at Kishangarh, Near Sector- A, Vasant Kunj, New Delhi comprised of Basement, Stilt, Ground + 01 Upper Floors owned/occupied by Science of the Soul Research Centre was inspected by the officer concerned of this department on 06/05/2017 in the presence of Mr. Rakesh and observed that the said building/premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fir for occupancy class-D "Assembly Building "(Religious)" with effect from 18/5/17 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 18/5/17 at New Delhi by

*W*  
*18/5*  
Vipin Kental  
Chief Fire Officer

*fi*  
*OK*

Copy to: -

1. The Authorized Signatory, Science of the Soul Research Centre, Guru Ravi Dass Marg, Pusa Road, New Delhi-110005
2. The Ex. Engineer (Bldg), Building Department, SDMC, Civic Center, Minto Road, New Delhi

**Conditions for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [ sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

## INSPECTION REPORT


S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	BBL/NBC Requirement	Provided at Site	Remarks MR/NMR
1	Name & Address of the Building	Science of the Soul Research Centre, Kishangarh, Near Sector-A, Pocket-A, Vasant Kunj, ND		
2	Type of Occupancy	Assembly Building "Group-D" (Religious)		
3	Building Comprised of	Basement, Stilt, Ground plus one upper floor		
4	Type of Case	New		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	F.6/DFS/MS/2014/128 dated 12.05.2014		
7	Date of Inspection	06/05/2017		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mr. Rakesh Kumar (Engineer)		
10	Year of construction	2015		
11	Applicant letter No.	Nil Dt. 24-04-2017 ODD No. 4827 Dt. 24-04-2017		
<b>1</b>	<b>Access to Building.</b>			
	1. Road width	09 Mts.	09 Mts.	MR
	2. Gate width	5 mtr	5 mtr	MR
	3. Width of internal road	NA	NA.	NA
<b>2</b>	<b>Number, width, type and arrangements of exits.</b>			
	<b>a. Number of Staircase</b>			
	1. Upper floors	2 No's	2 No's	MR
	2. Basement floor	2 No's	2 No's	MR
	<b>b. Width of Staircase</b>			
	1. Upper floors	2 m & 1.5 m	2 m & 1.59 m	MR
	2. Basement floor	2 m & 1.5 m	2 m & 1.50 m	MR
	<b>c. Protection of exits</b>			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	NA	NA	NA
	<b>d. No. of continuous staircase to terrace</b>	Two	Two	MR
	<b>e. Width of corridor</b>	NA	NA	NA
	<b>f. Door size</b>	1.25 m	1.25 m	MR
<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door.	NA	NA	NA
	2. Sealing of electrical shafts.	Required	Provided	MR
	3. Fire rating of shaft door.	NA	NA	NA
	4. Water curtain	NA	NA	NA
	5. Fire dampers.	Yes	Provided	MR
<b>4.</b>	<b>Smoke Management system.</b>			
	1. Basement	Required	Provided	MR
	2. Upper floors	Required	Natural ventilation	MR
<b>5.</b>	<b>Fire Extinguishers.</b>			
	1. Total numbers	06 No's Fire Extinguisher	06 No's	MR
	2. Types	ISI Marked	ABC-04, Co2- 02	MR
	3. ISI Marking		Yes	MR
<b>6.</b>	<b>First Aid Hose Reels.</b>			
	1. Total numbers on each floor.	One	Provided	MR
	2. Length of hose-reel hose.	30 m	Provided	MR
	3. Nozzle Diameter	05 mm	Provided	MR

New

Science of the Soul Research Centre, Kishangarh, Vasant Kunj

7	<b>Automatic Fire Detection and Alarming system.</b>			
	1. Type of detectors	NA	NA	NA
	2. Location of Main Panel	NA	NA	NA
	3. Location of Repeater Panel	NA	NA	NA
	4. Alternate source of power	NA	NA	NA
	5. Hooter's location	NA	NA	NA
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	NA	NA	NA
10.	<b>Automatic Sprinkler System</b>			
	1. Basement	NA	NA	NA
	2. Upper floors	NA	NA	NA
	3. Sprinkler above false ceiling	NA	NA	NA
11.	<b>Internal Hydrants.</b>			
	1. Size of Riser/Down-comer	100 mm	Provided	MR
	2. Number of Hydrant per floor	One	Provided	MR
	3. Hose box.	One	Provided	MR
12.	<b>Yard Hydrants.</b>			
	1. Total number of hydrants.	NA	NA	NA
	2. Hose box.	NA	NA	NA
13.	<b>Pumping arrangements.</b>			
	<b>a) Ground Level</b>			
	➤ Discharge of main pump.	NA	NA	NA
	➤ Head of main pump.	NA	NA	NA
	➤ Number of main pumps.	NA	NA	NA
	➤ Jockey Pump output.	NA	NA	NA
	➤ Jockey Pump head.	NA	NA	NA
	➤ Standby Pump output.	NA	NA	NA
	➤ Standby Pump head.	NA	NA	NA
	➤ h) Auto Starting/Manual Stopping.	NA	NA	NA
	<b>b) Terrace Level</b>			
	➤ Discharge of pump.	450 LPM	450 LPM	MR
	➤ Head of pump.	40 mtr	40 mtr	MR
	➤ Power supply.	Required	Provided	MR
	➤ d) Auto starting of pump.	Required	Provided	MR
14.	<b>Captive water storage for Fire Fighting.</b>			
	1. Underground tank capacity.	NA	NA	NA
	2. Draw-off connection.	NA	NA	NA
	3. Fire Service Inlet.	NA	NA	NA
	4. Access to tank.	NA	NA	NA
	5. Overhead tank capacity.	10,000 Ltr.	10,000 Ltr.	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	1. Pressurization of lift shaft.	NA	NA	NA
	2. Pressurization of lift lobby.	NA	NA	NA
	3. Communication in lift car.	NA	NA	NA
	4. Fireman's switch.	NA	NA	NA
	5. Lift signage.	NA	NA	NA
17	<b>Standby Power Supply</b>	Required	Provided	MR
18.	<b>Refuge Area</b>			
	1. Total area	NA	NA	NA
	2. Location	NA	NA	NA


N/15

<b>19.</b>	<b>Fire Control Room.</b>			
	1. Detector System Panel.	NA	NA	NA
	2. Flow Switch Panel.	NA	NA	NA
	3. PA system Panel.	NA	NA	NA
	4. Battery backup	NA	NA	NA
	5. Building floor plan	NA	NA	NA
<b>20.</b>	<b>Special Fire Protection System for the Protection of special Risk, if any :</b>			NA
<p>The Fire protection systems provided in the building were randomly checked/ tested and found functional at the time of inspection.</p> <p>The shortcoming issued by this department vide letter no.F6/DFS/MS/2017/SZ/358 dated 8/02/2017 have been rectified.</p> <p>Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules, 2010.</p> <p>Accordingly, DFA is put up for approval and signature please.</p> <p style="text-align: right;">   Signature of the Inspecting Officer  Name : R.N. Singh  Designation: ADO </p>				

New

Science of the Soul Research Centre, Kishangarh, Vasant Kunj

Div. Officer (SD)

  
9/5/17