

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/2017/ EH/w2/723

Dated: 19/05/2017


FIRE SAFETY CERTIFICATE

Certified that the M/s Suravie Restaurant (A unit of Holy Shrine Hotels Pvt. Ltd.) at 2/85, First floor Club Road, Punjabi Bagh, New Delhi-110028 in the building comprised of Ground + 03 Upper Floors was issued FSC vide Letter No. **F6/DFS/MS/EH/2014/WZ/578 dated 08/05/2014**. The premises was re inspected by the team of officers of this department on **02-05-2017** in the presence of Sh Ashish, found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly Building" Group D with effect from 19/05/17 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on19/05/17..... at New Delhi by.


(Atul Garg)

Chief Fire Officer,
Delhi Fire Service.


16/5/17

Copy to:

Sh Naveet Gupta (Director) M/s Suravie Restaurant (A unit of Holy Shrine Hotels Pvt. Ltd.) at 2/85, First floor Club Road, Punjabi Bagh, New Delhi-110028.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. All the doors, Exits and internal roads must be kept free from any obstruction.
9. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry

INSPECTION REPORT

1. Name & address of the building : **Suravie Restaurant** (A unit of Holy Shrine Hotels Pvt. Ltd.) at 2/85, First floor Club Road, Punjabi Bagh, New Delhi-110028.
2. Type of Occupancy : Assembly
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/EH/2014/WZ/578 dated 08/05/2014
5. Fire Safety directives letter No. : Nil
6. Date of inspection : 02.05.2017
7. Name of the Inspecting Officers : Udai Vir Singh ADO (W.P.)
8. Name and designation of officers
From the building side : Mr. Ashish
9. Year of Construction :
10. Applicant's letter No. : nil dated 12-04-2017

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	12 m	12 Provided	M/R
	• Gate width	NR	NR	NR
	• Width of internal road	NR	NR	NR
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	2 staircase provided up to 1 st floor for restaurant	M/R
	• Basement	02	02 Provided	M/R
	b. Width of staircases			
	• Upper Floors	1.5 m & 1.25 mtr	120cm&150cm	M.R.(Old Case)
	• Basement	1.5 mtr	142 & 120cm (Separate Entry/Exit)	M.R.
	c. Protection of exits			
	• Fire check door	NR	NR	NR
	• Pressurization	NR	NR	NR
	d. No. of continuous staircases to terrace	01	Provided	M/R
	e. Width of Corridor	N.A	NA (Hall only)	NA
	f. Door size	2 mtr	Provided	M.R.
3.	Compartmentation.			
	• Fire check door	NR	NR	NR
	• Sealing of electrical shafts	NR	NR	NR
	• Fire Rating of shaft door	NR	NR	NR
	• Water Curtain	NR	NR	NR
	• Fire Dampers	NR	NR	NR
4.	Smoke Management System. Basement owned by other person & have separate entry/exit			
	• Basements	NR	NP	NR
	• Upper floors	12 a/c per hour	Provided	M.R.
5.	Fire Extinguishers			
	• Total numbers	04 nos	06	M R

6. Date of inspection : 02.05.2017
 7. Name of the Inspecting Officers : Udai Vir Singh ADO (W.P.)
 8. Name and designation of officers :
 From the building side : Mr. Ashish
 9. Year of Construction :
 10. Applicant's letter No. : nil dated 12-04-2017

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	12 m	12 Provided	M/R
	• Gate width	NR	NR	NR
	• Width of internal road	NR	NR	NR
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	2 staircase provided up to 1 st floor for restaurant	M/R
	• Basement	02	02 Provided	M/R
	b. Width of staircases			
	• Upper Floors	1.5 m & 1.25 mtr	120cm&150cm	M.R.(Old Case)
	• Basement	1.5 mtr	142 & 120cm (Separate Entry/Exit)	M.R.
	c. Protection of exits			
	• Fire check door	NR	NR	NR
	• Pressurization	NR	NR	NR
	d. No. of continuous staircases to terrace	01	Provided	M/R
	e. Width of Corridor	N.A	NA (Hall only)	NA
	f. Door size	2 mtr	Provided	M.R.
3.	Compartmentation.			
	• Fire check door	NR	NR	NR
	• Sealing of electrical shafts	NR	NR	NR
	• Fire Rating of shaft door	NR	NR	NR
	• Water Curtain	NR	NR	NR
	• Fire Dampers	NR	NR	NR
4.	Smoke Management System. Basement owned by other person & have separate entry/exit			
	• Basements	NR	NP	NR
	• Upper floors	12 a/c per hour	Provided	M.R.
5.	Fire Extinguishers			
	• Total numbers	04 nos	06	M.R
	• Types	ABC & CO ₂	Provided	M.R
	• IS marking	ISI marked	Provided	M.R
6.	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided	M.R
	• Length of hose reel hose	30 m required	Provided	M.R
	• Nozzle diameter	5 mm	Provided	M.R

Handwritten signature/initials.

7.	Automatic fire detection and alarming system			
	• Type of detectors	NR	NR	NR
	• Location of Main Panel	NR	NR	NR
	• Location of Repeater Panel	NR	NR	NR
	• Alternate source of power	NR	NR	NR
	• Hooter's Location	NR	NR	NR
8.	MOEFA	Required	Provided	M.R
9.	Public Address System	NR	NR	NR
10.	Automatic Sprinkler system			
	• Basement	NR	NR	NR
	• Upper Floor	NR	Provided	M.R
	• Sprinkler above false ceiling	NR	Provided	M.R
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	provided	M.R
	• Number of hydrants per floor	01	provided	M.R.
	• Hose Box	01	provided	M.R
12.	Yard Hydrants.			
	• Total number of hydrants	NR	NR	NR
	• Hose Box	NR	NR	NR
3.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	NR	NR	NR
	➤ Head of Main pump	NR	NR	NR
	➤ Number of main pumps	NR	NR	NR
	➤ Jockey Pump out put	NR	NR	NR
	➤ Jockey pump head	NR	NR	NR
	➤ Standby pump out put	NR	NR	NR
	➤ Standby pump Head	NR	NR	NR
	➤ Auto Starting/Manual stopping	NR	NR	NR
	➤ Pump Hose Access	NR	NR	NR
	Terrace level			
	➤ Discharge of pump	450 LPM	Provided	M.R.
	➤ Head of the pump	33 m	Provided	M.R.
	➤ Power supply	Required	Provided	M.R.
	➤ Auto Starting of pump	Required	Provided	M.R.
4.	Captive Water Storage for fire fighting.:			
	Underground tank capacity	NR	NR	NR
	➤ Draw -off connection	NR	NR	NR
	➤ Fire service inlet	NR	NR	NR
	➤ Access to tank	NR	NR	NR
	➤ Overhead Tank Capacity	10,000 ltrs	Provided	M.R.
5.	Exit Signage.	required	Provided	M.R.
6.	Provision of Lifts			
	• Pressurization of Lift Shaft	NR	NR	NR

	Public Address System	NR	NR	NR
10.	Automatic Sprinkler system	Required	Provided	M.R
	<ul style="list-style-type: none"> Basement 	NR	NR	NR
	<ul style="list-style-type: none"> Upper Floor 	NR	Provided	M.R
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NR	Provided	M.R
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100 mm	provided	M.R
	<ul style="list-style-type: none"> Number of hydrants per floor 	01	provided	M.R.
	<ul style="list-style-type: none"> Hose Box 	01	provided	M.R
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	NR	NR	NR
	<ul style="list-style-type: none"> Hose Box 	NR	NR	NR
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	NR	NR	NR
	➤ Head of Main pump	NR	NR	NR
	➤ Number of main pumps	NR	NR	NR
	➤ Jockey Pump out put	NR	NR	NR
	➤ Jockey pump head	NR	NR	NR
	➤ Standby pump out put	NR	NR	NR
	➤ Standby pump Head	NR	NR	NR
	➤ Auto Starting/Manual stopping	NR	NR	NR
	➤ Pump Hose Access	NR	NR	NR
	Terrace level			
	➤ Discharge of pump	450 LPM	Provided	M.R.
	➤ Head of the pump	33 m	Provided	M.R.
	➤ Power supply	Required	Provided	M.R.
	➤ Auto Starting of pump	Required	Provided	M.R.
14.	Captive Water Storage for fire fighting.:			
	Underground tank capacity	NR	NR	NR
	➤ Draw -off connection	NR	NR	NR
	➤ Fire service inlet	NR	NR	NR
	➤ Access to tank	NR	NR	NR
	➤ Overhead Tank Capacity	10,000 ltrs	Provided	M.R.
15.	Exit Signage.	required	Provided	M.R.
16.	Provision of Lifts			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	NR	NR	NR
	<ul style="list-style-type: none"> Pressurization of Lift lobby 	NR	NR	NR
	<ul style="list-style-type: none"> Communication In lift Car 	NR	NR	NR
	<ul style="list-style-type: none"> Fireman's Grounding Switch 	NR	NR	NR
	<ul style="list-style-type: none"> Lift Signage 	NR	NR	NR
17.	Standby power supply	Required	Provided	M.R

46

18.	Refuge Area			
	➤ Total Area	NR	NR	NR
	➤ Location	NR	NR	NR
19.	Fire Control Room			
	➤ Detector System Panel	NR	NR	NR
	➤ Flow Switch Panel	NR	NR	NR
	➤ PA system Panel	NR	NR	NR
	➤ Batter backup	NR	NR	NR
	➤ Building Floor plans	NR	NR	NR
20.	Special Fire Protection Systems for Protection of special Risks, if any:	NR	NR	NR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/EH/2014/WZ/578 dated 08/05/2014 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note;- Basement owned by other person & have separate Entry/Exit.

Signature of the Inspecting Officer

Name Udai Vir Singh

Designation ADO (W.P.)

D. Vir Singh

Udai Vir Singh

[Signature]