

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

NO. FG/DFS/MS/EH/2017/S2/720

Dated: 19/05/17

FIRE SAFETY CERTIFICATE

Certified that M/s Zerruco (A Unit of Turkinz) at The Ashok Hotel at 50-B, Diplomatic Enclave, Chanakyapuri, New Delhi-110021, comprised of ground plus seven upper floors but restaurant is at ground floor only, owned/occupied by M/s Zerruco (A Unit of Turkinz), have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules,2010 and verified by the officer concerned of this department on dated 09.05.17 in the presence of Mr. Saurabh Kumar, General Manager and found that the premises is fit for occupancy class Group-D Assembly Building (Restaurant) with effect from ..19.05.2017 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules,2010.

Issued on.....19/05/.....2017 at New Delhi by

(Vipin Kental)

Chief Fire Officer

T.No.011-23412225

Copy to:- 1. Dr. P.K.Sharma, MOH, NDMC, Palika Kendra, New Delhi.

2. M/s Zerruco (A Unit of Turkinz) at The Ashok Hotel at 50-B,Diplomatic Enclave, Chanakyapuri, New Delhi-110021.

Conditions for the validity of fire safety certificate are as under:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. The employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All fire fighting equipment's shall be maintained in perfect working condition all time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate, six month prior to its expiry.

1101

INSPECTION REPORT

1	Name & address of the building	M/s Zerruco (A Unit of Turkinz) at The Ashok Hotel at 50-B, Diplomatic Enclave, Chanakyapuri, New Delhi-110021.		
2	Building Comprised of	Ground +7 Upper floors but restaurant is at ground floor only.		
3	Type of Occupancy	Assembly Occupancy-Restaurant		
4	Type of case	New Case		
5	Details of previous NOC	Nil.		
6	Fire safety directives letter No	Nil.		
7	Date of inspection	09.05.2017		
8	Name of the inspecting Officers	ADO Vedpal		
9	Name and designation of officers from the building side	Sh. Saurab Kumar (General Manager)		
10	Year of construction	1956		
11	Applicant's letter No.	No.D/MOH/138/Lic./SI-X		Dt. 16.03.2017
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	Required	15m	MR
	2) Gate width	Required	6m	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. basements	N.A.	N.A.	N.A.
	b. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. basements	N.A.	N.A.	N.A.
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N.A.	N.A.	N.A.
	d. No. of continuous staircase to terrace	Required	(Three) Provided	MR
	e. Width of corridor	N.A.	N.A.	N.A.
	f. Door size	2m/1.5m	2m & 1.70m(Two Exits)	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	Required	Provided	MR
	3. Fire Rating of shaft door	N.A.	N.A.	N.A.
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	Required	Provided	MR
4	Smoke Management system.			
	basement	30 a/c per hour	N.A.	N.A.
	upper floors	12 a/c per hour	Exhaust Fans Provided	MR
5	Fire Extinguishers			
	Total numbers	04Nos.	04Nos	MR
	Types	ABC/CO2 & WCO2	ABC & Water Co2,	MR
	ISI marking	ISI	Yes	MR
6	First-Aid Hose Reels.	(Fire fighting system is common for entire building)		
	Total numbers on each floor	01no near restaurant	01no near restaurant	MR
	Length of Hose reel hose	30 m	30m Provided	MR
	Nozzle Diameter	5 mm	5mm Provided	MR

(Handwritten signature)

N102

7	Automatic fire detection and alarming system			
	Type of detectors	Heat & Smoke	Heat & Smoke	MR
	location of Main Panel	Required	Provided at reception	MR
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	Required	Battery Backup	MR
	hooter's location	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System. (Fire fighting system is common for entire building)			
	basement	N.A.	N.A.	N.A.
	upper floors	Required	Provided	MR
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants (Fire fighting system is common for entire building)			
	Size of riser/down-corner	200 mm	Provided	MR
	Number of Hydrants per floor	3 nos each floor	Provided	MR
	hose Box	3 nos each floor	Porvided	MR
12	Yard Hydrants. (Fire fighting system is common for entire building)			
	Total number of hydrants	Required	10Nos+19Moniters Provided	MR
	Hose boxes	Required	10 No. Provided	MR
13	Pumping arrangements (Fire fighting system is common for entire building)			
	1. Ground level			
	a. Discharge of main Pump	2850 LPM	Provided	MR
	b. Head of main pump	80m	80m	MR
	c. Number of main pumps	Two	2nos.	MR
	d. jockey pump out put	225 LPM	225LPM	MR
	e. jockey pump head	80m	80m	MR
	f. Standby Pump output	2850 LPM	2850LPM	MR
	g. Stanby Pump head	80m	80m	MR
	h. Auto Starting/Manual stopping	Required	Provided	MR
	pump house access	Required	Provided	MR
	2. Terrace level			
	a. Discharge of pump	900LPM	900LPM	MR
	b. head of the pump	40m	40m	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting (Fire fighting system is common for entire building)			
	1. Underground tank capacity	4,00,000 ltr	Provided	MR
	a. Draw-off connection	Required	Provided	MR
	b. fire service inlet	Required	Provided	MR
	c. Access to tank	Required	Provided	MR
	Over head tank Capacity	25,000 ltr	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N.A.	N.A.	N.A.
	b. pressurization of lift lobby	N.A.	N.A.	N.A.
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area. Not Required			
	Total area	N/A	N/A	N/A
	location	N/A	N/A	N/A
19	Fire control room			
	a. Detector system Panel	Required	Provided	MR
	b. Flow switch Panel	N.A.	N.A.	N.A.
	c. PA system Panel	Required	Provided	MR
	d. Batter backup	Required	Provided	MR
	e. Building floor plans	Required	Provided	MR

N/03

20	Special Fire Protection systems Required for protection of special risks, if any:	ABC Type Fire Extinguishers Provided near electric panel	MR
----	---	--	----

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Accordingly DFA is put up for kind consideration please.

[Handwritten Signature] 11/5/17

Signature of the Inspecting Officer

Name Vedpal
Designation ADO (S.J.)

~~D.O. (S.D)~~
[Handwritten Signature]
12/5/17