

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHTPLACE  
NEW DELHI- 110001

No.F6/DFS/MS/School/NDZ/2017/ 782

Dated:  
31/05/17

FIRE SAFETY CERTIFICATE

Certified that the **Dashmesh Public School** at C-Block, Vivek Vihar, Delhi-95, owned/occupied by Dashmesh Public School, comprising of ground plus two upper floors was granted FSC vide letter no. No. F.6/DFS/MS/School/2014/519 dated 25/04/14. The school building was inspected by the officer concerned of this department on 22/05/17 in the presence of **Smt.Sarita Sexena** (Principal) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular no.262-362 Dated 17.01.2005 issued by the Director of Education and found that the building is fit for occupancy class B "Educational Building" with effect from ...31/05/17..... for a period of **three** years, subject to conditions printed overleaf.

Issued on .....31/05/17..... at New Delhi by

  
(Vipin Kental)

Chief Fire Officer

To,

The Principal  
Dashmesh Public School  
C-Block, Vivek Vihar, Delhi-95,

Copy to:-

The Director of Education  
GNCT of Delhi, Old secretariat  
Delhi -54.

- Conditions -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.

The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

1. Name & address of the building: Dashmesh Public School at C-Block, Vivek Vihar, Delhi -95.
2. Building is comprised of : Ground +2 upper floors
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/School/2014/519 dated 25/04/14
6. Fire Safety direction letter No : Circular No.262-362 Dated 17.01.2005 Director of Education
7. Date of Inspection : 22/05/17
8. Name of the Inspecting officers: ADO R.K.Yadav
9. Name and designation of Officer from the building side : Smt.Sarita Sexena (Principal)
10. Year of Construction : 1980
11. Applicant's letter No : DPS/No.64/1257dated 27/04/17

NO.	Minimum Standards on fire prevention and fire safety U/R33	Old Circular Requirement	Provided at Site	Remarks
1	Access to building			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	06 Mtrs.	15 Mtrs.	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basement</li> </ul>	02 Nos	02 Nos.	MR
		N/A	N/A	N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basement</li> </ul>	1.5 M	1.5 M & 1.15 M	MR
		N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
	e. No. of continuous staircases to terrace	2 nos.	2 Nos.	MR
	g. Width of Corridor	1.5 M	1.8 M	MR
	h. Door Size	1.0 Mtrs	1.0 Mtrs	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire rating of shaft door</li> <li>• Water curtain</li> <li>• Fire Dampers</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper floor</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> </ul>	12 Nos.	12 Nos.	MR
		ABC & Co2	ABC & Co2	MR
	<ul style="list-style-type: none"> <li>• IS marking</li> </ul>	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	1 no.	1 no.	MR
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	30 M	30 M	MR
		5 mm	5 mm	MR

7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants	Required	Provided	MR
	• size of riser/down-comer	100 MM	100 MM	MR
	• Number of hydrants per floor	1 No.	1 No.	MR
	• Hose Box	1 No.	1 No.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the Pump	40 M	40 M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	5000 Ltrs.	5000 Ltrs.	MR
15	Exit Signage.	N/A	N/A	N/A
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A

N17

20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A
----	--	-----	-----	-----

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The NOC issued vide letter no. F.6/DFS/MS/School/2014/519 dated 25/04/14 renewal under the circular no.262-362 dated 17.01.2005 is recommended.

R K Yadav

Signature of the Inspecting Officer

Name : R. K. Yadav

Designation : ADO (Laxmi Nagar)

24/5/12

DO (EO) on E-L

DY CFO (ND2)

[Signature]  
26/5

C. F. O.

m. scell

FT letter

[Signature]  
29/5

Say, FT letter is put up for signature please

CFO (ND2)

m. scell [Signature]  
31/5

R K Yadav  
31/5/2012

178/CP/ND2  
30/5/12/21/-