

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No.F.6/DFS/MS/ school/2017/wz/736

Dated: 24/05/2017

**FIRE SAFETY CERTIFICATE**

Certified that the Ganga International School at HiranKudna, Rohtak Road, Delhi-41, comprised of Ground + Two Upper Floors owned / occupied by Ganga International School, has already been issued Fire Safety Certificate Vide letter No. F6/DFS/MS/School/2014/WZ/611 dated 15.05.2014. The premises was re-inspected by the officer concerned of Fire Service on 01.05.2017 in the presence of Smt. Charu Kapoor (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Directorate of Education, Circular No. 262-362 dated 17.01.2005 and that the building / premises is fit for occupancy class-B Educational with effect from 24/05/17 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 24/05/17 at New Delhi by,

  
(ATUL GARG)  
CHIEF FIRE OFFICER  


Copy to :-

1. The Principal, Ganga International School, HiranKudna, Rohtak Road, Delhi-41.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

N/A

G+2 (School Block)-Covered area=4000Yard<sup>2</sup>G+3 (Hostel Block)-Covered area=8000Yard<sup>2</sup>

Total Area=12 Acres

**INSPECTION REPORT**

1. Name & address of the building: Ganga International School,  
Hiran Kudna, Rohtak Road, Delhi-41.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : Letter No F6/DFS/MS/School/2014/WZ/611 dated 15.05.2014
5. Fire Safety directives Letter No. : DOE Circular Dated 17.01.2005
6. Date of inspection : 01.05.2017
7. Name of the Inspecting Officer : A.K. Jaiswal
8. Name and designation of Officer  
from the building side : Smt. Charu Kapoor (Principal)
9. Year of Construction : 2009-2010
10. Applicant's letter No. : GIS/31/2017-18 dated 12/03/2017

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL/ <u>DOE Cir.17.1.2005</u> Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr.	6 mtr.	MR
	• Gate width	4.5 mtr.	4.5 mtr.	MR
	• Width of internal road	6 mtr.	6 mtr.	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.50 Mtr.	2.50 Mtr x 2	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NR	NR	NR
	• Pressurization	NR	NR	NR
	d. No of continuous staircase to terrace	1	1	MR
	e. Width Of Corridor	1.50 Mtr.	1.50 Mtr.	MR
	f. Door Size	1.00 Mtr.	1.00 Mtr.	MR

AB

