

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001

No.F6/DFS/MS/GH/2017/738

Dated : 24/5/17

FIRE SAFETY CERTIFICATE

Certified that the **Grand Godwin Guest House, 8502/41, Arakashan Road, Pahar Ganj, New Delhi** comprised of **Ground + 4 Upper Floors, Ground floor – 03 guest rooms + reception + 01 office, 1<sup>st</sup> floor to 4<sup>th</sup> floor 09 guest rooms at each floor total 39 guest rooms** was granted FSC by this department vide letter **No.F6/DFS/MS/GH/2014/NDZ/918 dated 24/07/14**. The premises was re-inspected by the officer concerned of this department on **06/05/17** in the presence of **Mr. Vinod Sareen (Prop.)** and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of class **Residential Group –A-1` for total 39 guest rooms only as above** with effect from ~~24/5/17~~ for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. mentioned below.

Issued on \_\_\_ at New Delhi by.

24/5/17

W  
28/5  
(Vipin Kental)  
Chief Fire Officer  
Delhi Fire Service  
Ph: - 011-23412225

Copy to:-

1. The Joint. Commissioner of Police (Lic),  
First Floor, P.S. Defence Colony New Delhi
2. The Licensee,  
Grand Godwin Guest House,  
8502/41, Arakashan Road, Pahar Ganj, New Delhi.

Conditions:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. The means of escape shall be kept unobstructed / unlocked & remain available for speedy evacuation of occupants in case of an emergency.
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

11-16

INSPECTION REPORT

- 1. Name & address of the building:- Grand Godwin Guest House 8502/41, Arakashan Road, Pahar Ganj New Delhi.
- 2. Type of occupancy:- Residential Group A-1 Ground + 4 Upper Floors. Ground floor – 03 guest rooms + reception + 01 office, 1<sup>st</sup> floor to 4<sup>th</sup> floor 09 guest rooms at each floor total 39 guest rooms
- 3. Type of case:- Renewal
- 4. Details of previous FSC:- No. F6/DFS/MS/GH/2014/NDZ/918 dated 24/07/2014.
- 5. Fire safety directives No.- N/A
- 6. Date of inspection:- 06/05/17
- 7. Name of the inspecting officer:- D.O. Gurmukh Singh
- 8. Name & designation of officer  
From the building side:- Mr. Vinod Sareen (Prop.).
- 9. Year of construction:- 1983.
- 10. Applicant's letter No:- 698/Addl. C.P./Lic. (H) dated 31/03/17

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site (PSS)	Remarks MR/NMR
1.	Access to Building			
	1) Road width	N/A	9 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01 No.	01 No.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	80 cms.	130 cms	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1 mtr.	1 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A

200

30

200

	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	12ACPH	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	20 Nos.	22 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number at each floor	01 no.	01 no.	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	5 mm.	5 mm.	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System / Intercom	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR

	b) Head of pump	30 Mtr.	30 Mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	5,000 ltrs.	5,000 ltrs.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the guest house were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/GH/2014/NDZ/918 dated 24/07/2014, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended.

*Gurmukh Singh*  
16/5/17  
Gurmukh Singh  
Divisional Officer

Dy CRO (NDZ)

*[Signature]*

17/5. re check on tank cap again  
2 P TM.

307/CF-NDZ  
22/5/17/24/5

C.F/O - MSCell  
19/5

Sir, Although the OHT of RCC of big size is available & cap. may be 50,000 lbs but as per previous inspection report requirement is 5,000 lbs