

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No. F6/DFS/MS/School/2017/NDZ/ 787

Dated: 01/06/2017

FIRE SAFETY CERTIFICATE

Certified that the Greenway Modern School located at between pocked A & D, Dilshad Garden, Delhi-110095, comprised of basement, ground plus four upper floors only owned/occupied by Greenway Modern School was issued FSC vide letter No-F6/DFS/MS/School/2013/NDZ/983 dated 27/09/2013. The school building was re-inspected by the officer concerned of this department on 25/05/2017 in the presence of Mr. Tarun Sachdeva, Vice Principal of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with rules 33 of the Delhi Fire Service Rules, 2010 and observed that the school building is fit for occupancy class "B" 'Educational Building' with effect from ...01/06/17 for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on.....01/06/2017.....at New Delhi by.

(Vipin Kental)  
Chief Fire Officer

To,

The Vice Principal  
Greenway Modern School  
Between pocked A & D,  
Dilshad Garden,  
Delhi-110095

Copy:-

The Dy. Director of Education,  
B-Block, Yamuna Vihar,  
Delhi-110053

37/5  
o/c  
he

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.



1. Name & address of the building : Greenway Modern School,  
Between Pocket A & D, Dilshad Garden, Delhi -110095
2. Building is comprised of : Basement, Ground plus four upper floors
3. Type of Occupancy : Educational
4. Type of Case : **Renewal**
5. Details of Previous NOC letter : F6/DFS/MS/School/2013/NDZ/983 dated 27/09/13
6. Fire Safety directive letter No. : F.6/DFS/MS/BP/2010/3019 dated 27/10/2010
7. Date of Inspection : 25/05/17
8. Name of the Inspecting officers : ADO V. B. Yadav
9. Name and designation of Officer from the building side : Mr. Tarun Sachdeva, Vice Principal
10. Year of Construction : 2005 & 2010
11. Applicant's letter No : Letter No.GMS/F.Cert/2017, Dated- 19/04/2017

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building.			
	• Road width	06 mtr.	15 mtr.	MR
	• Gate width	4.5 mtrs	06 mtrs	MR
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper floor	05 nos.	05 nos.	MR
	• Basement	02 nos.	02 nos.	MR
	b. Width of Staircases			
	• Upper floor	1.50 mtrs.	1.50 mtrs.	MR
	• Basement	1.50 mtrs.	1.50 mtrs. + 1 Ramp (04 mtrs)	MR
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	02 nos.	02 nos.	MR
	e. Width of Corridor	1.50 mtr.	1.80 mtr.	MR
	f. Door Size	01 mtr.	01 mtr.	MR
	g. No. of door in class room	02 nos.	01 & 02 nos.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	Required	Exhaust fans	MR
	• Upper floor	N/A	N/A	N/A
05	Fire Extinguishers.			
	• Total numbers	22 nos.	26 nos.	MR
	• Types	ABC /CO <sub>2</sub>	Provided	MR
	• IS marking	ISI marked	Provided	MR



06	First-Aid-Hose Reels.			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	02 No.	02 no.	MR
		30 mtr.	30 mtrs	MR
		05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System.			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of main panel</li> <li>Location of repeater panel</li> <li>Alternate source of power</li> <li>Hooter's location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> <li>Basement</li> <li>upper floor</li> <li>sprinkler above false ceiling</li> </ul>	Required	Provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> <li>size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose box</li> </ul>	100 mm	100 mm	MR
		02 nos.	02 nos.	MR
		02 nos.	02 nos.	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	<ul style="list-style-type: none"> <li>Discharge of main pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby pump out put</li> <li>Standby pump head</li> <li>Auto Starting /Manual stopping</li> <li>Pump house access</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	➤ Terrace Level			
	<ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power supply</li> <li>Auto Starting of pump</li> </ul>	900 lpm	900 lpm X 2	MR
		40 M	40 M	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead tank capacity</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	MR
		Required	Provided	MR
		25,000 ltrs	25,000 ltrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> <li>Pressurization of lift shaft</li> <li>Pressurization of lift lobby</li> <li>Communication in lift car</li> <li>Firemen's grounding switch</li> <li>Lift signage</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR




N/16

17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room / Reception			
	• Detector system panel	Required	Provided	MR
	• Flow switch panel	Required	Provided	MR
	• PA system panel	Required	Provided	MR
	• Battery backup	Required	Provided	MR
	• Building floor plans	Required	Provided	MR
20	Special Fire Protection Systems for Protection of Special Risks, if any:	N/A	N/A	N/A


The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required as per NBC Part IV, it is recommended to issue Fire Safety Certificate.

  
26/5/17

Signature of the Inspecting Officer  
Name :- V. B. Yadav  
Designation :- A.D.O (T.Pur)

DO(ED) - on leave  
DCFO (ND2)

  
26/5

174/CFDND  
29/5/17

C. F. P.

M-scull

FT for


29/5

As approved FT letter is put up for signatures please.

CFD (ND2)

M-scull

37/5

  
30/5/17