

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/ *school/2017/780*

Dated: *31/05/17*

FIRE SAFETY CERTIFICATE

Certified that the Happy English School at 2/10, Krishna Nagar, Delhi-110051, owned/occupied by Happy English School, comprised of ground plus three upper floors was issued NOC vide letter No.- F6/MS/DFS/2006/2537 dated-15/09/06. The school building was inspected by the officer concerned of this department on 27/04/2017 in the presence of Mr. S.S.Khungar (Manager) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular no.262-362 date 17/01/05 issued by Director of education and the school building is fit for occupancy class "B" 'Educational Building' for ground plus three upper floors with effect from *31/05/17*... for a period of **three** years, subject to conditions, printed overleaf.

Issued on.....*31/05/17*.....at New Delhi by

VK 19/5
(Vipin Kental)
Chief Fire Officer

To,
The Principal,
Happy English School,
2/10, Krishna Nagar, Delhi-110051.

Copy:-
The Dy. Director of Education,
B-Block, Yumna Vihar,
Delhi-110053.

1. Name & address of the building : Happy English School, F- 2/10, Krishna Nagar, Delhi-110051.
2. Building is comprised of : Ground plus three upper floors
3. Type of Occupancy : Educational
4. Type of Case : Renewal ✓
5. Details of Previous NOC letter : F6/MS/DFS/2006/2537 dated-15/09/06
6. Fire Safety direction letter No : Director of Education
7. Date of Inspection : 27/04/2017
8. Name of the Inspecting officers : ADO Om Parkash
9. Name and designation of Officer: from the building side : Mr. S.S.Khungar (Manager)
10. Year of Construction : 1990
11. Applicant's letter No : HESKN/16 Dated- 12/08/16

S.N	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	06mtr.	10 mtr.	MR
	• Gate width	4.5 mtr.	4.5 mtr.	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	01No.	02 No.	MR
	• Basement	N/A	N/A.	N/A
	B. Width of Staircases			
	• Upper Floor	1.50 mtr.	1 no.90m & II nd no.45m	MR(old accepted)
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	01 No.	01 No.	MR
	e. Width of Corridor	1.50mtr.	1.50mtr.	MR
	f. Door Size	01mtr.	01mtr.	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	8 nos.	8 nos.	MR
	• types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	01 No.	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided (Hooter)	MR
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	225 Lpm.	Provided	MR
	➤ Head of the Pump	40 M	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	5,000 Ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR

- N/19 -

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The inspection was carried out to check the shortcomings issued vide letter no. F.6/DFS/MS/School/2016/2860 dated 08/12/2016. The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules. The Fire Safety Certificate issued vide letter no. F6/MS/DFS/06/2537 dated 15/09/06 renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

Om Parkash
11/5/17

Signature of the Inspecting Officer

Name: Om Parkash

Designation: ADO

~~DO(ED)~~

Line
01/5

~~DCFO(ND2)~~

OA
2/5

(F.P.)

What about width of second stair case which should be atleast 0.75cm.

~~DCFO ND2~~

dh
2/5

W
2/5

~~DO(ED)~~

Sir,