

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/school/2017/NO2/758

Dated: 26/5/17

FIRE SAFETY CERTIFICATE

Certified that the Laxmi Public School located at X-20, Institutional Area Karkardooma, Delhi-110092 comprised of basement, stilt, ground plus three upper floors only owned/occupied by Laxmi Educational Society was issued NOC for old building block comprised of ground plus three upper floors vide letter No. F6/MS/DFS/2005/1383 dated 30/06/2005. The school was re-inspected by a team of officers of this department on 24/05/17 in the presence of Mr. Anil Kumar, treasurer of society and observed that the school have complied with the fire prevention and fire safety requirements in accordance with rules 33 of the Delhi Fire Service Rules, 2010 and found that the school building is fit for occupancy class "B" 'Educational Building' with effect from 26/5/17... for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on.....26/5/17.....at New Delhi by

26/5
(Vipin Kental)
Chief Fire Officer

To,
The Chairman,
M/s Laxmi Educational Society,
X-20, Institutional Area
Karkardooma,
Delhi-110092

Copy:-
The Dy. Director of Education,
419, Patparganj Industrial Area
Delhi-110092

o/c
He

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

K/1/4

1. Name & address of the building : Laxmi Public School,
X-20, Institutional Area Karkardooma, Delhi-110092
2. Building is comprised of : Old block (G+ 3) & new block(B + S + G + 3)
3. Type of Occupancy : Educational
4. Type of Case : New (Addition/Alteration)
5. Details of Previous NOC letter : F6/ MS/DFS/2005/ 1383 dt. 30/06/2005
for old block (G + 3)
6. Fire Safety directive letter No. : NBC part IV
7. Date of Inspection : 24/05/2017
8. Name of the Inspecting officers : Dy. CFO Sunil Chowdhary & ADO V. B. Yadav
9. Name and designation of Officer
from the building side : Mr. Anil Kumar (Treasurer)
10. Year of Construction : 2003 & 2017
11. Applicant's letter No : Letter No.nil Dt. 26/04/17

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> 06 mtr. 4.5 mtr. N/A 	<ul style="list-style-type: none"> 24 mtr. 4.5 mtr N/A 	<ul style="list-style-type: none"> MR MR N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper floor • Basement 	<ul style="list-style-type: none"> 04 nos. 02 nos. 	<ul style="list-style-type: none"> 04 nos. 02 nos. 	<ul style="list-style-type: none"> MR MR
	B. Width of Staircases			
	<ul style="list-style-type: none"> • Upper floor • Basement 	<ul style="list-style-type: none"> 1.50 mtr 1.50 mtr 	<ul style="list-style-type: none"> 1.50 mtr. each 1.50 mtr. each 	<ul style="list-style-type: none"> MR MR
	c. Protection of Exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<ul style="list-style-type: none"> N/A N/A 	<ul style="list-style-type: none"> N/A N/A 	<ul style="list-style-type: none"> N/A N/A
	d. No. of Continuous Staircases to Terrace	01 nos.	01 nos.	MA
	e. Width of Corridor	1.50 mtr.	02 mtr.	MR
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door (Basement) • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire dampers 	<ul style="list-style-type: none"> Required N/A N/A N/A N/A 	<ul style="list-style-type: none"> Provided N/A N/A N/A N/A 	<ul style="list-style-type: none"> MR N/A N/A N/A N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	<ul style="list-style-type: none"> Required N/A 	<ul style="list-style-type: none"> Exhaust Provided N/A 	<ul style="list-style-type: none"> MR N/A
05.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	<ul style="list-style-type: none"> 24 nos. ABC /CO₂ ISI marked 	<ul style="list-style-type: none"> 25 nos ABC & CO₂ Provided 	<ul style="list-style-type: none"> MR MR MR

6	First-Aid-Hose Reels.			
	Total numbers on each floor	02 nos.	02 nos.	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	05 mm	05 mm	MR
7	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
0	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
1	Internal Hydrants			
	• size of riser/down-comer	N/A	Provided	MR
	• Number of hydrants per floor	N/A	02 nos.	MR
	• Hose box	N/A	Provided	MR
2	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
3	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	900 LPM	900 LPM	MR
	• Head of the pump	40 M	40 M	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	N/A	N/A	N/A
	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	15,000 ltr	20,000 ltr	MR
	Exit Signage.	Required	Provided	MR

N/16

16	Provision of Lifts.	(Not installed)		
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

The School was issued NOC by this department vide letter No. F6/ MS/DFS/2005/ 1383 dt. 30/06/2005 for old building block comprised of ground plus three upper floors. The new block comprised of B+S+G+3 is constructed in 2017.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under NBC, it is recommended to issue Fire Safety Certificate.

Signature of the Inspecting Officer

Name :- V. B. Yadav

Designation :- A.D.O (T.Pur)

DO(ED) - one copy

DCFO (W/2)

[Handwritten Signature]
25/6