

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

No.F6/DFS/MS/EH/2017/

830

Dated :-----

09/06/17

FIRE SAFETY CERTIFICATE

Certified that the **Mc Donald Family Restaurant XV/8726-29, Khasra No. 863/11, Ground Floor & 1st floor, Plot No. 4, Block No. 5 D.B. Gupta Road, Pahar Ganj, New Delhi** comprised of **Basement, Ground + 4 Upper floor** was granted FSC by this department vide letter No.F6/DFS/MS/GH/2014/NDZ/604 dated **15/05/14** The premises was re-inspected by the officer concerned of this department on **23/05/17** in the presence of **Mr. Deepak (Manager)** and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Assembly Group D (Restaurant)** with effect from -----~~09/06/17~~--- for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, mentioned below.

Issued -----~~09/06/17~~---at New Delhi by.

V.K.
(Vipin Kental)
Chief Fire Officer
Delhi Fire Service
Ph-011-23412225

- Copy to:- (1) Medical Officer of Health,
NDMC,
Civic Centre, New Delhi.
- (2) The Manager,
Mc Donald Family Restaurant,
XV/8726-29, Khasra No. 863/11, Ground Floor & 1st floor,
Plot No. 4, Block No. 5 D.B. Gupta Road, Pahar Ganj, New Delhi.

Conditions:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. The means of escape shall be kept unobstructed / unlocked & remain available for speedy evacuation of occupants in case of an emergency
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

INSPECTION REPORT

1. Name & address of the building:- Mc Donald Family Restaurant XV/8726-29,
Khasra No. 863/11, Ground Floor & 1st floor,
Plot No. 4, Block No. 5, D.B. Gupta Road,
Pahar Ganj, New Delhi.
2. Type of occupancy:- Group – D Assembly Building Basement
Ground,+ 4 upper floor. (Restaurant at
Ground +1st floor)
3. Type of case:- Renewal
4. Details of previous NOC:- No. F6/DFS/MS/GH/2014/NDZ/604 dated
15/05/14.
5. Fire safety directives No.- N/A
6. Date of inspection:- 23/05/17
7. Name of the inspecting officer:- D.O. Gurmukh Singh
8. Name & designation of officer
From the building side:- Mr. Deepak (Manager)
9. Year of construction:- old existing building
10. Applicant's letter No:- Nil. dated 12/04/17

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing	Provided at site	Old Case Remarks MR/NMR
1.	Access to Building			
	1) Road width	9 mtr.	12 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors (mezzanine)	2 nos.	2 nos.	MR
	2. Basements	2 Nos	2 Nos	MR
	B. Width of staircase			
	1. Upper floors	1.5 mtr.	1.40 & 1.50 mtr.	MR
	2. Basements	1.00 mtr	1.00 & 1.40 mtr.	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	2 Mtr.	2.10 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			

X.7

	1) Basements	30 a/c per hour	Exhaust Fan	MR
	2) Upper floors (Ground fl.)	12 a/c per hour	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	10 Nos.	12 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	ISI	Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01	01	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Required	Provided	MR
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	100 mm	MR
	2) Number of hydrants per floor	01	01	MR
	3) Hose box	01	01	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level	N/A	N/A	N/A
	a) Discharge of pump	450 LPM	450 LPM	MRN/A
	b) Head of pump	30 mtr.	30 mtr.	MR

28

	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	10,000 ltrs	10,000 ltrs	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area			
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the restaurant were tested, checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No.F6/ DFS/MS/GH/2014/NDZ/604 dated 15/05/14 , renewal under rule35 of the Delhi Fire Service rules 2010, is recommended.

320102002
E(B) 17/8/16

Dy CRO (NDZ)

[Handwritten signature]
30/5

[Handwritten signature]
28/5/17

Gurmukh Singh
Divisional Officer.

[Handwritten marks]