

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

NO.F6/DFS/MS/School/2017/SZ/788

Dated: 02.06.2017

FIRE SAFETY CERTIFICATE

Certified that the Neo Great Mission Public School located Sector-5, Dwarka, New Delhi-110075, comprised of ground plus two upper floors was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2014/SZ/446 dated 4.4.2014. The premise was re-inspected by the officer concerned of this department on 4.4.2017 in presence of Smt. Kiran (Admn.) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of Education GNCT of Delhi, and that the building is fit for occupancy class B "Educational building" with effect from...02.06.2017... for a period of **three** years, in accordance with rule 36 unless renewed 37 or sooner cancelled under rule 40 subject to compliance of the conditions under rule 38 of the Delhi Fire Service, Rules 2010, printed overleaf.

Issued on02.06.2017... at New Delhi by

V.K. 17/6/17.
O/C (Vipin Kental)
Chief Fire Officer
Su

Copy to:-

1. The Dy. Director (Education), GNCT of Delhi, Old Secretariat, Delhi-110054.
2. The Principal, Great Mission Public School located at Sector-5, Dwarka, New Delhi-110075.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	Neo Great Mission Public School, Sector-5, Dwarka, New Delhi-110075	
2	Type of Occupancy	Educational Building "B"	
3	Type of case	Renewal (G+2)	
4	Details of previous NOC	F6/DFS/MS/School/2014/SZ/446 dated 4.04.2014	
5	Fire safety directives letter No	DOE Circular No. F-16/Estate/CC/Fire Safety/2011/3298 Dated 1.3.2011	
6	Date of inspection	20.05.2017	
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj	
8	Name and designation of officers from the building side	Mrs. Kiran (Admn.)	
9	Year of construction	2000	
10	Applicant's letter No.	FNGMPS/Fire/2017/111 dated 26.4.2017	Ground+2 upper floors

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/DOE letter dated 3.3.2011	Provided at site as per letter dated 4.4.2014	Remarks MR / NMR
1	Access to building			
	1) Road width	6 Mtrs.	9 Mtrs.	MR
	2) Gate width	5 Mtrs.	5 Mtrs.	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	2 Nos.	2 Nos.	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.5 Mtrs. & .75 Mtrs.	1.5 Mtrs. & .75 Mtrs.	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	One	one	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1 Mtr.	1 Mtr.	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement		N/A	N/A
	upper floors	12 a/c charge	Natural Vent.	MR
5	Fire Extinguishers			
	total numbers	6 Nos. Co2 OR ABC	6 Nos.	MR
	Types	ISI Marked	Co2 & ABC	MR
	ISI marking		Provided	MR

6	First-Aid Hose Reels.			
	total numbers on each floor	One	One	MR
	Length of Hose reel hose	30 m	30 m	M.
	Nozzle Diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	Provided	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	100 mm	N/A
	Number of Hydrants per floor	N/A	One	N/A
	hose Box	N/A	One	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450 Lpm.	450 & 180 LPM	MR
	b. head of the pump	40 Mtrs.	40 Mtrs.	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	MR
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	5000 Ltrs.	5000 Ltrs.	MR being old case
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

4/13

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: ABC Fire extinguisher provided near electric Panel.			MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety requirement as DOE Circular dated 1.3.2011, renewal of FSC issued vided letter no.F6/DFS/MS/School/2014/SZ/350 dated 21.3.2014 is recommended for ground plus two upper floors under rule 37 of the Delhi Fire Service Rules 2010.


Accordingly DFA is put up for approval and signature please.

S.P. Bhardwaj
27/5/17
S.P. Bhardwaj
ADO (Dwarka)

227/DO/SW
22/05/2017

DO SW
DO
22/5/17

DCFO (SZ)



DO SW
24/5

898/CF/SZ
26/5/17/18

CF/SZ m.s cell. FT/10.
26/5

FT is put up for signature please.

CF/SZ
m-s cell
17/6/17

S.P. Bhardwaj
31/5/17