

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F-6/DFS/MS/SCHOOL/WZ/2017/ 778

Dated: 30/05/2017

FIRE SAFETY CERTIFICATE

Certified that the **S.D.M.C. Primary School**, Located at **B-Block Chand Nagar, New Delhi-110018**. comprised of Three Block (connecting to each other) (Ground + 01 Upper Floors) owned/occupied by **S.D.M.C. Primary School** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 18-05-2017 in the presence of **Mr. Prabhu Dayal (Incharge)** and that the building/premises is fit for occupancy "Educational" Group B (**Except Multi activity Hall**) with effect from 30.05/17. for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.



(Atul Garg)
Chief Fire Officer,
Delhi Fire Service

Copy to:

The Principal
S.D.M.C. Primary School, B-Block Chand Nagar, New Delhi-110018

Following fire safety directives must be adhered to:-

- 1) All the means of escape shall be kept free of all type of obstruction all the time.
- 2) All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
- 3) All the fire fighting equipment shall be maintained in perfect working condition all the time and lapse rendering non-functional of fire safety measures, management shall be responsible.
- 4) Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
- 5) Basement shall be used as per NBC.
- 6) Multi activity hall shall not be used for school activity.
- 7) This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
- 8) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
- 9) "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

1. Name & address of the building: **S.D.M.C. Primary School, Located at B-Block Chand Nagar, New Delhi-110018.**

1. Type of Occupancy : Educational three Block(connecting to each other)
(Ground +1 Upper Floor)
2. Type of Case : New
3. Details of previous NOC : New case
4. Fire Safety directives Letter No. : DOE 3298-3398 dated 1-3-11
5. Date of inspection : 18/05/2017
6. Name of the Inspecting Officer : Udai vir Singh, ADO (WP)
7. Name and designation of Officer
from the building side : ~~Mr.~~ Prabhu Dayal (Incharge)
8. Year of Construction : 2009
9. Applicant's letter No. : SDMCPS/2017/05 Dated- 18-04-2017

No. of Students=415
No. of class rooms=34
Plot area= 5663.34sq.m
Covered area=2007.6sqm

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE 3298-3398 dated 1-3-11	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	7m Provided	MR
	• Gate width	Accessible	388cm Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	3	3	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m	1x150, 1x165, 1x180cm	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1.5m	220cm Provided	MR
	f. Door Size	1 mtr	110cm(Double Door)	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	8 nos.	9 Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	NR	NR	NA

	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Under ground tank capacity Draw off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15	Exit Signage	NA	NA	NA
16.	Provision of Lifts			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of lift lobby Communication in lift Car Fireman's Grounding Switch 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers

..... Nil

Note: - Multiactivity Hall do not meet with exit requirements & shall not be used for school activity.

~~W~~
Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name Uday Vir Singh

Name

Designation ADO/WP

Designation

~~D/W~~ 10/5/17

~~W~~ (W2)
CFO West 20/5/17

~~W~~ 19/5/17

PT PL

~~AOD/W~~

Sir FP is put up for sign ple.

~~CFO~~ 21/5/17

~~W~~ 28/5/17