

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO. F6/DFS/MS/School/2017/SZ /797

Dated: 05/06/2017

FIRE SAFETY CERTIFICATE

Certified that the Shri Ram Public School located at Village Bamnoli, New Delhi, comprised of ground plus two upper floors was granted NOC by this department vide letter No. F6/DFS/MS/2009/1796 dated 18.6.2009. The said premises was re-inspected by the officer concerned of this department on 30.5.2017 in presence of Sh. Naresh Kumar (Principal) and found that the premises have deemed complied with fire prevention and fire safety requirements in accordance Directorate of Education circular No. 262-362 dated 17.01.2005, and that the school building is fit for occupancy class B "Educational building" for ground plus two upper floors with effect from 05/06/17 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed overleaf.

Issued on 05/06/2017 at New Delhi by

W
5/6/17
OK (Vipin Kental)
Chief Fire Officer
SOY

Copy to:-

1. The Deputy Director (Education), Govt. of NCT of Delhi, Old Secretariat, New Delhi-54.
2. Principal, Shri Ram Public School, Village Bamnoli, New Delhi.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

1	Name & address of the building	Shri Ram Public School, Village Bamnoli, New Delhi.	
2	Type of Occupancy	Educational Building "B"	
3	Type of case	Renewal (G+2)	
4	Details of previous NOC	F6/DFS/MS/2009/1796 dated 18.06.2009	
5	Fire safety directives letter No	DOE Circular No. 262-263 dated 17.1.2005	
6	Date of inspection	30.05.2017	
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj	
8	Name and designation of officers from the building side	Sh. Naresh Kumar (Principal)	
9	Year of construction	2009	
10	Applicant's letter No.	SRPS/1199/2017 dated 5.5.2017	Ground+2 upper floor

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/DOE CIR. dated 17.1.2005/ letter dated 18.6.2009	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	6 Mtrs.	6 Mtrs.	MR
	2) Gate width	6 Mtrs.	6 Mtrs.	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	2 Nos.	2 Nos.	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.25 Mtrs. each	1.25 Mtrs. each	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Two	Two	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1 Mtr.	1 Mtr.	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	N/A	N/A	N/A
		12 a/c charge		
	upper floors		Natural Vent.	MR
5	Fire Extinguishers			
	total numbers	8 Nos. Co2 & ABC	8 Nos.	MR
	Types	ISI Marked	Co2 & ABC	MR
	ISI marking		Provided	MR

6	First-Aid Hose Reels.			
	total numbers on each floor	One	One	MR
	Length of Hose reel hose	30 m	30 m	MR
	Nozzle Diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	100 mm	100 mm	MR
	Number of Hydrants per floor	One	One	MR
	hose Box	One at each floor	One at each floor	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450 & 180 Lpm.	450 & 180 LPM	MR
	b. head of the pump	40 Mtrs.	40 Mtrs.	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	MR
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	5000 Ltrs.	5000 Ltrs.	MR being
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

N/A

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: CO2 Fire extinguisher provided near electric Panel.	MR		

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety requirement as per DOE Circular dated 17.1.2005, renewal of FSC issued vided letter no.F6/DFS/MS/2009/1796 dated 18.6.2009 is recommended for ground plus two upper floors under rule 37 of the Delhi Fire Service Act 2007 & Rules 2010. Accordingly DFA is put up for approval and signature please.

Suy
30/5/17
S.P. Bhardwaj
ADO (Dwarka)

~~DOSW~~

[Signature]
31/5/17

DCFO (S2)

[Signature]
31/5

397/00/SW
31/05/2017



CFD (S2) m.s cell FT M.
1/6

FT is put up for signature please.

CFD S2 m-s cell *[Signature]*
5/6/17