

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001
Fax No. 011-23412593, Ph. 011-23412225

No. F6/DFS/MS/School/2017/SZ/ 798

Dated: 06/06/2017

FIRE SAFETY CERTIFICATE

Certified that the Zayed Public School for Girls, located at B-112, Kalindi Kunj Road, Street No-7, Saheen Bagh, Jamia Nagar, Okhla, New Delhi-110025, comprised of basement, ground plus three upper floors Owned/Occupied by Zayed Public School for Girls was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2012/982 dated 19/03/2012. The premises was re-inspected by officer concerned of this department on 22.05.2017 in the presence of Mr. Mohd Ilyas (Manager) of the school and found that school have deemed complied with the fire prevention and fire safety arrangements in accordance with Directorate of Education circular No. F.16/Fire Safety/2011/13298 to 3398 dated 01.03.2011 issued by Director of Education and the building/premises is fit for occupancy class "Educational Building Group-B" with effect from 06/06/2017 of the issue of this certificate for a period of Three years subject to conditions as mentioned below.

Issued on 06/06/2017 at New Delhi by

Vipin Kental
Chief Fire Officer

Copy to: -

1. The Manager, Zayed Public School for Girls, B-112, Kalindi Kunj Road, Street No-7, Saheen Bagh, Jamia Nagar, Okhla, New Delhi-110025,
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye Laws.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT				
1	Name & Address of the Building	Zayed Public School, B-112, Kalindi Kunj Road, Street No-7, Saheen Bagh, Jamia Nagar Okhla, New Delhi-62		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Basement, Ground + Three upper floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2012/982 dated 19/03/2012		
6	Fire Safety Directives Letter No	F.16/Fire Safety/2011/13298 to 3398 dated 01.03.2011		
7	Date of Inspection	22-05-2017		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mr. Mohd. Ilyas (Manager)		
10	Year of construction	2003		
11	Applicant letter No.	Nil Dt. 06/05/2017		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	As per Old Noc 2012	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Accessible	12 mtr	MR
	• Gate width	N/A	5.2 mtr	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, width, type & arrangement of exits			
	a. Number of Staircase			
	➤ Upper floors	Two	02 staircase	MR
	➤ Basement floor	Two	01 staircase & 01 ramp	MR
	b. Width of Staircase			
	➤ Upper floors	1.5m/0.75m	1.50mtr & 1.40 mtr	MR
	➤ Basement floor	1.5 m/0.75m	1.50m & 3.70 mtr ramp	MR
	c. Protection of exits			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	One	One	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1m	Provided	MR
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4.	Smoke Management system.			
	• Basement	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers.			
	• Total numbers	14 No's	16 No's	MR
	• Types	ISI Marked	ABC-16	MR
	• ISI Marking		Yes	MR

6.	First Aid Hose Reels.			
	• Total numbers on each floor.	01 No	Provided	MR
	• Length of hose-reel hose.	30 m	Provided	MR
	• Nozzle Diameter	5 mm	Provided	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8.	MOEFA / Siren	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basement.	Required	Provided	MR
	• Upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants.			
	• Size of Riser/Down-comer	N/A	N/A	N/A
	• Number of Hydrant per floor	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
12.	Yard Hydrants.			
	• Total number of hydrants.	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
13.	Pumping arrangements.			
	a) Ground Level			
	➤ Discharge of main pump.	N/A	N/A	N/A
	➤ Head of main pump.	N/A	N/A	N/A
	➤ Number of main pumps.	N/A	N/A	N/A
	➤ Jockey Pump output.	N/A	N/A	N/A
	➤ Jockey Pump head.	N/A	N/A	N/A
	➤ Standby Pump output.	N/A	N/A	N/A
	➤ Standby Pump head.	N/A	N/A	N/A
	➤ Auto Starting / Manual Stopping.	N/A	N/A	N/A
	➤ Pump house access.	N/A	N/A	N/A
	b) Terrace Level			
	➤ Discharge of pump.	450 LPM & 180 Lpm	Provided	MR
	➤ Head of pump.	Required	40 mtr	MR
	➤ Power supply.	N/A	N/A	N/A
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for Fire Fighting.			
	• Underground tank capacity.	N/A	N/A	N/A
	➤ Draw-off connection.	N/A	N/A	N/A
	➤ Fire Service Inlet.	N/A	N/A	N/A
	➤ Access to tank.	N/A	N/A	N/A
	• Overhead tank capacity.	5,000 Ltr	5,000 Ltr	MR
15.	Exit Signage.	Required	Provided	MR

16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of lift shaft. • Pressurization of lift lobby. • Communication in lift car. • Fireman's switch. • Lift signage. 	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18.	Refuge Area			
	<ul style="list-style-type: none"> • Total area • Location 	N/A	N/A	N/A
19.	Fire Control Room.			
	<ul style="list-style-type: none"> • Detector System Panel. • Flow Switch Panel. • PA system Panel. • Battery backup • Building floor plan 	N/A	N/A	N/A
20.	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A

The Fire Protection system provided in the building were checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/DFS/MS/School/2012/982 dated 19.03.2012, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended

Accordingly DFA is put up for approval and signature please.

R.N. Singh
23/5/17

Signature of the Inspecting Officer
Name : R.N. Singh
Designation: ADO

D. O. (SD)

R.N. Singh
23/5/17

960/cfsc
26/5/17

CF (S2)

M. Scell
24/5

FT/10.

CF (S2)

M. Scell

U
26/5

FT letter is put up for sign. *R.N. Singh*
01/6

CF (S2)
M. Scell *U*
5/6/17.

