

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F.6/DFS/MS/2017 / *School/876*

Dated: *19/06* /2017

FIRE SAFETY CERTIFICATE

Certified that **Sachdeva Public School, Sector-13, Rohini, Delhi-110085** comprised of **Basement + Ground + 3 upper floor** owned/occupied by **Sachdeva Public School** has already been issued fire safety certificate vide letter no **F.6/DFS/MS/2014/School/WZ/467 dated 11/04/2014** The premises was re-inspected by the officer from this department on dated **06/06/2017** in the presence of **Dr. (Mrs.) Rajeev Prakash (Principal)** and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of NBC Part-IV and the building / premise is fit for occupancy of **Group Class B (Educational)** with effect from / /2017 for a period of **three years**, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on *19/06/17* at New Delhi by

(Signature)
(Atul Garg)

Chief Fire Officer
Ph: 011-23414250

(Signature)

Copy to:

1. The Principal, Sachdeva Public School, Sector-13, Rohini, Delhi-110085
2. The Director of Education, Old Secretariat, Delhi.

INSPECTION REPORT

1. Name & address of the building : Sachdeva Public School, Sector-13, Rohini, Delhi-110085
2. Type of Occupancy : Educational (B + G + Three upper floor)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/2014/School/WZ/467 dated 11/04/2014
5. Fire Safety directives letter No : NBC Part-IV
6. Date of inspection : 06/06/2017
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers
from the building side : Dr. (Mrs.) Rajeev Prakash (Principal)
9. Year of Construction : 1992 & 1999
10. Applicant's letter No. : SPS(R)/ADMN/FIRESAFETY/2017 dated 06/04/2017

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 mtr	6 mtr	M/R
	• Gate width	4.5 mtr	4.5 mtr	M/R
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	03	03	M/R
	• Basements	03	03	M/R
	b. Width of staircases			
	• Upper Floors	1.5 mtr	1.5 x 1, 1.25 x 2	M/R
	• Basements	1.5 mtr	1.5 x 1, 1.25 x 2	M/R
	c. Protection of exits		& one ramp	
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	1 mtr	1 mtr	M/R

R

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	N/A	N/A
		12 a/c per hour	N/A	N/A
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	Required	45	M/R
			ABC -30 CO2-15	M/R
		ISI marked	Yes	M/R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	Required	Provided	M/R
		30 m	Provided	M/R
		5 mm	Provided	M/R
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8	MOEFA	Required	Provided	M/R
9	Public Address System.	Required	Provided	M/R
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	Required	Provided	M/R
		N/A	N/A	N/A
		N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	4"	Provided	M/R
		04	Provided	M/R
		04	Provided	M/R

12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	180 LPM	2 x 180 LPM	M/R
	➤ Jockey pump head	40 M	Provided	M/R
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	Required	Provided	M/R
	➤ Pump House Access	Required	Provided	M/R
	• Terrace level			
	➤ Discharge of pump	900 LPM	02 x 900 LPM	M/R
	➤ Head of the pump	40 Mtr	Provided	M/R
	➤ Power Supply	Required	Provided	M/R
	➤ Auto Starting of pump	Required	Provided	M/R
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N/A	60,000 Ltrs	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10000 ltr	10000 ltr	M/R
15	Exit Signage.	Required	Provided	M/R
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A

18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/2014/School/WZ/467 dated 11/04/2014 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Handwritten signature
9/6/17

Signature of the Inspecting Officer

Name

Handwritten name: Rajesh Kumar

Designation

Handwritten designation: ADO/RN

DO/MSD

8 Singh

9.6.17

Dy CPO (WZ)

Handwritten signature
14/6/17

CFO West

18/06/17

f T P S

ADY RN

Sir, F.T. letter is put up for your kind perusal and signature please

Handwritten signature
16/6/17

Handwritten name: Rajesh Kumar
Handwritten designation: ADO/FPW

Handwritten signature
16/6/17