

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2017 / *1105/2017/874*

Dated: *19/06/2017*


FIRE SAFETY CERTIFICATE

Certified that **Jaipur Golden Hospital** located at **Sector-3, Rohini, Delhi-110085** comprised of four blocks i.e. Block- A- B+G+1, Block-B & C – B+G+3, Block-D – B+G+5 inter connected with each other owned/ occupied by **Jaipur Golden Hospital** was issued FSC vide this office letter no **F6/DFS/MS/Hospital/2014/WZ/508** dated **24.04.2014**. The premise was re- inspected by the officer concerned of this department on **08.06.2017** in the presence of **Mr Manoj Malik, Fire Officer** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premise have therefore, deemed complied with the requirement under rule 33 of the Delhi Fire Service Rules, 2010 and the building/ premise is fit for occupancy class Institutional "Group C" with effect from*19/06/17*.... for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on*19/06/17*..... at New Delhi



(Atul Garg)
Chief Fire Officer
Ph:-011-23414250

Copy to :

Dr. D.P. Saraswat, Medical Superintendent,
Jaipur Golden Hospital, Sec-03, Rohini, Delhi

INSPECTION REPORT

Block-A-B+G+1, Block-B&C- B+G+3, Block-D-B+G+5

1. Name & address of the building : Jaipur Golden Hospital, Sector – 03, Rohini,
2. Type of Occupancy : **Hospital**
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/Hospital/2014/WZ/508 dated 24/04/2014
5. Fire Safety directives letter No :
6. Date of inspection : 08/06/2017
7. Name of the Inspecting Officers : Dy.CFO(WZ) & DO (NW) & ADO (RN)
8. Name and designation of officers
from the building side : Mr. Manoj Malik (Fire Officer)
9. Year of Construction : 1990 & 1999
10. Applicant's letter No. : JGH/ADMIN/FIRE/2017/2489 dated 23/05/2017.

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none">• Road width	09 mtr	09 mtr	M/R
	<ul style="list-style-type: none">• Gate width	05 mtr	Provided	M/R
	<ul style="list-style-type: none">• Width of internal road	06 mtr	06 mtr	M/R
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none">• Upper Floors	07	07	M/R
	<ul style="list-style-type: none">• Basements	07	07	M/R
	b. Width of staircases			
	<ul style="list-style-type: none">• Upper Floors	2 mtr X 3, & 4 SC 1 mtr	03 SC 2 mtr & 04 SC 1 mtr	M/R
	<ul style="list-style-type: none">• Basements	2 mtr X 3, 4 SC 1 mtr	03 SC 2 mtr & 04 SC 1 mtr	M/R
	c. Protection of exits			
	<ul style="list-style-type: none">• Fire check door	Required	Provided	M/R
	<ul style="list-style-type: none">• Pressurization	N.A	Provided	N.A
	e. No. of continuous staircases to terrace	03	07	M/R
	g. Width of Corridor			
	h. Door Size	2 mtr	2 mtr	M/R

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Required	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	Provided GF	M/R
		12 a/c per hour	Provided GF	M/R
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	Water Co2 09 ltr Co2 type 4.5 kg DCP type ISI marked	188	M/R
			Yes	M/R
			Yes	M/R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	5 no's	Provided	M/R
		30 m	Provided	M/R
		5 mm	Provided	M/R
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	Required	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
		Comman area	Provided	M/R
8	MOEFA	Required	Provided	M/R
9	Public Address System.	Required	Provided	M/R
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	Required	Provided	M/R
		Required	Provided	M/R
		N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	100 mm	Provided	M/R
		05 no.	Provided	M/R
		05 no.	Provided	M/R

12	Yard Hydrants.			
	• Total number of hydrants	Required	Provided	M/R
	• Hose Box	Required	Provided	M/R
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	2400 LPM	Provided	M/R
	➤ Head of Main pump	70 M	Provided	M/R
	➤ Number of main pumps	2 electric 1 stand by 0 jockey	Provided	M/R
	➤ Jockey Pump out put	180 LPM	Provided	M/R
	➤ Jockey pump head	70 M	Provided	M/R
	➤ Standby Pump out put	2400 LPM	Provided	M/R
	➤ Standby Pump Head	70 M	Provided	M/R
	➤ Auto Starting/ Manual stopping	Required	Provided	M/R
	➤ Pump House Access	Required	Provided	M/R
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power Supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	3,00,000 ltrs	3,00,000 ltrs	M/R
	➤ Draw-off connection	Required	Provided	M/R
	➤ Fire service inlet	Required	Provided	M/R
	➤ Access to tank	Required	Provided	M/R
	• Overhead Tank capacity	20,000 ltr	20,000 ltr	M/R
15	Exit Signage.	Required	Provided	M/R
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	Required	Provided GF	M/R
	• Pressurization of Lift lobby	N/A	Provided	M/R
	• Communication In lift Car	Required	Provided	M/R
	• Fireman's Grounding Switch	Required	Provided	M/R
	• Lift Signage	Required	Provided	M/R
17	Standby power supply	Required	Provided	M/R

18	Refuge Area.			
	➤ Total Area	Required	Provided	M/R
	➤ Location	4 th floor	Provided	M/R
19	Fire Control Room			
	• Detector System Panel	Required	Provided	M/R
	• Flow Switch Panel	Required	Provided	M/R
	• PA System Panel	Required	Provided	M/R
	• Batter backup	Required	Provided	M/R
	• Building Floor Plans	Required	Provided	M/R
20	Special Fire Protection Systems for Protection of special Risks, if any:		No special risk at present	

The fire protection systems provided in the building were test checked and found functional at the time of inspection. The management have complied all observations communicated vide letter no 1277 dated 19/05/2017.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/Hospital/2014/WZ/508 dated 24/04/2014 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

[Signature]
Dy. CFO (WZ)

[Signature]
DO (NWD)

[Signature]
ADO (RN)

[Signature]
16/06/17

fi P/s