

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2017 / *School/871*

Dated: *19/06/2017*

FIRE SAFETY CERTIFICATE

Certified that the Govt. Sr. Sec. School, Sector-22, Phase-III, Rohini, Delhi-110085 comprised of basement, ground and three upper floors owned/ occupied by the Govt. Sr. Sec. School have complied with the fire prevention and safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 02.06.2017 in the presence of Sh.Harbansh Sikri, Contractor and that the building/premises is fit for occupancy Class "Group B Educational" with effect from*19.06.17* for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on*19/6/17*..... at New Delhi

(Signature)
(Atul Garg)

Chief Fire Officer

Ph:-011-23414250

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.
2. The Principal, Govt. Sr. Sec. School, Sector- 22, Phase-III, Rohini, Delhi-110085
3. The Assistant Engineer, PWD Sub Division-1, NWEMD FSL Building, Sec-14, Rohini, Delhi.

DL
Copy

INSPECTION REPORT

1. Name & address of the building : Govt. Sr. Sec. School, Sector -22, Phase-III, Rohini , Delhi-110085.
2. Type of Occupancy : Educational
3. Type of Case : New Case (Basement, Ground + 03 upper floors)
4. Details of previous NOC : --
5. Fire Safety directives letter No : NBC Part-4
6. Date of inspection : 02/06/2017
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers
from the building side : Sh. Harbansh Sikri , Contractor
9. Year of Construction : 2017
10. Applicant's letter No. : No.12(2)/PWD Sub-Div.-2/2017-18/23 dated: 27.04.2017

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	18m	MR
	• Gate width	4.5m	6m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	03	03	MR
	• Basements	02 & 02 Ramp	02 & 02 Ramp	MR
	b. Width of staircases			
	• Upper Floors	1.50m	1.90m each	MR
	• Basements	2m	02m each & 02 ramp -2meach	MR
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02	03	MR
	e. Width of Corridor	Required	Provided	MR
f. Door Size	1 m	1.10m	MR	
3	Compartmentation.			
	• Fire check door	NA	NA	NA

	<ul style="list-style-type: none"> Hose Box 	NA	02	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NA	450 lpm	NA
		NA	40m	NA
		N/A	N/A	N/A
		NA	NA	NA
		NA	NA	NA
		N/A	N/A	N/A
		N/A	N/A	N/A
		900lpm	450 lpm x 02	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	100,000 ltr.	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		15,000 ltr	20,000 ltr.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			

	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition, at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standard on fire prevention and fire safety requirements as stipulated under NBC Part 4, it is recommended to issue Fire Safety Certificate.

[Handwritten Signature]
8/6/17

Signature of the Inspecting Officer
Name :- Rajesh Kumar
Designation:- ADO/RN

DO/NWD
Singh
9.6.17
DYCEO (N2)
cto west
13/06/17
AT P/S

[Handwritten Signature]
14/6/17