

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

Fax No. 011-23412593, Ph. 011-23412225

No. F6/DFS/MS/EH/2017/SZ/ 861

Dated: ...15/06/17

FIRE SAFETY CERTIFICATE

Certified that the **Barat Ghar at S.L. House** located at **Plot No-215/70/2/1, Sarai Sahuji, Maharishi Dayanand Marg, Malviya Nagar, New Delhi**, comprised of Stilt, Ground plus One upper floor was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/EH/2014/SZ/768 dated 23/06/2014. The building was re-inspected by the officer concerned of this department on 03/06/2017 in the presence of Mr. Amit Bansal (Manager) of the society and observed that the said building/premises used Stilt as Parking, GF- Barat Ghar, FF-19 rooms, have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Assembly**" (**Barat Ghar**) as above with effect from date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 15/6/17 at New Delhi by

15/6/17
(Vipin Kental)
Chief Fire Officer

Copy to: -

1. Shri Sukhan Lal Memorial Charitable Society (Regd.), Barat Ghar at S.L. Hose, Plot No. 215/70/2/1, Sarai Sahuji, Maharishi Dayanand Marg, Malviya Nagar, New Delhi-110017
2. The DHO (SZ), South MCD, Public Health Deptt., Green Park, New Delhi-110016

Conditions for the validity of Fire Safety Certificate


1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye Laws.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT


1	Name & Address of the Building	Barat Ghar at S.L. House, Kh. No. 215/70/2/1, Sarai Shahji, Malviya Nagar Road, New Delhi-17 (Sukhan Lal Memorial Charitable Society)		
2	Type of Occupancy	Assembly Building, Group-D (Barat Ghar)		
3	Building comprised of	Stilt, Ground + One upper floor.		
4	Type of Case	Renewal		
5	Details of Previous NOC	No.F6/DFS/MS/EH/2014/SZ/768 Dated 23-06-2014		
6	Fire Safety Directives Letter No	F.6/DFS/MS/EH/2005/718 dated 04.04.2005		
7	Date of Inspection	03-06-2017		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mr. Amit Bansal (Manager)		
10	Year of construction	1991-92		
11	Applicant letter No.	Nil Dated 27/02/2017		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Dt. 30-12-2011 requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Required	6 mtr	MR
	• Gate width	Required	4.5 mtr	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, width, type & arrangement of exits			
	a. Number of Staircase			
	• Upper floors	2 No's	3 No's	MR
	• Basement floor	N/A	N/A	N/A
	b. Width of Staircase			
	• Upper floors	Required	1.25m, 1.15m. & 1.5m (Iron)	MR
	• Basement floor	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Required	Two	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	2 m	2m × 4	MR
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4.	Smoke Management system.			
	• Basement	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	N/A	N/A
5.	Fire Extinguishers.			
	• Total numbers	ISI marked	15 No's	MR
	• Types		ABC-10 & Co2-05	MR
	• ISI Marking		Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	Hose Reels	One	MR
	• Length of hose-reel hose.		30 m	MR
	• Nozzle Diameter		5 mm	MR

7. Automatic fire detection & alarming system.				
	• Type of detectors	N/A	Provided smoke type	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	DG Set	N/A
	• Hooter's location	N/A	Every floor	N/A
8.	MOEFA	Required	Provided	M/R
9.	Public Address System	Required	Provided	M/R
10. Automatic Sprinkler System				
	• Basement	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11. Internal Hydrants.				
	• Size of Riser/Down-comer	N/A	100 mm	N/A
	• Number of Hydrant per floor	N/A	One	N/A
	• Hose box.	N/A	One	N/A
12. Yard Hydrants.				
	• Total number of hydrants.	N/A	Provided	N/A
	• Hose box.	N/A	Provided	N/A
13. Pumping arrangements.				
	• Ground Level			
	➤ Discharge of main pump.	N/A	1620 LPM	N/A
	➤ Head of main pump.	N/A	70 m	N/A
	➤ Number of main pumps.	N/A	One	N/A
	➤ Jockey Pump output.	N/A	180 LPM	N/A
	➤ Jockey Pump head.	N/A	70 m	N/A
	➤ Standby Pump output.	N/A	N/A	N/A
	➤ Standby Pump head.	N/A	N/A	N/A
	➤ Auto Starting / Manual Stopping.	N/A	N/A	N/A
	➤ Access to pump house	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump.	450 LPM	900 LPM	MR
	➤ Head of pump.	39 mtr	40 m	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14. Captive water storage for Fire Fighting.				
	• Underground tank capacity.	N/A	2,00,000 Ltr	N/A
	➤ Draw-off connection.	N/A	N/A	N/A
	➤ Fire Service Inlet.	N/A	N/A	N/A
	➤ Access to tank.	N/A	N/A	N/A
	• Overhead tank capacity.	5,000 Ltr	20,000 Ltr.	M/R
15.	Exit Signage.	Required	Provided	M/R
16. Provision of Lifts.				
	• Pressurization of lift shaft.	N/A	N/A	N/A
	• Pressurization of lift lobby.	N/A	N/A	N/A
	• Communication in lift car.	Required	Provided	MR
	• Fireman's switch.	Required	Provided	MR
	• Lift signage.	Required	Provided	MR
17	Standby Power Supply	Required	Provided (DG Set)	MR
18. Refuge Area				
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A


N/12

19.	Fire Control Room.			
	• Detector System Panel.	N/A	N/A	N/A
	• Flow Switch Panel.	N/A	N/A	N/A
	• PA system Panel.	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for the Protection of special Risk, if any :			N/A
<p>The Fire protection systems provided in the building were tested/ checked and found functional at the time of inspection.</p> <p>Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/DFS/MS/EH2014/SZ/768 dated 23-06-2014, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.</p> <p>Accordingly, DFA is put up for approval and signature please.</p> <p style="text-align: right;"> Signature of the Inspecting Officer Name : R.N. Singh Designation: A.D.O.</p>				


Div. Officer (SD)


8/6/17

942/452
12/6/17/15/16


Dy. ofd (SD)





m. seel

F7 100.

UK
12/6