

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001

No. F.6/DFS/MS/Assembly/SZ/2017/898

Dated: 22.06.2017

FIRE SAFETY CERTIFICATE

Certified that Auditorium (Vasuki) Lok Kala Manch, located at Plot No. 20, Institutional Area, Lodhi Road, New Delhi-110003 comprised of Basement, Ground, Mezzanine & First floor but the auditorium is running at Ground & Mezzanine Floor only was granted FSC by this department vide letter No. F6/DFS/MS/2014/SZ/234 dated 14/02/2014. The premises was re-inspected by the officer concerned of this department on 30/05/2017 in the presence of Mr. Mariappan (Manager) and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No. F.16/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/2011 and that the premises fit for occupancy class "Assembly Building, Group-D" with effect from ~~22.06.2017~~ 22.06.2017 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010.

Issued on. 22.06.2017 at New Delhi by


(Vipin Kental)
Chief Fire Officer
Ph.: 011-23412225

Copy to:-

1. Ms. Hema Ramaswami (President), Auditorium (Vasuki) Lok Kala Manch, located at Plot No. 20, Institutional Area, Lodhi Road, New Delhi-110003.
2. The Joint Commissioner of Police (Lic.), First Floor, P.S. Defence Colony, New Delhi-110049.

Conditions for the validity of fire safety certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1. Name & address of the building: Auditorium (Vasuki) located at Lok Kala Manch, Plot No.20, Institutional Area, Lodhi Road, New Delhi-110003.
2. Type of Occupancy : Group D Assembly Building
3. Type of Case : Renewal **[Basement, Ground, Mezzanine & First floor]**
4. Details of Previous NOC : F6/DFS/MS/2014/SZ/234 dated 14/02/2014
5. Fire Safety directives letter No : F6/DFS/MS/BP/88/708 dated 25/05/1988
6. Date of inspection : 30/05/2017
7. Name of Inspecting Officers : A.K. Malik
8. Name and designation of officers
From the building side : Mr. Mariappan (Manager)
9. Year of Construction : 1988
10. Applicant's letter No. : Nil dated 04/05/2017, outdoor diary no. 6230 dated 04/05/2017

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	9m 5m NA	Provided 3.5m NA	MR MR (old case) NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	One Two	Provided Provided	MR MR
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	1.2m 1.2m & 0.75m	Provided Provided	MR MR
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA NA	NA NA	NA NA
	d. No. of continuous staircases to terrace	Required	1 No.	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	2m	GF:One of 1m & Two of 0.9m Mezzanine Floor: One of 1.25m	MR (old case)
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 ACPH 12 ACPH	Exhaust Fan M.V.S.	MR MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	10 No's ABC/W. CO ₂ /CO ₂ ISI marked	28 No's 4/4/2- Nos Yes	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	2 at GF & 1 on Upper Floors 30 m 5 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power 	NA NA NA NA	Provided Ground Floor NA Provided	NA NA NA NA

	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	NA	Provided	NA
		NA	Provided	NA
		NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	Provided	NA
		NA	Provided	NA
		NA	Provided	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		900 LPM	2 Nos of 900 LPM	MR
		35 M	40m & 35m	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	25,000 Lts	Provided	MR
		NA	NA	NA
		NA	NA	NA
		Required	Provided	MR
		10,000 Lts	10,000 Lts	MR
		Required	Provided	MR
15.	Exit Signage.			
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		Required	Provided	MR
17.	Standby power supply			
18.	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	NA	NA	NA
		NA	NA	NA
19.	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Batter backup Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:			
		NA	NA	NA

The fire protection systems provided in the building were randomly tested, checked and found

- N/21 -

Auditorium (Vasuki) located at Lok Kala Manch, Plot No.20,, Institutional Area, Lodhi Road, New Delhi-110003
Keeping in view of the above substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.
Accordingly DFA is put up for approval.

Amitabh
31/5/17

Signature of Inspecting Officer
Name:- A.K. Malik
Designation:-DO (SD)

Dy. CFO(SZ)

22/5

21/5

~~22/5~~
21/5

DCFO/SZ

what is present use of mezanine floor.

22/5/17

21/5/17

22/5

21/5

