

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/School/2017/ 897

Dated: 22.06.2017

FIRE SAFETY CERTIFICATE

Certified that the Evergreen Sr. Sec. School located at Vasundhara Enclave, Delhi-110096, comprised of ground plus three upper floors only owned/occupied by Evergreen Sr. Sec. School was issued FSC vide letter no. F6/DFS/MS/School/2014/NDZ/104 dated 27/01/2014. The school building was re-inspected by the officer concerned of this department on 10/06/2017 in the presence of Mr. Jitender, Purchase Manager of the school and observed that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular Letter No. 262- 362 dated 17/01/2005 issued by Director of Education and the school building is fit for occupancy class 'B' 'Educational Building' for ground plus three upper floors with effect from 22.06.2017 for a period of **three** years, subject to conditions, printed overleaf.

Issued on 22.06.2017 at New Delhi by


(Vipin Kental)
Chief Fire Officer



To,
The Principal
Evergreen Sr. Sec. School,
Vasundhara Enclave,
Delhi-110096,

Copy:-
The Dy. Director of Education,
D- Block, Anand Vihar
Delhi

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

1. Name & address of the building : Evergreen Public School,
Vasundhara Enclave, Delhi-96
2. Building is comprised of : Ground plus three upper floors
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F6/DFS/MS/School/2014/NDZ/104 Dt 27/01/14
6. Fire Safety directive letter No. : Circular No. 262-362 dated 17/01/2005
7. Date of Inspection : 10/06/2017
8. Name of the Inspecting officers : ADO V. B. Yadav
9. Name and designation of Officer
from the building side : Mr. Jitendra, Purchase Manager
10. Year of Construction : 2003
11. Applicant's letter No : Letter No. EPS/VE/2017/9-29/202, Dated 01/05/17

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	06 mtrs.	15 mtrs.	MR
	• Gate width	4.5 mtrs	4.5 mtrs.	MR
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper floor	02 nos	02 nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper floor	1.50 mtrs or less	1.50 mtrs & 1.0 mtrs	MR
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	01 nos.	01 nos.	MR
	e. Width of Corridor	1.50 mtrs.	2.30 mtrs.	MR
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers			
	• Total numbers	12 nos.	17 nos	MR
	• Types	ABC /CO ₂	ABC & CO ₂	MR
	• IS marking	ISI marked	Provided	MR


06	First-Aid-Hose Reels.			
	Total numbers on each floor	02 nos.	02 nos.	MR
	• Length of hose reel hose	30 mtrs.	30 mtrs.	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter	N/A	N/A	MR
08	MOEFA	N/A	N/A	N/A
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	02 nos.	02 nos.	MR
	• Hose box	02 nos.	02 nos.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	450 lpm	450 x 2 lpm	MR /
	• Head of the pump	40 M	40 M	MR /
	• Power supply	Required	Provided	MR /
	• Auto starting of pump	Required	Provided	MR /
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	5,000 ltr	10,000 ltr	MR
15	Exit Signage.	Required	Provided	MR

- 2/11 -

16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A


The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the Circular no. 262- 362 dated 17/01/2005 issued by Director of Education, it is recommended to issue Fire Safety Certificate.


Signature of the Inspecting Officer
Name :- V. B. Yadav
Designation :- A.D.O (T.Pur)

Submitted please.
DO(ED)

DeFO (ND2)


29/6



27/6