

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO. F6/DFS/MS/EH/2017/SZ/ 885

Dated: 21/06/17

FIRE SAFETY CERTIFICATE

Certified that the M/S Fire 'N' Ice Restaurant at Pankaj Arcade-III, Sector-10, Dwarka, New Delhi, is running at third floor of the building comprised of ground plus three upper floors was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/2014/SZ/EH/824 Dated 3.7.2014. The said premises was re-inspected by the officers concerned of this department on 29.5.2017 in presence of Sh. Pankaj Goyal (Sr. Manager) and found that the premises have deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010, and that the building is fit for occupancy class D "Assembly building ("Restaurant") with effect from.....21/06/17 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed overleaf.

Issued on21/06/17..... at New Delhi by

20/6
(Vipin Kental)
JLC (Chief Fire Officer)
Suj

Copy To:-

1. DHOWest Zone, Deputy Health Office, Municipal Corporation of Delhi, Najafgarh Zone New Delhi.
2. Manager, Fire 'N' Ice Restaurant, M/S Fire 'N' Ice Restaurant, 3rd floor at Pankaj Arcade-III, Sector-10, Dwarka, New Delhi.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	M/S Fire 'N' Ice estaurant, Pankaj Arcade-III, 3rd Floor, DDA Mkt., Sector-10, Dwarka, New Delhi.		
2	Type of Occupancy	Assembly "D" Restaurant		
3	Type of case	Renewal		
4	Details of previous NOC	No. F-6/DFS/MS/2014/SZ/EH/824 Dated 3.7.2014		
5	Fire safety directives letter No	F6/MS/DFS/GH/2005/711 dated 01.4.2005		
6	Date of inspection	29.5.2017		
7	Name of the inspecting Officers :	M K Chattopadhyay (DO S/W) S.P Bhardwaj ADO (Dwarka)		
8	Name and designation of officers	Sh. Pankaj Goyal (Sr. Manager)		
9	Year of construction	2002	Restaurant Runinig at 3rd Floor	
10	Applicant's letter No.	Nil Dated 16.5.2017	Building having Ground + 3 upper Floors	

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per Letter dated 01.4.2005	Provided as per letter dated 03.7.2014	Remarks MR / NMR
--------	---	--	--	------------------

1	Access to building			
	1) Road width	6 Mtrs.	20 Mtrs.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A

2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	One	One	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.25 Mtrs.	1.17 Mtrs.	MR being old case
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Requied	One	
	e. Width of corridor	N/A	1.25 Mtrs.	N/A
	f. Door size	2 Mtrs.	2 Mtrs.	MR

3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

4	Smoke Management system.			
	basement		N/A	N/A
		N/A		
		12 a/c per hour		
			Exhaust Fans	

Fire Extinguishers				
	total numbers			
	Types	4 Nos. CO2, ABC	4 Nos	MR
	ISI Marked	ISI Marked	ABC, CO2,	MR
6	First-Aid Hose Reels.		Yes	MR
	total numbers on each floor	1 No.	1 No.	MR
	Length of Hose reel hose	30 m	30 Mtrs.	MR
	Nozzle Diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	MR
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	Required	Provided in entire floor	MR
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level/			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450, 180 Lpm.	450,180 Lpm.	MR
	b. head of the pump	30 Mtrs.	30 Mtrs.	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	10000 Ltrs.	10000 ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	Required	Provided	MR
	d. Fireman's grounding switch	Required	Provided	MR

N/11

17	Standby power supply	Required	Provided	MR
18	Refuge Area.		Not Required	
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: CO2 Fire Extinguisher Provided near electric Panel			

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety requirements under the rules, renewal of Fire Safety Certificate issued vide letter No.F6/DFS/MS/2014/SZ/EH/824 dated 3.7.2014 is recommended under rules 37 of the Delhi Fire Service Act 2007 & Rules 2010.

Accordingly DFA is put up for approval and signature please.

[Signature]
9/6/17
M K Chattopadhyay
DO (S/W)

[Signature]
31/5/17
S.P Bhardwaj
ADO (DWARKA)

394/DO/S2
29/06/17

DCFO (S2)

949/CF S2
16/6/17 21/6

[Signature]
M/6



CFO (S2)

m. s. cell

F7 M.

[Signature]
16/6

FT is put up for signature please.

CFO S2

m-s cell

[Signature]
20/6

[Signature]
16/6/17