

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

Fax No. 011-23412593, Ph. 011-23412225

No. F6/DFS/MS/Petrol/2017/SZ/ 889

Dated: 21/06/17

FIRE SAFETY CERTIFICATE

Certified that M/s **Lotus Automobiles (IOCL Filling Station)** located at **Kh. No. 76/26, M.G. Road, Mehrauli, New Delhi**, comprised of Ground & First floor only was granted FSC by this department vide letter No F.6/DFS/MS/2014/SZ/717 dated 12/06/2014. The premises was re-inspected by the officer concerned of this department on 04/06/2017 in the presence of Mr. Rajender Kr. Sharma (Proprietor) of the said filling station and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Hazardous Building**" Group-J, as above with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010

Issued on 21/06/17 at New Delhi by


(Vipin Kental)
Chief Fire Officer

Copy to: -

1. The Joint C.P. (Lic.), First floor, PS Defence Colony, New Delhi-110049
2. The Proprietor, Lotus Automobiles, Kh. No. 76/26, M.G. Road, Mehrauli, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangement provided therein shall be maintained in good working condition at all time.
2. Any loss of life or property due to non-functional fire safety measures shall be the responsibility of the management.
3. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
4. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
5. This fire safety certificate may not be treated in any case for regularization of unauthorised construction, if any.
6. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & Address of the Building	Lotus Automobiles at Kh. No. 76/26, Mehrauli Gurgaon Road, Near Chattarpur Metro Station, Mehrauli, New Delhi-110030.		
2	Type of Occupancy	Hazardous Building "Group-J" (Filling Station)		
3	Building Comprised of	Ground floor only		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/2014/SZ/717 Dated 12/06/2014		
6	Fire Safety Directives Letter No			
7	Date of Inspection	04-06-2017		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mr. Rajender Kr. Sharma		
10	Year of construction	2004		
11	Applicant letter No.	No. Nil Dt.25-04-2017		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	As per Old NOC-2009	Provided at Site	Remarks MR/NMR
1	Access to Building.	Required	12 mtr	MR
	• Road width	N/A	N/A	N/A
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, width, type & arrangement of exits.			
	a. Number of Staircase			
	➤ Upper floors.	One	One	MR
	➤ Basement.	N/A	N/A	N/A
	b. Width of Staircase			
	➤ Upper floors	1.2 mtr	1.2 mtr	MR
	➤ Basement	N/A	N/A	N/A
	c. Protection of exits			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	N/A	N/A	N/A
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4.	Smoke Management system.			
	• Basement	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers.			
	• Total numbers		20 No's	MR
	• Types	ISI Marked	ABC-12, Co2-04 & Foam-04	MR
	• ISI Marking		Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	N/A	N/A	N/A
	• Length of hose-reel hose.	N/A	N/A	N/A
	• Nozzle Diameter	N/A	N/A	N/A

7	Automatic fire detection & alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants.			
	• Size of Riser/Down-comer	N/A	N/A	N/A
	• Number of Hydrant per floor	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
12.	Yard Hydrants.			
	• Total number of hydrants.	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	N/A	N/A	N/A
	➤ Head of main pump.	N/A	N/A	N/A
	➤ Number of main pumps.	N/A	N/A	N/A
	➤ Jockey Pump output.	N/A	N/A	N/A
	➤ Jockey Pump head.	N/A	N/A	N/A
	➤ Standby Pump output.	N/A	N/A	N/A
	➤ Standby Pump head.	N/A	N/A	N/A
	➤ Auto Starting / Manual Stopping.	N/A	N/A	N/A
	➤ Pump house access.	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump.	N/A	N/A	N/A
	➤ Head of pump.	N/A	N/A	N/A
	➤ Power supply.	N/A	N/A	N/A
	➤ Auto starting of pump.	N/A	N/A	N/A
14.	Captive water storage for Fire Fighting.			
	• Underground tank capacity.	N/A	N/A	N/A
	• Draw-off connection.	N/A	N/A	N/A
	• Fire Service Inlet.	N/A	N/A	N/A
	• Access to tank.	N/A	N/A	N/A
	• Overhead tank capacity.	N/A	N/A	N/A
15.	Exit Signage.	N/A	N/A	N/A
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	N/A	N/A	N/A
	• Pressurization of lift lobby.	N/A	N/A	N/A
	• Communication in lift car.	N/A	N/A	N/A
	• Fireman's switch.	N/A	N/A	N/A
	• Lift signage.	N/A	N/A	N/A
17.	Standby Power Supply	Required	Provided (DG Set)	MR
18.	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A

19.	Fire Control Room. 1. Detector system panel. 2. Flow switch panel. 3. PA system panel. 4. Battery backup. 5. Building floor plan.	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A

The Petrol filling station was inspected by the undersigned on 04.06.2017 in the presence of Mr. RK Sharma (Proprietor) and observed that filling station is comprised of ground and first floor only.

The fire protection system such as fire extinguishers of different type and capacity, fire buckets filled with sand & water provided at suitable places in the retail outlet area were checked and found functional at the time of inspection.

“No Smoking” sign boards were found displayed both in Hindi & English at conspicuous places. No loose electric wiring was seen in the premises.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/2014/SZ/717 dated 12.06.2014, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

R.N. Singh
8/6/17

Signature of the Inspecting Officer
Name : R.N. Singh
Designation: ADO

D. O. (SD)

Anilash
9/6/17

Dy. CFO/SZ

943/cfo 52
15/6/1916

[Signature]
14/6



CFO EPS

m. skell

15/6

[Handwritten mark]