

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

Fax No. 011-23412593, Ph. 011-23412225

No. F.6 DFS/MS/School/2017/SZ/

892

Dated:

21/06/17

FIRE SAFETY CERTIFICATE

Certified that the **S.D.M.C. Primary Co-Ed. School** located at **Maidan Garhi, New Delhi**, comprised of Ground + One upper floor, having total 13 rooms (7 Classrooms, 3 Store-room, 1 office & 1 staff room) was granted Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2014/SZ/335 dated 20.03.2014. The premise/building was re-inspected by the officer concerned of this department on 02/06/2017 in presence of Mr. Rajbir Singh (HOS) of the school and found that the School have complied with the fire prevention and fire safety requirements in accordance with circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education, Govt. of NCT of Delhi and that the school building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of **Three years**, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on21/06/17..... at New Delhi by.

4
9/16
(Vipin Kental)
Chief Fire Officer

Copy to: -

1. The Principal, S.D.M.C. Primary Co-Ed. School, Maidan Garhi, New Delhi-110068
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

hr
alc

Conditions for the validity of Fire Safety Certificate

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT				
1	Name & Address of the Building	South Delhi Municipal Corporation Primary Co-Ed. School, Maidan Garhi, New Delhi-68		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Ground + One upper floor		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/School/2014/SZ/335 Dt. 20.03.2014		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	02-06-2017		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mr. Rajbir Singh (HOS)		
10	Year of construction	2007 (C-2)		
11	Applicant letter No.	No. 01 Dt. 18.04.17 ODD No. 4847 dated 24/04/2017		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	As per old NOC-2014	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Required	06 mtr	MR
		Required	4.5 mtr	MR
		N/A	N/A	N/A
2	Number, width, type & arrangement of exits.			
	a. Number of Staircase			
	<ul style="list-style-type: none"> Upper floors. Basement. 	Two	Two	MR
		N/A	N/A	N/A
	b. Width of Staircase			
	<ul style="list-style-type: none"> Upper floors Basement 	Required	1.50m & 1.49m	MR
		N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A	N/A	N/A
		N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1 m	Provided	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door. Sealing of electrical shafts. Fire rating of shaft door. Water curtain Fire dampers. 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4.	Smoke Management system.			
	<ul style="list-style-type: none"> Basement Upper floors 	N/A	N/A	N/A
		N/A	N/A	N/A
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers Types ISI Marking 		5 No's	MR
		ISI Marked	ABC-5	MR
			Provided	MR
6.	First Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor. Length of hose-reel hose. Nozzle Diameter 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A

7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	N/A	N/A	N/A
		N/A	N/A	N/A
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting / Manual Stopping. Pump house access. Terrace Level <ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
14.	Captive water storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby Power Supply	N/A	N/A	N/A
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	N/A	N/A	N/A
		N/A	N/A	N/A

N/

19.	Fire Control Room.			
	1. Detector system panel.	N/A	N/A	N/A
	2. Flow switch panel.	N/A	N/A	N/A
	3. PA system panel.	N/A	N/A	N/A
	4. Battery backup.	N/A	N/A	N/A
	5. Building floor plan.	N/A	N/A	N/A
20.	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A

The Fire protection systems provided in the building were checked randomly and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the DOE circular 01/03/2011, FSC issued vide letter No. F.6/DFS/MS/School/2014/SZ/335 dated 20/03/2014, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

R.N. Singh
6/6/17

Signature of the Inspecting Officer
Name : R.N. Singh
Designation: ADO

D. O. (SD)

R.N. Singh
6/6/17

Dy. CB (S2)

[Signature]
6/6.

929/cbse
7/6/17/16

Chd (S1)

M.S. Jell

FTM.

Uk
7/6.

