

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

Fax No. 011-23412593, Ph. 011-23412225

No. F6/DFS/MS/Indl/2017/SZ/

891


Dated:

21/06/17

FIRE SAFETY CERTIFICATE

Certified that M/s **Ultimate Fashions Pvt. Ltd** located at **S-41, Okhla Industrial Area, Phase-II, New Delhi-110020**, comprised of Basement, Ground, Mezzanine + One upper floor was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/2013/SZ/1366 dated 31/12/2013. The building/premises was re-inspected by the officer concerned of this department on 03.06.2017 in the presence of Mr. Inderpal Singh (Director) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Industrial Building**" Group-G with effect from the date of issue of this certificate for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 21/06/17 at New Delhi by


(Vipin Kental)
Chief Fire Office

Copy to:-

1. M/s Ultimate Fashions Pvt. Ltd., S-41, Okhla Industrial Area, Phase-II, ND-110020
2. The Ex. Engineer (Bldg.), Bldg. Deptt., South MCD, Civic Centre, Minto Road, ND -110002


Conditions for the validity of Fire Safety Certificate

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained
4. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.


INSPECTION REPORT


1	Name & Address of the Building	M/s Ultimate Fashions Pvt. Ltd, S-41, Okhla Industrial Area Phase-II, New Delhi-20		
2	Type of Occupancy	Industrial Building (Group-G)		
3	Building Comprised of	Basement, Ground, Mezzanine + 1 upper floor.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/2013/SZ/1366 Dated 31-12-2013		
6	Fire Safety Directives Letter No	F.6/DFS/MS/94/BP/549 Dated 06-04-1994		
7	Date of Inspection	03-06-2017		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mr. Inderpal Singh (Director)		
10	Year of construction	1994		
11	Applicant letter No.	Nil Dt. Nil ODD No. 6709 Dt. 18.05.2017		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	As Per Old NOC-2013	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	1. Road width	Required	6 mtr	MR
	2. Gate width	Required	4.5 mtr	MR
	3. Width of internal road	N/A	N/A	N/A
2	Number, width, type and arrangements of exits.			
	a. Number of Staircase			
	1. Upper floors	2 No's	2 No's	MR
	2. Basement floor	2 No's	2 No's	MR
	b. Width of Staircase			
	1. Upper floors	Required	1.35 & 1.20 mtr	MR (old case)
	2. Basement floor	Required	1.25 & 1.14 mtr	MR (old case)
	c. Protection of exits			
	1. Fire check door	Required in basement	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Two	Two	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	N/A	N/A	N/A
3	Compartmentation.			
	1. Fire check door.	Required in basement	Provided	MR
	2. Sealing of electrical shafts.	N/A	N/A	N/A
	3. Fire rating of shaft door.	N/A	N/A	N/A
	4. Water curtain	N/A	N/A	N/A
	5. Fire dampers.	N/A	N/A	N/A
4.	Smoke Management system.			
	1. Basement	30 a/c per hour	Exhaust fan provided	MR
	2. Upper floors	12 a/c per hour	Exhaust fan provided	MR
5.	Fire Extinguishers.			
	1. Total numbers		22 No's	MR
	2. Types	ISI Marked	Co2-07, W.Co2-05, ABC-10	MR
	3. ISI Marking		Provided	MR
6.	First Aid Hose Reels.			
	1. Total numbers on each floor.	Hose-reel	01	MR
	2. Length of hose-reel hose.		30 m	MR
	3. Nozzle Diameter		5 mm	MR

7	Automatic Fire Detection and Alarming system.			
	1. Type of detectors	N/A	N/A	N/A
	2. Location of Main Panel	N/A	N/A	N/A
	3. Location of Repeater Panel	N/A	N/A	N/A
	4. Alternate source of power	N/A	N/A	N/A
	5. Hooter's location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1. Basement	N/A	Provided	N/A
	2. Upper floors	N/A	N/A	N/A
	3. Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants.			
	1. Size of Riser / Down-comer	N/A	N/A	N/A
	2. Number of Hydrant per floor	N/A	N/A	N/A
	3. Hose box.	N/A	N/A	N/A
12.	Yard Hydrants.			
	1. Total number of hydrants.	N/A	N/A	N/A
	2. Hose box.	N/A	N/A	N/A
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	N/A	N/A	N/A
	➤ Head of main pump.	N/A	N/A	N/A
	➤ Number of main pumps.	N/A	N/A	N/A
	➤ Jockey Pump output.	N/A	N/A	N/A
	➤ Jockey Pump head.	N/A	N/A	N/A
	➤ Standby Pump output.	N/A	N/A	N/A
	➤ Standby Pump head.	N/A	N/A	N/A
	➤ Auto Starting / Manual Stopping.	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump.	Required	1200 LPM	MR
	➤ Head of pump.	Required	40 mtr	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for fire fighting.			
	• Underground tank capacity.	N/A	N/A	N/A
	➤ Draw-off connection.	N/A	N/A	N/A
	➤ Fire Service Inlet.	N/A	N/A	N/A
	➤ Access to tank.	N/A	N/A	N/A
	• Overhead tank capacity.	5,000 Ltr	20,000 Ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	1. Pressurization of lift shaft.	N/A	N/A	N/A
	2. Pressurization of lift lobby.	N/A	N/A	N/A
	3. Communication in lift car.	N/A	N/A	N/A
	4. Fireman's switch.	N/A	N/A	N/A
	5. Lift signage.	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided (DG Set)	MR
18.	Refuge Area			
	1. Total area	NA	NA	NA
	2. Location	NA	NA	NA
19.	Fire Control Room.			


19.	Fire Control Room.			
	1. Detector System Panel.	NA	NA	NA
	2. Flow Switch Panel.	NA	NA	NA
	3. PA system Panel.	NA	NA	NA
	4. Battery backup	NA	NA	NA
	5. Building floor plan	NA	NA	NA
20.	Special Fire Protection System for the Protection of special Risk, if any.	Required	02 No's Co2 type fire extinguisher provided	MR
<p>The fire protection system provided in the building were tested and found functional at the time of inspection.</p> <p>In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under rules, renewal of the FSC issued vide letter No. F.6/DFS/MS/2013/SZ/1366 dated 31.12.2013, under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.</p> <p>Accordingly DFA is put up for perusal and signature please</p>				
<p> Signature of the Inspecting Officer Name : R.N. Singh Designation: ADO</p>				

Div. Officer (SD)


8/6/17


Dy. Chief Fire Officer




9/6

938/062
14/6/17-15/6