

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

Fax No. 011-23412593, Ph. 011-23412225

No. F.6 DFS/MS/School/2017/SZ/906

Dated: 23.06.17

**FIRE SAFETY CERTIFICATE**

Certified that the **Laxman Public School (Hostel building)** located at **Hauz Khas Enclave, New Delhi**, comprised of **Two Blocks** (Block-1 comprised of Ground + 02 upper floors) & (Block-2 comprised of Ground + 03 upper floors) was granted FSC by this department vide letter No. F.6/DFS/MS/School/2012/958 dated 20.11.2012. The building was re-inspected by the officer concerned of this department on 12/06/2017 in presence of Mr. Neeraj Vajpai (Admn) of the school and found that the said school building have complied with the fire prevention and fire safety requirements in accordance with circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education, Govt. of NCT of Delhi and that the school building is fit for occupancy class "**Educational Building**" with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 23.06.17 at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer

Copy to: -

1. The HOS, Laxman Public School, Hauz Khas Enclave, New Delhi-110016
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

1	Name & Address of the Building	Laxman Public School (Hostel Building), Hauz Khas Enclave, New Delhi-110016		
2	Type of Occupancy	Group-B, "Educational Building" (School)		
3	Building Comprised of	Block 1- Ground + 2 upper floors. Block 2- Ground + 3 upper floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/School/2012/958 dated 20.11.2012 (for boys hostel & Principal residence-cum-girls hostel)		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	12/06/2017		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mr. Neeraj Vajpai (Admn)		
10	Year of construction	1990		
11	Applicant letter No.	LPS/Admin/DFS/2017-18 dated 09/05/2017		
<b>S. No</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>NBC/BBL requirement</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
1	<b>Access to Building.</b>			
	1. Road width	6 Mtr	9 Mtr	MR
	2. Gate width	-NA-	4.5 Mtr	-NA-
	3. Width of internal road	-NA-	NA	-NA-
2	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	1. Upper floors	One in each block	Block 1- 2 No's Block 2- 3 No's	MR
	2. Basement floor	-NA-	-NA-	-NA-
	<b>b) Width of Staircase</b>			
	1. Upper floors	1.50 m	Block 1- 1.50m, 0.95m Block 2- 1.20m, 1.13m & 2.0m (Iron)	MR
	2. Basement floor	-NA-	-NA-	-NA-
	<b>c) Protection of exits</b>			
	1. Fire check door	-NA-	-NA-	-NA-
	2. Pressurization	-NA-	-NA-	-NA-
	<b>d) No. of continuous staircase to terrace</b>	One in each block	Provided	MR
	<b>e) Width of corridor</b>	-NA-	-NA-	-NA-
	<b>f) Door size</b>	1 m	1 m	MR
3	<b>Compartmentation.</b>			
	1. Fire check door.	-NA-	-NA-	-NA-
	2. Sealing of electrical shafts.	-NA-	-NA-	-NA-
	3. Fire rating of shaft door.	-NA-	-NA-	-NA-
	4. Water curtain	-NA-	-NA-	-NA-
	5. Fire dampers.	-NA-	-NA-	-NA-
4.	<b>Smoke Management system.</b>			
	1. Basement.	-NA-	-NA-	-NA-
	2. Upper floors	-NA-	-NA-	-NA-
5.	<b>Fire Extinguishers.</b>			
	1. Total numbers		30 No's (both the blocks)	MR
	2. Types	ISI Marked	ABC- 15, WCo2- 15	MR
	3. ISI Marking		Provided	MR
6.	<b>First Aid Hose Reels.</b>			
	1. Total numbers on each floor.	Hose Reels	One/floor (each block)	MR
	2. Length of hose-reel hose.		30 m	MR
	3. Nozzle Diameter		5 mm	MR

Renewal

Laxman Public School (Hostel Bldg.), Hauz Khas Enclave

7	<b>Automatic fire detection &amp; alarming system.</b>			
	1. Type of detectors	-NA-	-NA-	-NA-
	2. Location of Main Panel	-NA-	-NA-	-NA-
	3. Location of Repeater Panel	-NA-	-NA-	-NA-
	4. Alternate source of power	-NA-	-NA-	-NA-
	5. Hooter's location	-NA-	-NA-	-NA-
8.	<b>MOEFA / SIREN</b>	Required	Provided	MR
9.	<b>Public Address System</b>	-NA-	Provided	-NA-
10.	<b>Automatic Sprinkler System</b>			
	1. Basement.	-NA-	-NA-	-NA-
	2. Upper floors	-NA-	-NA-	-NA-
	3. Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	<b>Internal Hydrants.</b>			
	1. Size of Riser / Down-comer	-NA-	Provided	-NA-
	2. Number of Hydrant per floor	-NA-	One	-NA-
	3. Hose box.	-NA-	One	-NA-
12.	<b>Yard Hydrants.</b>			
	1. Total number of hydrants.	-NA-	-NA-	-NA-
	2. Hose box.	-NA-	-NA-	-NA-
13.	<b>Pumping arrangements.</b>			
	• <b>Ground Level</b>			
	➤ Discharge of main pump.	-NA-	-NA-	-NA-
	➤ Head of main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps.	-NA-	-NA-	-NA-
	➤ Jockey Pump output.	-NA-	-NA-	-NA-
	➤ Jockey Pump head.	-NA-	-NA-	-NA-
	➤ Standby Pump output.	-NA-	-NA-	-NA-
	➤ Standby Pump head.	-NA-	-NA-	-NA-
	➤ Auto Starting / Manual Stopping.	-NA-	-NA-	-NA-
	• <b>Terrace Level</b>			
	➤ Discharge of pump.	450 LPM	450 LPM × 2	MR
	➤ Head of pump.	40 Mtr	40 m each	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	<b>Captive water storage for Fire Fighting.</b>			
	1. Underground tank capacity.	-NA-	-NA-	-NA-
	➤ Draw-off connection.	-NA-	-NA-	-NA-
	➤ Fire Service Inlet.	-NA-	-NA-	-NA-
	➤ Access to tank.	-NA-	-NA-	-NA-
	2. Overhead tank capacity.	10,000 Ltr	Provided	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	1. Pressurization of lift shaft.	-NA-	-NA-	-NA-
	2. Pressurization of lift lobby.	-NA-	-NA-	-NA-
	3. Communication in lift car.	-NA-	-NA-	-NA-
	4. Fireman's switch.	-NA-	-NA-	-NA-
	5. Lift signage.	-NA-	-NA-	-NA-
17.	<b>Standby Power Supply</b>	-NA-	Provided (DG Set)	-NA-
18.	<b>Refuge Area</b>			
	1. Total area	-NA-	-NA-	-NA-
	2. Location	-NA-	-NA-	-NA-

Renewal

Laxman Public School (Hostel Bldg.), Hauz Khas Enclave

N/12

<b>19.</b>	<b>Fire Control Room.</b>			
	1. Detector System Panel.	-NA-	-NA-	-NA-
	2. Flow Switch Panel.	-NA-	-NA-	-NA-
	3. PA system Panel.	-NA-	-NA-	-NA-
	4. Battery backup	-NA-	-NA-	-NA-
	5. Building floor plan	-NA-	-NA-	-NA-
<b>20.</b>	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>			-NA-
<p>The Fire protection systems provided in the building were checked randomly and found functional at the time of inspection. The shortcomings communicated vide letter dated 03/11/16 have been complied. the school management has provided additional staircase (iron made). ✓</p> <p>Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/DFS/MS/School2012/SZ/958 dated 20.11.2012, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.</p> <p>Accordingly DFA is put up for approval and signature please.</p> <p style="text-align: right;"><i>R.N. Singh</i> 14/6/17</p> <p style="text-align: right;">Signature of the Inspecting Officer Name : R.N. Singh Designation: ADO</p>				

Renewal

Laxman Public School (Hostel Bldg.), Hauz Khas Enclave

DO (SD)

*Anilash*  
14/6/17