

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

Fax No. 011-23412593, Ph. 011-23412225

No. F6/DFS/MS/EH/2017/SZ/910

Dated: 23.06.17

FIRE SAFETY CERTIFICATE

Certified that the M/s **Pizza Express restaurant** located at **T-303 B, Third floor, Ambience Mall, Vasant Kunj**, running at third floor of the building, comprised of three tier basement, ground + three upper floors was granted FSC by this department vide letter No. F.6/DFS/MS/EH/2014/SZ/942 dated 30.07.2014. The premises was re-inspected by the officer concerned of this department on 10/06/2017 in the presence of Mr. Sumit (Manager) of the eating house and observed that the said premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class-D "**Assembly Building**" (Eating House) as above with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 23.06.17 at New Delhi by


(Vipin Kental)
Chief Fire Officer

Copy to: -

1. M/S Pizza Express restaurant (A Unit of Gourmet Investments Pvt Ltd),
T-303B, Third floor, Ambience Mall, Vasant Kunj, New Delhi-110070
2. The Joint C.P. (Lic.), First Floor, PS Defence Colony, New Delhi-110049

Conditions for the validity of Fire Safety Certificate

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye Laws.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & Address of the Building	M/s Pizza Express Restaurant, T-303 B, Third floor, Ambience Mall, Vasant Kunj, ND-70 (A Unit of Gourmet Investment Pvt. Ltd.)		
2	Type of Occupancy	Assembly Building "Group-D" Restaurant		
3	Building Comprised of	Three tier Basement, Ground + 03 upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/EH/2014/SZ/942 Dated 30-07-2014		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	10-06-2017		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mr. Sumit (Manager)		
10	Year of construction	2006-07	Restt running at 3 rd floor in Ambience Mall building.	
11	Applicant letter No.	Nil dated Nil ODD no. 6825 Dated 22-05-2017		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.	F.6/DFS/MS/Mall/SZ/2017/33 dated 09/01/2017		
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Restaurant within Mall	As above As above As above	MR N/A N/A
2	Number, width, type & arrangement of exits.			
	a. Number of Staircase	Provided & Maintained by Ambience Mall		
	<ul style="list-style-type: none"> Upper floors Basement floor 	2 No's N/A	As above As above	MR N/A
	b. Width of Staircase	Provided & Maintained by Ambience Mall		
	<ul style="list-style-type: none"> Upper floors Basement floor 	Required N/A	As above As above	MR N/A
	c. Protection of exits	Provided & Maintained by Ambience Mall		
	<ul style="list-style-type: none"> Fire check door Pressurization 	Required N/A	As above As above	MR N/A
	d. No. of continuous staircase to terrace	Required	As above	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	2.0 mtr	2.0 mtr & 1.22 mtr	MR
3	Compartmentation.	Provided & Maintained by Ambience Mall		
	<ul style="list-style-type: none"> Fire check door. Sealing of electrical shafts. Fire rating of shaft door. Water curtain Fire dampers. 	N/A N/A N/A N/A N/A	As above As above N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management system.	Provided & Maintained by Ambience Mall		
	<ul style="list-style-type: none"> Basement Upper floors 	N/A Required	As above Exhaust fans provided	N/A MR
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers Types ISI Marking 	ISI marked	07 No's ABC-04, W.Co2-03 Provided	MR MR MR
6.	First Aid Hose Reels.	Provided & Maintained by Ambience Mall		
	<ul style="list-style-type: none"> Total numbers on each floor. Length of hose-reel hose. Nozzle Diameter 	Hose-reel	Provided near Restt. 30m 5mm	MR MR MR

M/s Pizza Express Restt, T-303 B, Third floor, Ambience Mall, Vasant Kunj, New Delhi

7	Automatic fire detection & alarming system.	Provided & Maintained by Ambience Mall		
	• Type of detectors	Required	Smoke & Heat	MR
	• Location of Main Panel	Required	As above	MR
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	Required	As above	MR
	• Hooter's location	Required	As above	MR
8.	MOEFA	Required	As above	MR
9.	Public Address System	N/A	As above	N/A
10.	Automatic Sprinkler System	Provided & Maintained by Ambience Mall		
	• Basement	Required	As above	MR
	• Upper floors	Required	Provided in Restt.	MR
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants.	Provided & Maintained by Ambience Mall		
	• Size of Riser/Down-comer	Required	As above	MR
	• Number of Hydrant per floor	Required	As above	MR
	• Hose box.	Required	As above	MR
12.	Yard Hydrants.	Provided & Maintained by Ambience Mall		
	• Total number of hydrants.	N/A	As above	N/A
	• Hose box.	N/A	As above	N/A
13.	Pumping arrangements.	Provided & Maintained by Ambience Mall		
	• Ground Level	Provided & Maintained by Ambience Mall		
	➤ Discharge of main pump.	4500 LPM	As above	MR
	➤ Head of main pump.	70 mtr	As above	MR
	➤ Number of main pumps.	Two	As above	MR
	➤ Jockey Pump output.	450 LPM	As above	MR
	➤ Jockey Pump head.	70 mtr	As above	MR
	➤ Standby Pump output.	4500 LPM	As above	MR
	➤ Standby Pump head.	70 mtr	As above	MR
	➤ Auto Starting / Manual Stopping.	Required	As above	MR
	• Terrace Level	Provided & Maintained by Ambience Mall		
	➤ Discharge of pump.	N/A	N/A	N/A
	➤ Head of pump.	N/A	N/A	N/A
	➤ Power supply.	N/A	N/A	N/A
	➤ Auto starting of pump.	N/A	N/A	N/A
14.	Captive water storage for Fire Fighting.	Provided & Maintained by Ambience Mall		
	• Underground tank capacity.	5,00,000 Ltr	As above	MR
	➤ Draw-off connection.	Required	As above	MR
	➤ Fire Service Inlet.	Required	As above	MR
	➤ Access to tank.	Required	As above	MR
	• Overhead tank capacity.	20,000 Ltr	As above	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.	Provided & Maintained by Ambience Mall		
	• Pressurization of lift shaft.	N/A	N/A	N/A
	• Pressurization of lift lobby.	N/A	N/A	N/A
	• Communication in lift car.	N/A	N/A	N/A
	• Fireman's switch.	N/A	N/A	N/A
	• Lift signage.	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided (DG Set)	MR
18.	Refuge Area	Provided & Maintained by Ambience Mall		
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A

M/s Pizza Express Restt, T-303 B, Third floor, Ambience Mall, Vasant Kunj, New Delhi

N/ 9

19.	Fire Control Room.	Provided & Maintained by Ambience Mall		
	• Detector System Panel.	N/A	As above	N/A
	• Flow Switch Panel.	N/A	As above	N/A
	• PA system Panel.	N/A	As above	N/A
	• Battery backup	N/A	As above	N/A
	• Building floor plan	N/A	As above	N/A
20.	Special Fire Protection System for the Protection of special Risk, if any :	N/A	As above	N/A

The Fire protection systems provided in the building were checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/EH/2014/SZ/942 Dated 30/07/2014, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

R.N. Singh
15/6

Signature of the Inspecting Officer
Name : R.N. Singh
Designation: ADO

M/s Pizza Express Restt, T-303 B, Third floor, Ambience Mall, Vasant Kunj, New Delhi

D.O. (SD)

Put up with FSC of Mall.

Anilash
16/6/14

AND