

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO. F6/DFS/MS/School/2017/SZ/ 937

Dated: 29/06/17

FIRE SAFETY CERTIFICATE

Certified that the Jindal Public School located at Dashrathpuri, Dwarka Palam Road, New Delhi-110045, having two blocks namely A & B Block, A Block comprised of ground plus two upper floors & B Block comprised of ground plus one upper floor was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2014/SZ/574 dated 7.5.2014. The said School building was re-inspected by the officer concerned of this department on 13.6.2017 in presence of Sh. Uttam Singh (Principal) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance Directorate of Education circular no. 262-362 dated 17.1.2005 and that the premises/building is fit for occupancy class B "Educational building" with effect from 29/06/17... for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed overleaf.

Issued on ... 29/06/17 at New Delhi by

U
27/6.
(Vipin Kental)
o/c Chief Fire Officer
Delhi Fire Service
SH

Copy to:-

1. The Deputy Director (Education), Govt. of NCT of Delhi, Old Secretariat, New Delhi-54.
2. The Principal, Jindal Public School located at Dashrathpuri, Dwarka Palam Road, New Delhi-110045.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	Jindal Public School, Dashrathpuri, Dwarka Palam Road, New Delhi-110045.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal (Ground Plus Two Upper Floors)		
4	Details of previous NOC	F6/DFS/MS/School/2014 dated 07.05.2014		
5	Fire safety directives letter No	Directorate of Education CIR. Dated 262-362 dated 17.1.2005		
6	Date of inspection	13.06.2017		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Sh. Uttam Singh (Principal)		
9	Year of construction	2001		
10	Applicant's letter No.	Nil dated 23.6.2017		

			Two Blocks A Block G + 2 & B Block G + 1	
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	DOE CIR. Dated 17.1.2005/ Letter dated 9.2.2009	Provided at site as per letter dated 7.5.2014	Remarks MR / NMR

1	Access to building			
	1) Road width	6 Mtrs.	Provided	MR
	2) Gate width	4.5 Mtrs.	Provided	MR
	3) Width of internal road	N/A	N/A	N/A

2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	A Block:3 Nos. B Block 2 Nos.	A Block:3 Nos. B Block 2 Nos.	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.50 Mtrs.each	A Block: (1 No. G to 1st Floor 1.50 Mtrs.) 2 Nos. 1.25 & 1.22 Mtrs. B Block: 2 Nos.1.28 & .75 Mtrs.	MR being old case
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Required	2 Nos. each block	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1 Mtr.	1 Mtr.	MR

3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

4	Smoke Management system.			
	basement	N/A	N/A	N/A
		12 a/c charge		
	upper floors		Natural Vent.	MR

5	Fire Extinguishers			
	total numbers		20 Nos.	MR
	Types	One No. CO2 OR ABC for every 300 Sq.Mtrs.	CO2 & ABC	MR
	ISI marking	ISI Marked	Provided	MR

6	First-Aid Hose Reels.			
	total numbers on each floor	One each block	2 Nos. in A Block & 1 No. in B Block	MR
	Length of Hose reel hose	30 m	30 m	
	Nozzle Diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	Required	100 mm	MR
	Number of Hydrants per floor	One each block	2 Nos. in A Block & 1 No. in B Block	MR
	hose Box	Required	Provided	MR
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450 & 180 LPM each Block	450 & 180 LPM each block	MR
	b. head of the pump	40 Mtrs.	40 Mtrs.	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	MR
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	5000 Lts.	5000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

419

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	area location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: CO2 Fire Extinguisher Provided near Electric Panel	MR		

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety required as per DOE CIR. dated 17.1.2005, renewal FSC issued vided letter no.F6/DFS/MS/School/2014/SZ/574 dated 7.5.2014 , is recommended for A Block ground plus two upper floors & B Block Ground plus One upper floor under rules 37 of the Delhi Fire Service Rules 2010.

Accordingly DFA is put up for approval and signature please.

S.P. Bhardwaj
14/6/12

S.P. Bhardwaj
ADO (Dwarka)

443/DO(S2)
19.06.2012

DO/SW

[Signature]
18/6/12

DCFO(S2)