

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No.

F6/DFS/MS/Club/2014/SZ/644/903

Dated:

29/6/17

FIRE SAFETY CERTIFICATE

Certified that M/s Delhi Gymkhana Club located at No.2, Safdarjung Road, New Delhi-110011, comprised of ground floor only, owned/occupied by M/s Delhi Gymkhana Club Ltd was granted FSC by this department vide letter No. F6/DFS/MS/Club/2014/SZ/644, dated 27-05-2014. The premises was re-inspected by the officer concerned of this department on 07-06-2017 in the presence of Col (Retd) Ravinder Kumar, Assistant Secretary and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "D" Assembly (Club House) at ground floor only with effect from ~~23/6/17~~ 29/6/17 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ... 29/06/2017 at New Delhi by.

(Vipin Kental)

Chief Fire Officer

T.No.011-23412225

Copy to:- 1.MOH, NDMC, Palika Kendra, New Delhi-110001.

2. M/s Delhi Gymkhana Club located at No.2, Safdarjung Road, New Delhi-110011.

Conditions for the validity of fire safety certificate are as under:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. The employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All fire fighting equipments shall be maintained in perfect working condition all time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate, six month prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : M/s Delhi Gymkhana Club located at No.2, Safdarjung Road, New Delhi-110011.
2. Building is comprised of : Ground floor only.
3. Type of Occupancy : Group-D, Assembly Building (Club House).
4. Type of Case : Old Case
5. Details of Previous NOC : No.F.6/DFS/MS/Club/2014/SZ/644, dated-27.05.14.
6. Fire Safety direction letter No : Nil.
7. Date of Inspection : 07.06.2017.
8. Name of the Inspecting Officers : Vedpal (ADO)
9. Name and designation of Officer from the building side : Col. (Rtd) Ravinder Kumar.
10. Year of Construction : Not Known.
11. Applicant's letter No : No. Nil, dated 16.05.17.

| S.No | Minimum Standards on fire prevention and fire safety U/R33 | Requirements as per Old NOC/Existing Fire Safety System | Provided at Site | Remarks |
|--------------|--|---|---|---------|
| 1 | Access to building | | | |
| | Road width | Accessible | 9m | MR |
| | Gate width | Required | 4.5m (02nos) | MR |
| | Width of internal road | N.A. | N.A. | N.A. |
| 2 | Number, Width, Type and Arrangement of Exits. | | | |
| | a. Number of Staircases | | | |
| | Upper Floor | N.A. | N.A. | N.A. |
| | Basement | N.A. | N.A. | N.A. |
| | B. Width of Staircases | | | |
| | Upper Floor | N.A. | N.A. | N.A. |
| | Basement | N.A. | N.A. | N.A. |
| | c. Protection of exits | | | |
| | Fire check door | N.A. | N.A. | N.A. |
| | Pressurization | N.A. | N.A. | N.A. |
| | e. No. of continuous staircases to terrace | N.A. | 01no. | N.A. |
| | | N.A. | N.A. | N.A. |
| | g. Width of Corridor | | | |
| h. Door Size | Required | 02 Exits in each eating house | MR(old case) | |
| 3 | Compartmentation | | | |
| | Fire check door | N.A. | N.A. | N.A. |
| | Sealing of electrical shafts | N.A. | N.A. | N.A. |
| | Fire rating of shaft door | N.A. | N.A. | N.A. |
| | Water curtain | N.A. | N.A. | N.A. |
| | Fire Dampers | N.A. | N.A. | N.A. |
| | | N.A. | N.A. | N.A. |
| 4 | Smoke Management System. | | | |
| | Basement | N.A. | N.A. | N.A. |
| | Upper floor | 12 a/c per hour | Exhaust fans and natural ventilation Provided | MR |
| 5. | Fire Extinguisher | | | |
| | Total numbers | 30 nos. | 30 nos. | MR |
| | types | CO ₂ & ABC | CO ₂ & ABC | MR |
| | IS marking | ISI marked | ISI marked | MR |
| 6 | First-aid-Hose Reels. | | | |
| | Total numbers at ground floor | 12nos. | 12nos. | MR |
| | Length of hose reel hose | 30m | 30m | MR |

| | | | | |
|----|---|------------|------------------------------|--------------|
| 7 | Automatic fire detection and alarming system. | | | |
| | Type of detectors | N.A. | N.A. | N.A. |
| | Location of main panel | N.A. | N.A. | N.A. |
| | Location of repeater panel | N.A. | N.A. | N.A. |
| | Alternate source of power | N.A. | N.A. | N.A. |
| | Hooters | N.A. | N.A. | N.A. |
| 8 | MOEFA | Required | Provided | MR |
| 9 | Public address System. | Required | Provided | MR |
| 10 | Automatic Sprinkler System. | | | |
| | Basement | N.A. | N.A. | N.A. |
| | upper floor | N.A. | N.A. | N.A. |
| | sprinkler above false ceiling | N.A. | N.A. | N.A. |
| 11 | Internal Hydrants | | | |
| | size of riser/down-comer | N.A. | N.A. | N.A. |
| | Number of hydrants per floor | N.A. | N.A. | N.A. |
| | Hose Box | N.A. | N.A. | N.A. |
| 12 | Yard Hydrants. | | | |
| | Total number of hydrants | N.A. | N.A. | N.A. |
| | Hose Box | N.A. | N.A. | N.A. |
| 13 | Pumping Arrangements. | | | |
| | • Ground Level | Required | 450 & 180LPM | MR(old case) |
| | ➤ Discharge of main Pump | Required | 450 & 180LPM | MR(old case) |
| | ➤ Head of Main Pump | Required | 70m & 40m | MR(old case) |
| | ➤ Number of main pumps | Required | 01no. | MR(old case) |
| | ➤ Jockey pump out put | N.A. | N.A. | N.A. |
| | ➤ Jockey pump head | N.A. | N.A. | N.A. |
| | ➤ Standby pump out put | N.A. | N.A. | N.A. |
| | ➤ Standby pump Head | N.A. | N.A. | N.A. |
| | ➤ Auto Starting /Manual stopping | Required | Provided | MR |
| | ➤ Pump House Access | Required | Provided | MR |
| | • Terrace Level | N.A. | N.A. | N.A. |
| | ➤ Discharge of pump | N.A. | N.A. | N.A. |
| | ➤ Head of the Pump | N.A. | 40m | MR |
| | ➤ Power supply | N.A. | N.A. | N.A. |
| | ➤ Auto Starting of pump | N.A. | N.A. | N.A. |
| 14 | Captive Water Storage for Fire Fighting. | | | |
| | On ground tank capacity | N.A. | N.A. | N.A. |
| | Draw-off connection | N.A. | N.A. | N.A. |
| | Fire service inlet | N.A. | N.A. | N.A. |
| | Access to tank | N.A. | N.A. | N.A. |
| | Overhead Tank capacity | 15000Ltrs. | 15000Litrs | MR(old case) |
| 15 | Exit Signage. | Required | Provided | MR |
| 16 | Provision of Lifts. | | | |
| | Pressurization of Lift Shaft | N.A. | N.A. | N.A. |
| | Pressurization of Lift lobby | N.A. | N.A. | N.A. |
| | Communication in lift car | N.A. | N.A. | N.A. |
| | Firemen's grounding switch | N.A. | N.A. | N.A. |
| | Lift Signage | N.A. | N.A. | N.A. |
| 17 | Standby power supply | Required | Provided 50Kva Generator set | MR |
| 18 | Refuge Area. | | | |
| | Total area | N.A. | N.A. | N.A. |
| | Location | N.A. | N.A. | N.A. |


N/20

M/s Delhi Gymkhana Club located at No.2, Safdarjung Road, New Delhi-110011.

| | | | | |
|----|---|------|------|------|
| 19 | Fire Control Room | | | |
| | Detector system panel | N.A. | N.A. | N.A. |
| | Flow switch panel | N.A. | N.A. | N.A. |
| | PA system panel | N.A. | N.A. | N.A. |
| | Batter backup | N.A. | N.A. | N.A. |
| | Building Floor Plans | N.A. | N.A. | N.A. |
| 20 | Special Fire Protection systems for of special Risks, if any: | N.A. | N.A. | N.A. |

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the FSC issued vide letter No.F.6/DFS/MS/Club/2014/SZ/644, dated 27.05.2014 renewal under rule 37 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly DFA is put up for your approval and signature please.

 9/6/17

Signature of the Inspecting Officer

Name : Vedpal

Designation : ADO

~~D.O. (S.D)~~

~~Divilash~~
12/6/17

~~dy. (S.D)~~

